

2004 Industrial Sewage Monthly Summary - Central Region

Canadian Pacific Railway Company 2025 McCowan Road
Toronto

Sector: Miscellaneous
Ministry Office: Toronto

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

TOTAL SUSPENDED SOLIDS

C of A Non-Compliance

March 9, 2004 - December 31, 2004	25	mg/L	24hr	12 exceedances	26	250	Conducting Study	Assessment underway
--------------------------------------	----	------	------	----------------	----	-----	------------------	---------------------

Total C of A Non-Compliance = 12 exceedances

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility and ministry action are current to October 2005. Conviction information is current to January 2006. For up-to-date information, please contact the appropriate district or area office."

2004 Industrial Sewage Monthly Summary - Central Region

Magna Structural Systems Inc.

400 Chisholm Drive
Milton

Sector: Miscellaneous
Ministry Office: Halton-Peel

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

OIL AND GREASE

C of A Non-Compliance

April 2004	10	mg/L	any	3 exceedances	12	25	Action Plan Submitted - Implementing Improvements	Other Abatement Action taken
May 2004	10	mg/L	any	5 exceedances	17	56	Action Plan Submitted - Implementing Improvements	Other Abatement Action taken
June 2004	10	mg/L	any	2 exceedances	34	39	Action Plan Submitted - Implementing Improvements	Other Abatement Action taken

Total C of A Non-Compliance = 10 exceedances

TOTAL SUSPENDED SOLIDS

C of A Non-Compliance

January 2004	15	mg/L	any	2 exceedances	18	33	Action Plan Submitted - Implementing Improvements	Other Abatement Action taken
March 2004	15	mg/L	any	10 exceedances	16	54	Action Plan Submitted - Implementing Improvements	Other Abatement Action taken
April 2004	15	mg/L	any	9 exceedances	16	52	Action Plan Submitted - Implementing Improvements	Other Abatement Action taken

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility and ministry action are current to October 2005. Conviction information is current to January 2006. For up-to-date information, please contact the appropriate district or area office."

2004 Industrial Sewage Monthly Summary - Central Region

Magna Structural Systems Inc.

400 Chisholm Drive
Milton

Sector: Miscellaneous
Ministry Office: Halton-Peel

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
May 2004	15	mg/L	any	8 exceedances	16	37	Action Plan Submitted - Implementing Improvements	Other Abatement Action taken
June 2004	15	mg/L	any	10 exceedances	16	46	Action Plan Submitted - Implementing Improvements	Other Abatement Action taken
July 2004	15	mg/L	any	9 exceedances	16	82	Action Plan Submitted - Implementing Improvements	Other Abatement Action taken
August 2004	15	mg/L	any	1 exceedance	166		Action Plan Submitted - Implementing Improvements	Other Abatement Action taken
September 2004	15	mg/L	any	2 exceedances	46	85	Action Plan Submitted - Implementing Improvements	Other Abatement Action taken

Total C of A Non-Compliance = 51 exceedances

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility and ministry action are current to October 2005. Conviction information is current to January 2006. For up-to-date information, please contact the appropriate district or area office."

2004 Industrial Sewage Monthly Summary - Central Region

Ontario Power Generation Inc. - Darlington

2151 South Service Road
Clarington

Sector: Electric Power Generation
Ministry Office: York-Durham

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

ACUTE LETHALITY - DAPHNIA

Clean Water Regulations

July 2004	Pass	acute toxicity	any	1 exceedance	Fail		other	Assessment Complete - No Further Action Required
-----------	------	----------------	-----	--------------	------	--	-------	--

Total Clean Water Regulations = 1 exceedance

TOTAL SUSPENDED SOLIDS

Clean Water Regulations

August 2004	44	mg/L	daily	1 exceedance	44.4		other	Assessment Complete - No Further Action Required
October 2004	18	mg/L	mon avg	1 exceedance	21.83		other	Other Abatement Action Taken
October 16, 2004 - October 21, 2004	44	mg/L	daily	4 exceedances	63.8	237	other	Other Abatement Action Taken

Total Clean Water Regulations = 6 exceedances

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility and ministry action are current to October 2005. Conviction information is current to January 2006. For up-to-date information, please contact the appropriate district or area office."

2004 Industrial Sewage Monthly Summary - Central Region

Ontario Power Generation Inc. - Pickering

1675 Montgomery Park Road
Pickering

Sector: Electric Power Generation
Ministry Office: York-Durham

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

ACUTE LETHALITY - DAPHNIA

Clean Water Regulations

May 2004	Pass	acute toxicity	any	1 exceedance	Fail		Other	Assessment Complete - No Further Action Required
June 2004	Pass	acute toxicity	any	1 exceedance	Fail		Other	Assessment Complete - No Further Action Required

Total Clean Water Regulations = 2 exceedances

MORPHOLINE

C of A Non-Compliance

May 2004	50	ppm	any	1 exceedance	121		Ceased Operations, Equipment Modified, Repaired, Replaced or Re-calibrated	Assessment Complete - No Further Action Required
----------	----	-----	-----	--------------	-----	--	--	--

Total C of A Non-Compliance = 1 exceedance

TOTAL RESIDUAL CHLORINE

C of A Non-Compliance

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility and ministry action are current to October 2005. Conviction information is current to January 2006. For up-to-date information, please contact the appropriate district or area office."

2004 Industrial Sewage Monthly Summary - Central Region

Ontario Power Generation Inc. - Pickering

1675 Montgomery Park Road
Pickering

Sector: Electric Power Generation
Ministry Office: York-Durham

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
June 2004	0.01	mg/L	none	1 exceedance	0.04		Ceased Operations, Equipment Modified, Repaired, Replaced or Re-calibrated	Assessment Complete - No Further Action Required
August 2004	0.01	mg/L	none	1 exceedance	0.03		Equipment Modified, Repaired, Replaced or Re-calibrated	Assessment Complete - No Further Action Required

Total C of A Non-Compliance = 2 exceedances

TOTAL RESIDUAL CHLORINE (Pickering A)

C of A Non-Compliance

June 2004	0.01	mg/L	none	1 exceedance	0.19		Conducting Study, Equipment Modified, Repaired, Replaced or Re-calibrated	Assessment Complete - No Further Action Required
-----------	------	------	------	--------------	------	--	---	--

Total C of A Non-Compliance = 1 exceedance

TOTAL RESIDUAL CHLORINE (Pickering B)

C of A Non-Compliance

June 2004	0.01	mg/L	none	1 exceedance	0.2		Conducting Study, Equipment Modified, Repaired, Replaced or Re-calibrated	Assessment Complete - No Further Action Required
-----------	------	------	------	--------------	-----	--	---	--

Total C of A Non-Compliance = 1 exceedance

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility and ministry action are current to October 2005. Conviction information is current to January 2006. For up-to-date information, please contact the appropriate district or area office."

2004 Industrial Sewage Monthly Summary - Central Region

Petro-Canada - Atlantic Drive

6086 Atlantic Drive
Mississauga

Sector: Miscellaneous
Ministry Office: Halton-Peel

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

OIL AND GREASE

C of A Non-Compliance

February 2004	15	mg/L	any	1 exceedance	130		Other	Assessment Complete - No Further Action Required
---------------	----	------	-----	--------------	-----	--	-------	--

Total C of A Non-Compliance = 1 exceedance

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility and ministry action are current to October 2005. Conviction information is current to January 2006. For up-to-date information, please contact the appropriate district or area office."

2004 Industrial Sewage Monthly Summary - Central Region

Petro-Canada - Oakville Refinery

3275 Rebecca Street
Oakville

Sector: Petroleum Refineries
Ministry Office: Halton-Peel

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

ACUTE LETHALITY - DAPHNIA

Clean Water Regulations

January 2004	Pass	acute toxicity	any	1 exceedance	Fail		New Equipment or Treatment Process Installed	Assessment Complete - No Further Action Required
--------------	------	----------------	-----	--------------	------	--	--	--

Total Clean Water Regulations = 1 exceedance

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility and ministry action are current to October 2005. Conviction information is current to January 2006. For up-to-date information, please contact the appropriate district or area office."

2004 Industrial Sewage Monthly Summary - Central Region

Petro-Canada - Van Kirk Drive

25 Van Kirk Drive
Brampton

Sector: Miscellaneous
Ministry Office: Halton-Peel

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

OIL AND GREASE

C of A Non-Compliance

February 2004	15	mg/L	any	1 exceedance	60		Action Plan Submitted - Implementing Improvements	Assessment Complete - No Further Action Required
---------------	----	------	-----	--------------	----	--	--	---

Total C of A Non-Compliance = 1 exceedance

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility and ministry action are current to October 2005. Conviction information is current to January 2006. For up-to-date information, please contact the appropriate district or area office."

2004 Industrial Sewage Monthly Summary - Central Region

St. Lawrence Cement Inc. - Acton Quarry

12791 Churchill Road (Third Line)
Halton Hills

Sector: Miscellaneous
Ministry Office: Halton-Peel

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

FLOW

C of A Non-Compliance

June 12, 2004 - June 13, 2004	20	L/sec	any	2 exceedances	25.44	25.44	Equipment Modified, Repaired, Replaced or Re- calibrated	Assessment Complete - Incident Resolved
----------------------------------	----	-------	-----	---------------	-------	-------	--	--

Total C of A Non-Compliance = 2 exceedances

TOTAL SUSPENDED SOLIDS

C of A Non-Compliance

March 2004	15	mg/L	any	1 exceedance	70		Other	Assessment Complete - No Further Action Required
------------	----	------	-----	--------------	----	--	-------	---

Total C of A Non-Compliance = 1 exceedance

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility and ministry action are current to October 2005. Conviction information is current to January 2006. For up-to-date information, please contact the appropriate district or area office."

2004 Industrial Sewage Monthly Summary - Central Region

**St. Lawrence Cement Inc. -
Mississauga**

2391 Lakeshore Rd. West
MISSISSAUGA

Sector: Industrial Minerals
Ministry Office: Halton-Peel

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
TOTAL SUSPENDED SOLIDS								
Clean Water Regulations								
February 2004	50	mg/L	/wk	1 exceedance	76		New Equipment or Treatment Process Installed	Assessment Complete - No Further Action Required
December 2004	50	mg/L	/wk	1 exceedance	56.2		None Required	Assessment Complete - No Further Action Required

Total Clean Water Regulations = 2 exceedances

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility and ministry action are current to October 2005. Conviction information is current to January 2006. For up-to-date information, please contact the appropriate district or area office."

2004 Industrial Sewage Monthly Summary - Central Region

St. Marys Cement Inc. (Canada)

400 Waverley Road
Clarington

Sector: Industrial Minerals
Ministry Office: York-Durham

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

TOTAL SUSPENDED SOLIDS

Clean Water Regulations

December 1, 2004 - December 31, 2004	25	mg/L	mon avg	1 exceedance	31.75		Other	Assessment Complete - No Further Action Required
December 2004	50	mg/L	weekly	1 exceedance	53		Other	Assessment Complete - No Further Action Required

Total Clean Water Regulations = 2 exceedances

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility and ministry action are current to October 2005. Conviction information is current to January 2006. For up-to-date information, please contact the appropriate district or area office."