

2004 Municipal/Private Sewage Monthly Summary - Central Region

351658 Ontario Limited & 795208 Ontario Limited

8501 Mississauga Road
Brampton

Sector: Miscellaneous
Ministry Office: Halton-Peel

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
TOTAL SUSPENDED SOLIDS								
C of A Non-Compliance								
May 2004	10	mg/L	6 wk avg	1 exceedance	18.3		Equipment Modified, Repaired, Replaced or Re-calibrated	Assessment Complete - No Further Action Required
July 2004	10	mg/L	6 wk avg	1 exceedance	13.9		Equipment Modified, Repaired, Replaced or Re-calibrated	Assessment Complete - No Further Action Required

Total C of A Non-Compliance = 2 exceedances

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility and ministry action are current to October 2005. Conviction information is current to January 2006. For up-to-date information, please contact the appropriate district or area office."

2004 Municipal/Private Sewage Monthly Summary - Central Region

American Water Services Canada Corp.

5741 Black River Road
Georgina

Sector: Sewage - Municipal
Ministry Office: York-Durham

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

PHOSPHORUS

C of A Non-Compliance

May 2004	0.18	mg/L	monthly	1 exceedance	0.28		Other	Assessment Complete - No Further Action Required
----------	------	------	---------	--------------	------	--	-------	--

Total C of A Non-Compliance = 1 exceedance

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility and ministry action are current to October 2005. Conviction information is current to January 2006. For up-to-date information, please contact the appropriate district or area office."

2004 Municipal/Private Sewage Monthly Summary - Central Region

City of Toronto - Highland Creek

51 Beechgrove Drive
Toronto

Sector: Sewage - Municipal
Ministry Office: Toronto

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

PHOSPHORUS

C of A Non-Compliance

January 2004	1	mg/L	mon avg	1 exceedance	1.2		Other	Provincial Officer's Order issued
--------------	---	------	---------	--------------	-----	--	-------	-----------------------------------

Total C of A Non-Compliance = 1 exceedance

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility and ministry action are current to October 2005. Conviction information is current to January 2006. For up-to-date information, please contact the appropriate district or area office."

2004 Municipal/Private Sewage Monthly Summary - Central Region

Clublink Capital Corporation - Blue Springs Golf Club

13448 Dublin Line
Halton Hills

Sector: Miscellaneous
Ministry Office: Halton-Peel

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

TOTAL SUSPENDED SOLIDS

C of A Non-Compliance

September 1, 2004 - September 30, 2004	30	mg/L	mon avg	2 exceedances	30	32	Equipment Modified, Repaired, Replaced or Re- calibrated	Assessment underway
---	----	------	---------	---------------	----	----	--	---------------------

Total C of A Non-Compliance = 2 exceedances

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility and ministry action are current to October 2005. Conviction information is current to January 2006. For up-to-date information, please contact the appropriate district or area office."

2004 Municipal/Private Sewage Monthly Summary - Central Region

Rattlesnake Point Golf Club Limited

5407 Regional Road 25
Milton

Sector: Miscellaneous
Ministry Office: Halton-Peel

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
TOTAL SUSPENDED SOLIDS								
C of A Non-Compliance								
October 1, 2003 - October 31, 2003	30	mg/L	mon avg	1 exceedance	31		Operational Process Modification	Voluntary Abatement Program Underway

Total C of A Non-Compliance = 1 exceedance

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility and ministry action are current to October 2005. Conviction information is current to January 2006. For up-to-date information, please contact the appropriate district or area office."

2004 Municipal/Private Sewage Monthly Summary - Central Region

**The Regional Municipality of
Durham - Harmony Creek WPCP**

785 Colonel Sam Drive
Oshawa

Sector: Sewage - Municipal
Ministry Office: York-Durham

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

PHOSPHORUS

C of A Non-Compliance

May 1, 2004 - May 31, 2004	1	mg/L	monthly average	1 exceedance	1.19		Equipment Modified, Repaired, Replaced or Re- calibrated	Assessment Complete - No Further Action Required
-------------------------------	---	------	--------------------	--------------	------	--	--	---

Total C of A Non-Compliance = 1 exceedance

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility and ministry action are current to October 2005. Conviction information is current to January 2006. For up-to-date information, please contact the appropriate district or area office."

2004 Municipal/Private Sewage Monthly Summary - Central Region

**The Regional Municipality of
Durham - Newcastle WPCP**

1000 Toronto Street
Clarington

Sector: Sewage - Municipal
Ministry Office: York-Durham

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

TOTAL CHLORINE RESIDUAL

C of A Non-Compliance

May 1, 2004 - May 31, 2004	0.04	mg/L	monthly	1 exceedance	0.08		Equipment Modified, Repaired, Replaced or Re- calibrated	Assessment Complete - No Further Action Required
-------------------------------	------	------	---------	--------------	------	--	--	---

Total C of A Non-Compliance = 1 exceedance

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility and ministry action are current to October 2005. Conviction information is current to January 2006. For up-to-date information, please contact the appropriate district or area office."

2004 Municipal/Private Sewage Monthly Summary - Central Region

The Regional Municipality of Durham - Nonquon River WPCP

1730 Scugog Line 8
Scugog

Sector: Sewage - Municipal
Ministry Office: York-Durham

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
AMMONIA								
C of A Non-Compliance								
February 1, 2004 - February 29, 2004	11.7	kg/d	monthly average	1 exceedance	21.43		Action Plan Submitted - Implementing Improvements	Voluntary Abatement Program Underway
February 1, 2004 - February 29, 2004	3	mg/L	monthly average	1 exceedance	4.9		Action Plan Submitted - Implementing Improvements	Voluntary Abatement Program Underway
March 1, 2004 - March 31, 2004	10	mg/L	monthly average	1 exceedance	10.6		Action Plan Submitted - Implementing Improvements	Voluntary Abatement Program Underway
April 1, 2004 - April 30, 2004	19.4	kg/d	monthly average	1 exceedance	52.1		Action Plan Submitted - Implementing Improvements	Voluntary Abatement Program Underway
April 1, 2004 - April 30, 2004	5	mg/L	monthly average	1 exceedance	7.27		Action Plan Submitted - Implementing Improvements	Voluntary Abatement Program Underway
May 1, 2004 - May 31, 2004	11.7	kg/d	monthly average	1 exceedance	18.6		Action Plan Submitted - Implementing Improvements	Voluntary Abatement Program Underway
May 1, 2004 - May 31, 2004	3	mg/L	monthly average	1 exceedance	4.43		Action Plan Submitted - Implementing Improvements	Voluntary Abatement Program Underway

Total C of A Non-Compliance = 7 exceedances

PHOSPHORUS

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility and ministry action are current to October 2005. Conviction information is current to January 2006. For up-to-date information, please contact the appropriate district or area office."

2004 Municipal/Private Sewage Monthly Summary - Central Region

**The Regional Municipality of
Durham - Nonquon River WPCP**

1730 Scugog Line 8
Scugog

Sector: Sewage - Municipal
Ministry Office: York-Durham

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
C of A Non-Compliance								
March 1, 2004 - March 31, 2004	0.3	mg/L	monthly average	1 exceedance	0.34		Action Plan Submitted - Implementing Improvements	Voluntary Abatement Program Underway

Total C of A Non-Compliance = 1 exceedance

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility and ministry action are current to October 2005. Conviction information is current to January 2006. For up-to-date information, please contact the appropriate district or area office."

2004 Municipal/Private Sewage Monthly Summary - Central Region

The Regional Municipality of Halton - Skyway WWTP

1125 Lakeshore Road
Burlington

Sector: Sewage - Municipal
Ministry Office: Halton-Peel

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

ESCHERICHIA COLI

C of A Non-Compliance

September 1, 2003 - September 30, 2003	200	cfu/100 ml	mon avg	1 exceedance	271		Operational Process Modification	Assessment Complete - Incident Resolved
---	-----	---------------	---------	--------------	-----	--	-------------------------------------	--

Total C of A Non-Compliance = 1 exceedance

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility and ministry action are current to October 2005. Conviction information is current to January 2006. For up-to-date information, please contact the appropriate district or area office."

2004 Municipal/Private Sewage Monthly Summary - Central Region

**The Regional Municipality of
York - Mount Albert WPCP**

5866 Doane Road
East Gwillimbury

Sector: Sewage - Municipal
Ministry Office: York-Durham

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

PHOSPHORUS

C of A Non-Compliance

January 2004	0.1	mg/L	week	1 exceedance	0.135		New Equipment or Treatment Proces Installed	Assessment Complete - No Further Action Required
February 2004	0.1	mg/L	week	1 exceedance	0.135		New Equipment or Treatment Proces Installed	Assessment Complete - No Further Action Required
March 2004	0.1	mg/L	week	1 exceedance	0.14		New Equipment or Treatment Proces Installed	Assessment Complete - No Further Action Required

Total C of A Non-Compliance = 3 exceedances

TOTAL SUSPENDED SOLIDS

C of A Non-Compliance

January 1, 2004 - January 31, 2004	6	mg/L	month	1 exceedance	7.9		New Equipment or Treatment Proces Installed	Assessment Complete - No Further Action Required
February 1, 2004 - February 28, 2004	6	mg/L	month	1 exceedance	6.175		New Equipment or Treatment Proces Installed	Assessment Complete - No Further Action Required
March 1, 2004 - March 31, 2004	6	mg/L	month	1 exceedance	9.6		New Equipment or Treatment Proces Installed	Assessment Complete - No Further Action Required

Total C of A Non-Compliance = 3 exceedances

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility and ministry action are current to October 2005. Conviction information is current to January 2006. For up-to-date information, please contact the appropriate district or area office."

2004 Municipal/Private Sewage Monthly Summary - Central Region

The Regional Municipality of York - Schomberg WPCP

Lot: 34, 35, Conc: 7,8,9, Plan
King

Sector: Sewage - Municipal
Ministry Office: York-Durham

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

AMMONIA

C of A Non-Compliance

April 1, 2004 - April 30, 2004	8	mg/L	/2wk	1 exceedance	13.1		Action Plan Submitted - Implementing Improvements	Assessment Complete - No Further Action Required
-----------------------------------	---	------	------	--------------	------	--	--	---

Total C of A Non-Compliance = 1 exceedance

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility and ministry action are current to October 2005. Conviction information is current to January 2006. For up-to-date information, please contact the appropriate district or area office."

2004 Municipal/Private Sewage Monthly Summary - Central Region

**The Regional Municipality of
York - Sutton WPCP**

5741 Black River Road
Georgina

Sector: Sewage - Municipal
Ministry Office: York-Durham

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

PHOSPHORUS

C of A Non-Compliance

July 1, 2004 - July 31, 2004	0.18	mg/L	mon avg	1 exceedance	0.28		Equipment Modified, Repaired, Replaced or Re- calibrated	Assessment Complete - No Further Action Required
---------------------------------	------	------	---------	--------------	------	--	--	---

Total C of A Non-Compliance = 1 exceedance

TOTAL SUSPENDED SOLIDS

C of A Non-Compliance

July 1, 2004 - July 31, 2004	15	mg/L	mon avg	1 exceedance	22.04		Equipment Modified, Repaired, Replaced or Re- calibrated	Assessment Complete - No Further Action Required
---------------------------------	----	------	---------	--------------	-------	--	--	---

Total C of A Non-Compliance = 1 exceedance

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility and ministry action are current to October 2005. Conviction information is current to January 2006. For up-to-date information, please contact the appropriate district or area office."