

2004 Municipal/Private Sewage Monthly Summary - Northern Region

City of Greater Sudbury

1173 Kelly Lake Road
Greater Sudbury

Sector: Sewage - Municipal
Ministry Office: Sudbury

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

BIOCHEMICAL OXYGEN DEMAND

C of A Non-Compliance

December 2004	20	mg/L	/yr	1 exceedance	23.9		Other	Voluntary Abatement Program Underway
---------------	----	------	-----	--------------	------	--	-------	--------------------------------------

Total C of A Non-Compliance = 1 exceedance

ESCHERICHIA COLI

C of A Non-Compliance

July 2004	500	CT/100 mL	/mon	1 exceedance	2849		Equipment Modified, Repaired, Replaced or Re-calibrated	Assessment Complete - No Further Action Required
-----------	-----	-----------	------	--------------	------	--	---	--

Total C of A Non-Compliance = 1 exceedance

TOTAL SUSPENDED SOLIDS

C of A Non-Compliance

December 2004	20	mg/L	/yr	1 exceedance	25.9		Other	Voluntary Abatement Program Underway
---------------	----	------	-----	--------------	------	--	-------	--------------------------------------

Total C of A Non-Compliance = 1 exceedance

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility and ministry action are current to October 2005. Conviction information is current to January 2006. For up-to-date information, please contact the appropriate district or area office."

2004 Municipal/Private Sewage Monthly Summary - Northern Region

**The Corporation of the City of
North Bay**

650 Memorial Drive
North Bay

Sector: Sewage - Municipal
Ministry Office: North Bay

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

PHOSPHORUS

C of A Non-Compliance

September 1, 2004 - September 30, 2004	1	mg/L	/mon	1 exceedance	1.08		Additional monitoring underway	Assessment Complete - Incident Resolved
---	---	------	------	--------------	------	--	-----------------------------------	--

Total C of A Non-Compliance = 1 exceedance

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility and ministry action are current to October 2005. Conviction information is current to January 2006. For up-to-date information, please contact the appropriate district or area office."

2004 Municipal/Private Sewage Monthly Summary - Northern Region

**The Corporation of the
Municipality of West Nipissing**

1 Third Street, Sturgeon Falls
West Nipissing

Sector: Sewage - Municipal
Ministry Office: North Bay

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
ESCHERICHIA COLI								
C of A Non-Compliance								
March 1, 2004 - March 31, 2004	200	CT/100 mL	mon avg	1 exceedance	864.5		Action plan submitted, Equipment Modified, Repaired, Replaced or Re- calibrated	Voluntary Abatement Program Underway
April 1, 2004 - April 30, 2004	200	CT/100 mL	mon avg	1 exceedance	437		Action plan submitted, Equipment Modified, Repaired, Replaced or Re- calibrated	Voluntary Abatement Program Underway
May 1, 2004 - May 31, 2004	200	CT/100 mL	mon avg	1 exceedance	1843.5		Action plan submitted, Equipment Modified, Repaired, Replaced or Re- calibrated	Voluntary Abatement Program Underway
December 1, 2004 - December 31, 2004	200	CT/100 mL	mon avg	1 exceedance	430		Action plan submitted, Equipment Modified, Repaired, Replaced or Re- calibrated	Voluntary Abatement Program Underway

Total C of A Non-Compliance = 4 exceedances

TOTAL SUSPENDED SOLIDS

C of A Non-Compliance

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility and ministry action are current to October 2005. Conviction information is current to January 2006. For up-to-date information, please contact the appropriate district or area office."

2004 Municipal/Private Sewage Monthly Summary - Northern Region

The Corporation of the Municipality of West Nipissing

1 Third Street, Sturgeon Falls
West Nipissing

Sector: Sewage - Municipal
Ministry Office: North Bay

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
January 1, 2004 - December 31, 2004	25	mg/L	annual avg	1 exceedance	26.25		Other	Voluntary Abatement Program Underway

Total C of A Non-Compliance = 1 exceedance

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility and ministry action are current to October 2005. Conviction information is current to January 2006. For up-to-date information, please contact the appropriate district or area office."

2004 Municipal/Private Sewage Monthly Summary - Northern Region

The Corporation of the Town of Espanola

200 Bois Street
Espanola

Sector: Sewage - Municipal
Ministry Office: Sudbury

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
FLOW								
C of A Non-Compliance								
January 2004	3490	m3	/d	10 exceedances	3492	3805	Operational Process Modification	Additional requirements added in certificate of approval/permit
February 2004	3490	m3	/d	3 exceedances	3943	9954	Operational Process Modification	Additional requirements added in certificate of approval/permit
March 2004	3490	m3	/d	3 exceedances	3913	4587	Operational Process Modification	Additional requirements added in certificate of approval/permit
December 2004	3490	m3	/d	3 exceedances	3645	4892	Operational Process Modification	Additional requirements added in certificate of approval/permit

Total C of A Non-Compliance = 19 exceedances

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility and ministry action are current to October 2005. Conviction information is current to January 2006. For up-to-date information, please contact the appropriate district or area office."

2004 Municipal/Private Sewage Monthly Summary - Northern Region

The Corporation of the Town of Kapuskasing

Montgomery Street North
Kapuskasing

Sector: Sewage - Municipal
Ministry Office: Timmins

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
ESCHERICHIA COLI								
C of A Non-Compliance								
May 1, 2004 - May 31, 2004	200	CT/100	/mon mL	1 exceedance	2099.78		None Required	Voluntary Abatement Program Underway
June 1, 2004 - June 30, 2004	200	CT/100	/mon mL	1 exceedance	226.79		None Required	Voluntary Abatement Program Underway
July 1, 2004 - July 31, 2004	200	CT/100	/mon mL	1 exceedance	1331		None Required	Voluntary Abatement Program Underway
August 1, 2004 - August 31, 2004	200	CT/100	/mon mL	1 exceedance	8642.97		None Required	Voluntary Abatement Program Underway
September 1, 2004 - September 30, 2004	200	CT/100	/mon mL	1 exceedance	629.97		None Required	Voluntary Abatement Program Underway

Total C of A Non-Compliance = 5 exceedances

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility and ministry action are current to October 2005. Conviction information is current to January 2006. For up-to-date information, please contact the appropriate district or area office."

2004 Municipal/Private Sewage Monthly Summary - Northern Region

The Corporation of the Township of Atikokan

101 Little Falls Road
Atikokan

Sector: Sewage - Municipal
Ministry Office: Thunder Bay

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
TOTAL SUSPENDED SOLIDS								
C of A Non-Compliance								
December 2004	25	mg/L	annual	1 exceedance	40		Other	Other Abatement Action taken

Total C of A Non-Compliance = 1 exceedance

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility and ministry action are current to October 2005. Conviction information is current to January 2006. For up-to-date information, please contact the appropriate district or area office."

2004 Municipal/Private Sewage Monthly Summary - Northern Region

The Corporation of the Township of Manitouwadge

Lot M179, Conc BLKA
Manitouwadge

Sector: Sewage - Municipal
Ministry Office: Thunder Bay

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

BIOCHEMICAL OXYGEN DEMAND

C of A Non-Compliance

July 2004	25	mg/L	/d	1 exceedance	97		New Equipment or Treatment Process Installed	Other Abatement Action taken
-----------	----	------	----	--------------	----	--	---	------------------------------

Total C of A Non-Compliance = 1 exceedance

TOTAL SUSPENDED SOLIDS

C of A Non-Compliance

April 2004	30	mg/L	/d	1 exceedance	72		New Equipment or Treatment Process Installed	Other Abatement Action taken
June 2004	30	mg/L	/d	1 exceedance	36		New Equipment or Treatment Process Installed	Other Abatement Action taken

Total C of A Non-Compliance = 2 exceedances

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility and ministry action are current to October 2005. Conviction information is current to January 2006. For up-to-date information, please contact the appropriate district or area office."

2004 Municipal/Private Sewage Monthly Summary - Northern Region

The Corporation of the Township of McGarry

McGarry Mining Claim Mc L5414 PCL 348CST
McGarry

Sector: Sewage - Municipal
Ministry Office: Timmins

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

TOTAL SUSPENDED SOLIDS

Policy/Guideline

December 2004	50	%	annual avg	1 exceedance	23.6		None Required	Other Abatement Action taken
---------------	----	---	------------	--------------	------	--	---------------	------------------------------

Total Policy/Guideline = 1 exceedance

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility and ministry action are current to October 2005. Conviction information is current to January 2006. For up-to-date information, please contact the appropriate district or area office."

2004 Municipal/Private Sewage Monthly Summary - Northern Region

The Corporation of the Village of Thornloe

Lot: 1, Conc: 6, Harley Township
Harley

Sector: Sewage - Municipal
Ministry Office: Timmins

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

PHOSPHORUS

C of A Non-Compliance

March 2004	1	mg/L	annual avg	1 exceedance	1.146		None Required	Provincial Officer's Order issued
------------	---	------	------------	--------------	-------	--	---------------	-----------------------------------

Total C of A Non-Compliance = 1 exceedance

TOTAL SUSPENDED SOLIDS

C of A Non-Compliance

March 2004	25	mg/L	annual avg	1 exceedance	590		None Required	Provincial Officer's Order issued
March 2004	37.5	kg/d	annual avg	1 exceedance	415		None Required	Provincial Officer's Order issued

Total C of A Non-Compliance = 2 exceedances

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility and ministry action are current to October 2005. Conviction information is current to January 2006. For up-to-date information, please contact the appropriate district or area office."