

2005 Air Emissions Monthly Summary - Central Region

Algonquin Power Energy From Waste Inc.

7656 Bramalea Road
Brampton

Sector: Miscellaneous
Ministry Office: Halton-Peel

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

NITROGEN OXIDES

C of A Non-Compliance

September 2005	110	ppm dry volume	24hr avg	1 exceedance	120	120	Equipment Modified, Repaired, Replaced or Re-calibrated	Assessment Complete - Incident Resolved
----------------	-----	----------------	----------	--------------	-----	-----	---	---

Total C of A Non-Compliance = 1 exceedance

OPACITY

C of A Non-Compliance

November 2005	10	% opacity	6min avg	2 days of exceedances	11.3	13.3	Equipment Modified, Repaired, Replaced or Re-calibrated	Assessment Complete - Incident Resolved
---------------	----	-----------	----------	-----------------------	------	------	---	---

Total C of A Non-Compliance = 2 days of exceedances

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to October 2006. For up-to-date information, please contact the appropriate district or area office."

2005 Air Emissions Monthly Summary - Central Region

H.L. Blachford, Limited

2323 Royal Windsor Drive
Mississauga

Sector: Miscellaneous
Ministry Office: Halton-Peel

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

NOISE

C of A Non-Compliance

August 2005	45	dBA	any	1 exceedance	57		Conducting Study	Assessment underway
-------------	----	-----	-----	--------------	----	--	------------------	---------------------

Total C of A Non-Compliance = 1 exceedance

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to October 2006. For up-to-date information, please contact the appropriate district or area office."

2005 Air Emissions Monthly Summary - Central Region

Halton Recycling Ltd.

395 Harry Walker Parkway S.
Newmarket

Sector: Miscellaneous
Ministry Office: York-Durham

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

ODOUR

C of A Non-Compliance

August 3, 2005 - August 10, 2005	1	odour unit	10min avg	1 exceedance	1218		Action Plan Submitted - Implementing Improvements, New Equipment or Treatment Process Installed, Operational Process Modification, Other	Assessment Underway, Director's Order Issued, Other Abatement Action Taken, Provincial Officer's Order Issued, Voluntary Abatement Program Underway
-------------------------------------	---	---------------	-----------	--------------	------	--	--	--

Total C of A Non-Compliance = 1 exceedance
Based on air dispersion models

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to October 2006. For up-to-date information, please contact the appropriate district or area office."

2005 Air Emissions Monthly Summary - Central Region

Medical Waste Management Inc.

3, 4 - 95 Deerhurst Drive
Brampton

Sector: Miscellaneous
Ministry Office: Halton-Peel

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

CARBON MONOXIDE

C of A Non-Compliance

September 6, 2005 - September 8, 2005	35	mg/m3	any	1 exceedance	72		Other	Assessment underway
--	----	-------	-----	--------------	----	--	-------	---------------------

Total C of A Non-Compliance = 1 exceedance

MERCURY

C of A Non-Compliance

September 6, 2005 - September 8, 2005	20	µg/m3	any	1 exceedance	62		Other	Assessment underway
--	----	-------	-----	--------------	----	--	-------	---------------------

Total C of A Non-Compliance = 1 exceedance

NITROGEN OXIDES

C of A Non-Compliance

September 6, 2005 - September 8, 2005	324	mg/m3	any	1 exceedance	453		Other	Assessment underway
--	-----	-------	-----	--------------	-----	--	-------	---------------------

Total C of A Non-Compliance = 1 exceedance

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to October 2006. For up-to-date information, please contact the appropriate district or area office."

2005 Air Emissions Monthly Summary - Central Region

**Meritor Suspension Systems
Company Ltd.**

150 Steeles Avenue
Milton

Sector: Miscellaneous
Ministry Office: Halton-Peel

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

NOISE

C of A Non-Compliance

April 2005	45	dBA	any	1 exceedance	52		Other	Assessment underway
------------	----	-----	-----	--------------	----	--	-------	---------------------

Total C of A Non-Compliance = 1 exceedance

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to October 2006. For up-to-date information, please contact the appropriate district or area office."

2005 Air Emissions Monthly Summary - Central Region

Nestlé Canada Inc.

55 & 65 Carrier Dr
Toronto

Sector: Miscellaneous
Ministry Office: Toronto

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

ODOUR

C of A Non-Compliance

January 2005	1	odour unit	10min avg	1 exceedance	1		Action Plan Submitted - Implementing Improvements, New/Modified Sampling Program Underway, Operational Process Modification	Voluntary Abatement Program Underway
--------------	---	------------	-----------	--------------	---	--	---	--------------------------------------

Total C of A Non-Compliance = 1 exceedance

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to October 2006. For up-to-date information, please contact the appropriate district or area office."

2005 Air Emissions Monthly Summary - Central Region

Premier Candle Corp.

960 Britannia Road East
Mississauga

Sector: Miscellaneous
Ministry Office: Halton-Peel

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

ODOUR

C of A Non-Compliance

June 2005	1	odour unit	10min avg	1 exceedance	1.5		Action Plan Submitted - Implementing Improvements	Assessment underway
-----------	---	------------	-----------	--------------	-----	--	--	---------------------

Total C of A Non-Compliance = 1 exceedance

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to October 2006. For up-to-date information, please contact the appropriate district or area office."