

2005 Municipal/Private Sewage Monthly Summary - Northern Region

City of Greater Sudbury - Dowling STP

Riverside Drive
Greater Sudbury

Sector: Sewage Municipal
Ministry Office: Sudbury

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

ESCHERICHIA COLI

C of A Non-Compliance

April 2005	200	CT/100 mL	mon avg	1 exceedance	269		Equipment Modified, Repaired, Replaced or Re-calibrated	Assessment Complete - Incident Resolved
------------	-----	-----------	---------	--------------	-----	--	---	---

Total C of A Non-Compliance = 1 exceedance

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to October 2006. For up-to-date information, please contact the appropriate district or area office."

2005 Municipal/Private Sewage Monthly Summary - Northern Region

City of Greater Sudbury - Garson Lagoon

Garson
Greater Sudbury

Sector: Sewage Municipal
Ministry Office: Sudbury

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

SUSPENDED SOLIDS

Policy/Guideline

December 2005	40	ppm	/yr	1 exceedance	44.4		Ceased Operations	Assessment Underway
---------------	----	-----	-----	--------------	------	--	-------------------	---------------------

Total Policy/Guideline = 1 exceedance

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to October 2006. For up-to-date information, please contact the appropriate district or area office."

2005 Municipal/Private Sewage Monthly Summary - Northern Region

**City of Greater Sudbury - Levack
STP**

High St.
Greater Sudbury

Sector: Sewage Municipal
Ministry Office: Sudbury

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

ESCHERICHIA COLI

C of A Non-Compliance

June 2005	200	CT/100 mL	mon avg	1 exceedance	100000		New/Modified Sampling Program Underway, Other	Assessment Complete - Incident Resolved
-----------	-----	--------------	---------	--------------	--------	--	--	--

Total C of A Non-Compliance = 1 exceedance

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to October 2006. For up-to-date information, please contact the appropriate district or area office."

2005 Municipal/Private Sewage Monthly Summary - Northern Region

City of Greater Sudbury - Lively STP

Lot 7, Con 5, Waters Twp.
Greater Sudbury

Sector: Sewage Municipal
Ministry Office: Sudbury

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

ESCHERICHIA COLI

C of A Non-Compliance

May 2005	200	CT/100 mL	mon avg	1 exceedance	346		Other	Assessment Underway
October 2005	200	CT/100 mL	mon avg	1 exceedance	100000		Other	Assessment Underway

Total C of A Non-Compliance = 2 exceedances

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to October 2006. For up-to-date information, please contact the appropriate district or area office."

2005 Municipal/Private Sewage Monthly Summary - Northern Region

**City of Greater Sudbury - Walden
STP**

Lot: 10, Conc: 3
Greater Sudbury

Sector: Sewage Municipal
Ministry Office: Sudbury

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

ESCHERICHIA COLI

C of A Non-Compliance

October 2005	200	CT/100 mL	mon avg	1 exceedance	100000		Other	Assessment Underway
--------------	-----	--------------	---------	--------------	--------	--	-------	---------------------

Total C of A Non-Compliance = 1 exceedance

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to October 2006. For up-to-date information, please contact the appropriate district or area office."

2005 Municipal/Private Sewage Monthly Summary - Northern Region

Ontario Realty Corp. - North Bay

4700 Highway 11 North
North Bay

Sector: Miscellaneous
Ministry Office: North Bay

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
HIGH PH EFFLUENT								
C of A Non-Compliance								
April 2005	9.5	pH	any	1 exceedance	9.9		Operational Process Modification, Other	Assessment Complete - Incident Resolved

Total C of A Non-Compliance = 1 exceedance

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to October 2006. For up-to-date information, please contact the appropriate district or area office."

2005 Municipal/Private Sewage Monthly Summary - Northern Region

Sudbury Condominium Corporation #5

Lot 13, Con 2, Curtin Unorg Twp.
Willisville/Whitefish Falls

Sector: Sewage Municipal
Ministry Office: Sudbury

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

PHOSPHORUS

Policy/Guideline

January 31, 2005 - December 31, 2005	1	ppm	mon avg	11 exceedances	1.41	4.65	Other	Assessment Underway
---	---	-----	---------	----------------	------	------	-------	---------------------

Total Policy/Guideline = 11 exceedances

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to October 2006. For up-to-date information, please contact the appropriate district or area office."

2005 Municipal/Private Sewage Monthly Summary - Northern Region

**The Corporation of the City of
Temiskaming Shores**

Lakeview Drive
Haileybury

Sector: Sewage Municipal
Ministry Office: North Bay

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
ESCHERICHIA COLI								
C of A Non-Compliance								
January 2005	200	CT/100 mL	any	1 exceedance	400		Operational Process Modification, Other	Other Abatement Action taken
August 2005	200	CT/100 mL	any	1 exceedance	403		Operational Process Modification, Other	Other Abatement Action taken
Total C of A Non-Compliance = 2 exceedances								

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to October 2006. For up-to-date information, please contact the appropriate district or area office."

2005 Municipal/Private Sewage Monthly Summary - Northern Region

**The Corporation of the
Municipality of Callander**

Lot 34 & 35 Conc 11
Callander

Sector: Sewage Municipal
Ministry Office: North Bay

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
SUSPENDED SOLIDS								
C of A Non-Compliance								
May 5, 2005 - May 16, 2005	30	mg/L	rolling avg	2 exceedances	31.3	43.3	Conducting Study	Assessment underway
May 9, 2005 - May 24, 2005	30	mg/L	rolling avg	1 exceedance	50		New/Modified Sampling Program Underway	Assessment underway
June 11, 2005 - June 15, 2005	30	mg/L	rolling avg	1 exceedance	35.3		Conducting Study	Assessment underway
June 7, 2005 - June 14, 2005	30	mg/L	rolling avg	1 exceedance	30.66		New/Modified Sampling Program Underway	Assessment underway

Total C of A Non-Compliance = 5 exceedances

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to October 2006. For up-to-date information, please contact the appropriate district or area office."

2005 Municipal/Private Sewage Monthly Summary - Northern Region

**The Corporation of the
Municipality of Greenstone -
Longlac WPCP**

Centennial Avenue
Greenstone

Sector: Sewage Municipal
Ministry Office: Thunder Bay

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

SUSPENDED SOLIDS

C of A Non-Compliance

November 2005	25	mg/L	/d	1 exceedance	42		Equipment Modified, Repaired, Replaced or Re- calibrated	Assessment Complete - No Action Required
---------------	----	------	----	--------------	----	--	--	---

Total C of A Non-Compliance = 1 exceedance

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to October 2006. For up-to-date information, please contact the appropriate district or area office."

2005 Municipal/Private Sewage Monthly Summary - Northern Region

**The Corporation of the
Municipality of West Nipissing -
Sturgeon Falls**

1 Third St.
West Nipissing

Sector: Sewage Municipal
Ministry Office: North Bay

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

ESCHERICHIA COLI

C of A Non-Compliance

February 1, 2005 - February 28, 2005	200	CT/100 mL	mon avg	1 exceedance	335		Equipment Modified, Repaired, Replaced or Re- calibrated	Other Abatement Action taken
---	-----	--------------	---------	--------------	-----	--	--	------------------------------

Total C of A Non-Compliance = 1 exceedance

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to October 2006. For up-to-date information, please contact the appropriate district or area office."

2005 Municipal/Private Sewage Monthly Summary - Northern Region

**The Corporation of the
Municipality of West Nipissing -
Verner**

Lot: 8, Conc: 3
West Nipissing

Sector: Sewage Municipal
Ministry Office: North Bay

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

SUSPENDED SOLIDS

Policy/Guideline

January 1, 2005 - December 31, 2005	25	mg/L	annual avg	1 exceedance	31		None Required	Voluntary Abatement Program Underway
--	----	------	------------	--------------	----	--	---------------	---

Total Policy/Guideline = 1 exceedance

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to October 2006. For up-to-date information, please contact the appropriate district or area office."

2005 Municipal/Private Sewage Monthly Summary - Northern Region

**The Corporation of the Town of
Blind River**

15 Martin St.
Blind River

Sector: Sewage Municipal
Ministry Office: Sault Ste. Marie

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

SUSPENDED SOLIDS

C of A Non-Compliance

June 30, 2005 - July 31, 2005	25	ppm	/mon	2 exceedances	25.75	26.4	Other	Other Abatement Action Taken
----------------------------------	----	-----	------	---------------	-------	------	-------	------------------------------

Total C of A Non-Compliance = 2 exceedances

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to October 2006. For up-to-date information, please contact the appropriate district or area office."

2005 Municipal/Private Sewage Monthly Summary - Northern Region

The Corporation of the Town of Cobalt

100 Hudson Bay Road
Cobalt

Sector: Sewage Municipal
Ministry Office: North Bay

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
LOW PH EFFLUENT								
C of A Non-Compliance								
March 2005	6	pH	any	2 exceedances	4.4	5.5	Equipment Modified, Repaired, Replaced or Re-calibrated, New Equipment or Treatment Process Installed	Assessment underway
April 2005	6	pH	any	1 exceedance	2.8		Equipment Modified, Repaired, Replaced or Re-calibrated, New Equipment or Treatment Process Installed	Assessment underway
May 2005	6	pH	any	2 exceedances	4.4	4.9	Equipment Modified, Repaired, Replaced or Re-calibrated, New Equipment or Treatment Process Installed	Assessment underway

Total C of A Non-Compliance = 5 exceedances

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to October 2006. For up-to-date information, please contact the appropriate district or area office."

2005 Municipal/Private Sewage Monthly Summary - Northern Region

The Corporation of the Town of Kapuskasing

Montgomery St. North
Kapuskasing

Sector: Sewage Municipal
Ministry Office: Timmins

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

ESCHERICHIA COLI

C of A Non-Compliance

May 1, 2005 - May 31, 2005	200	cfu/100 ml	mon avg	1 exceedance	2571.76		Conducting Study	Assessment Underway
June 1, 2005 - June 30, 2005	200	CT/100 mL	mon avg	1 exceedance	502.97		Conducting Study	Assessment Underway
July 1, 2005 - July 31, 2005	200	cfu/100 ml	mon avg	1 exceedance	328.18		Conducting Study	Assessment Underway
August 1, 2005 - August 31, 2005	200	CT/100 mL	mon avg	1 exceedance	734.379		Conducting Study	Assessment Underway
September 1, 2005 - September 30, 2005	200	CT/100 mL	mon avg	1 exceedance	1538		Conducting Study	Assessment Underway

Total C of A Non-Compliance = 5 exceedances

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to October 2006. For up-to-date information, please contact the appropriate district or area office."

2005 Municipal/Private Sewage Monthly Summary - Northern Region

The Corporation of the Town of Latchford

Lot: 17, Conc: 1
Latchford

Sector: Sewage Municipal
Ministry Office: North Bay

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

SUSPENDED SOLIDS

Order Non-Compliance

February 1, 2005 - December 31, 2005	25	mg/L	mon avg	6 exceedances	25.5	94.8	New/Modified Sampling Program Underway	Provincial Officer's Order Issued
---	----	------	---------	---------------	------	------	---	--------------------------------------

Total Order Non-Compliance = 6 exceedances

Policy/Guideline

January 1, 2005 - December 31, 2005	25	mg/L	annual avg	1 exceedance	26.05		New/Modified Sampling Program Underway	Provincial Officer's Order Issued
--	----	------	------------	--------------	-------	--	---	--------------------------------------

Total Policy/Guideline = 1 exceedance

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to October 2006. For up-to-date information, please contact the appropriate district or area office."

2005 Municipal/Private Sewage Monthly Summary - Northern Region

**The Corporation of the Town of
Mattawa**

Lot 38 & 39 Conc. 1
Mattawa

Sector: Sewage Municipal
Ministry Office: North Bay

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

PHOSPHORUS

C of A Non-Compliance

May 1, 2005 - May 31, 2005	2.5	mg/L	mon avg	1 exceedance	14.6		Training / Procedure Change	Assessment Complete - Incident Resolved, Assessment Complete - No Action Required
-------------------------------	-----	------	---------	--------------	------	--	-----------------------------	--

Total C of A Non-Compliance = 1 exceedance

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to October 2006. For up-to-date information, please contact the appropriate district or area office."

2005 Municipal/Private Sewage Monthly Summary - Northern Region

The Corporation of the Township of Ear Falls

KM275, Part 1 Aspen St.
Ear Falls

Sector: Sewage Municipal
Ministry Office: Kenora

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

ESCHERICHIA COLI

C of A Non-Compliance

January 1, 2005 - January 31, 2005	200	cfu/100 ml	/mon	1 exceedance	480		Operational Process Modification	Other Abatement Action taken
February 1, 2005 - February 28, 2005	200	cfu/100 ml	/mon	1 exceedance	220		Operational Process Modification	Other Abatement Action taken
April 1, 2005 - April 19, 2005	200	cfu/100 ml	/mon	1 exceedance	7500		Operational Process Modification	Other Abatement Action taken

Total C of A Non-Compliance = 3 exceedances

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to October 2006. For up-to-date information, please contact the appropriate district or area office."

2005 Municipal/Private Sewage Monthly Summary - Northern Region

The Corporation of the Township of Manitouwadge

Lot M179, Conc BLKA
Manitouwadge

Sector: Sewage Municipal
Ministry Office: Thunder Bay

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

SUSPENDED SOLIDS

C of A Non-Compliance

August 2005	30	mg/L	/d	1 exceedance	32		Operational Process Modification	Other Abatement Action Taken
-------------	----	------	----	--------------	----	--	----------------------------------	------------------------------

Total C of A Non-Compliance = 1 exceedance

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to October 2006. For up-to-date information, please contact the appropriate district or area office."

2005 Municipal/Private Sewage Monthly Summary - Northern Region

Township of Central Manitoulin - Mindemoya STP

Lot 22, Con 6, Carnarvan Twp.
Central Manitoulin

Sector: Sewage Municipal
Ministry Office: Sudbury

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

BIOCHEMICAL OXYGEN DEMAND

C of A Non-Compliance

October 2005	25	ppm	mon avg	1 exceedance	101.25		Other	Assessment Underway
November 2005	25	ppm	mon avg	1 exceedance	35.8		Other	Assessment Underway

Total C of A Non-Compliance = 2 exceedances

SUSPENDED SOLIDS

C of A Non-Compliance

November 2005	25	ppm	mon avg	1 exceedance	26		Other	Assessment Underway
---------------	----	-----	---------	--------------	----	--	-------	---------------------

Total C of A Non-Compliance = 1 exceedance

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to October 2006. For up-to-date information, please contact the appropriate district or area office."