

2005 Municipal/Private Sewage Monthly Summary - West Central Region

City of Hamilton - Woodward

700 Woodward Avenue
Hamilton

Sector: Sewage Municipal
Ministry Office: Hamilton

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

PHOSPHORUS

C of A Non-Compliance

November 1, 2005 - November 30, 2005	0.8	mg/L	/mon	1 exceedance	0.91		Conducting Study	Assessment underway
December 1, 2005 - December 31, 2005	0.8	mg/L	/mon	1 exceedance	1.51		Conducting Study	Voluntary Abatement Program Underway

Total C of A Non-Compliance = 2 exceedances

TOTAL SUSPENDED SOLIDS

C of A Non-Compliance

November 1, 2005 - November 30, 2005	25	mg/L	/mon	1 exceedance	30.1		Conducting Study	Assessment underway
December 1, 2005 - December 31, 2005	25	mg/L	/mon	1 exceedance	60.1		Conducting Study	Voluntary Abatement Program Underway

Total C of A Non-Compliance = 2 exceedances

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to October 2006. For up-to-date information, please contact the appropriate district or area office."

2005 Municipal/Private Sewage Monthly Summary - West Central Region

Jah-Jireh Seniors Ministry Association

4505 Thirty Road, RR#3
Lincoln

Sector: Miscellaneous
Ministry Office: Niagara

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

AMMONIUM

C of A Non-Compliance

October 18, 2005 - November 15, 2005	5	mg/L	/mon	2 exceedances	5.19	6.36	New Equipment or Treatment Process Installed	Other Abatement Action taken
---	---	------	------	---------------	------	------	---	------------------------------

Total C of A Non-Compliance = 2 exceedances

ESCHERICHIA COLI

C of A Non-Compliance

January 18, 2005 - December 21, 2005	100	CT/100 mL	/mon	6 exceedances	120	1200000	New Equipment or Treatment Process Installed	Other Abatement Action taken
---	-----	--------------	------	---------------	-----	---------	---	------------------------------

Total C of A Non-Compliance = 6 exceedances

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to October 2006. For up-to-date information, please contact the appropriate district or area office."

2005 Municipal/Private Sewage Monthly Summary - West Central Region

**The Corporation of Haldimand
County - Jarvis**

4, 5, Conc: 7, Walpole,
Haldimand

Sector: Sewage Municipal
Ministry Office: Hamilton

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

TOTAL SUSPENDED SOLIDS

C of A Non-Compliance

November 7, 2005 - November 10, 2005	25	mg/L	/d	1 exceedance	37.7		Other	Other Abatement Action taken
---	----	------	----	--------------	------	--	-------	------------------------------

Total C of A Non-Compliance = 1 exceedance

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to October 2006. For up-to-date information, please contact the appropriate district or area office."

2005 Municipal/Private Sewage Monthly Summary - West Central Region

**The Corporation of Haldimand
County - Caledonia**

320 Lanark St.
Haldimand

Sector: Sewage Municipal
Ministry Office: Hamilton

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
AMMONIA								
C of A Non-Compliance								
January 1, 2005 - January 31, 2005	2	mg/L	/mon	2 exceedances	2.11	2.14	Action Plan Submitted - Implementing Improvements, Operational Process Modification	Assessment Complete - Incident Resolved, Assessment Complete - No Action Required
June 1, 2005 - June 30, 2005	1	mg/L	/mon	2 exceedances	3.48	4.87	Operational Process Modification	Assessment Complete - No Action Required

Total C of A Non-Compliance = 4 exceedances

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to October 2006. For up-to-date information, please contact the appropriate district or area office."

2005 Municipal/Private Sewage Monthly Summary - West Central Region

**The Corporation of Haldimand
County - Cayuga**

Lot: 31, Conc: 1 STR, N. Cayuga
Haldimand

Sector: Sewage Municipal
Ministry Office: Hamilton

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

ESCHERICHIA COLI

C of A Non-Compliance

March 1, 2005 - March 31, 2005	200	CT/100 mL	/mon	2 exceedances	259	359	None	Assessment underway
-----------------------------------	-----	--------------	------	---------------	-----	-----	------	---------------------

Total C of A Non-Compliance = 2 exceedances

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to October 2006. For up-to-date information, please contact the appropriate district or area office."

2005 Municipal/Private Sewage Monthly Summary - West Central Region

**The Corporation of Norfolk
County - Simcoe**

16 Oakwood Avenue
Norfolk

Sector: Sewage Municipal
Ministry Office: Hamilton

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

ESCHERICHIA COLI

C of A Non-Compliance

February 1, 2005 - February 28, 2005	200	CT/100 mL	/mon	1 exceedance	235		Operational Process Modification	Assessment underway
---	-----	--------------	------	--------------	-----	--	-------------------------------------	---------------------

Total C of A Non-Compliance = 1 exceedance

PHOSPHORUS

C of A Non-Compliance

June 1, 2005 - June 30, 2005	1	mg/L	/mon	1 exceedance	1.11		Operational Process Modification	Assessment Complete - No Action Required
---------------------------------	---	------	------	--------------	------	--	-------------------------------------	---

Total C of A Non-Compliance = 1 exceedance

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to October 2006. For up-to-date information, please contact the appropriate district or area office."

2005 Municipal/Private Sewage Monthly Summary - West Central Region

The Creative Centre for Learning and Development

6727 South Chippawa Road
West Lincoln

Sector: Miscellaneous
Ministry Office: Niagara

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

FLOW

C of A Non-Compliance

January 1, 2005 - December 31, 2005	21.3	m3	/d	1 exceedance	28.04		Action Plan Submitted - Implementing Improvements	Assessment complete no action required.
September 2005	55	m3	/d	1 exceedance	66.6		Action Plan Submitted - Implementing Improvements	Assessment complete no action required.
October 2005	55	m3	/d	1 exceedance	55.9		Action Plan Submitted - Implementing Improvements	Assessment complete no action required.

Total C of A Non-Compliance = 3 exceedances

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to October 2006. For up-to-date information, please contact the appropriate district or area office."

2005 Municipal/Private Sewage Monthly Summary - West Central Region

**The Regional Municipality of
Niagara - Port Dalhousie**

40 Lighthouse Road
St. Catharines

Sector: Sewage Municipal
Ministry Office: Niagara

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

ESCHERICHIA COLI

C of A Non-Compliance

April 1, 2005 - April 30, 2005	200	CT/100 mL	/mon	1 exceedance	831		Conducting Study	Voluntary Abatement Program Underway
-----------------------------------	-----	--------------	------	--------------	-----	--	------------------	---

Total C of A Non-Compliance = 1 exceedance

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to October 2006. For up-to-date information, please contact the appropriate district or area office."

2005 Municipal/Private Sewage Monthly Summary - West Central Region

**The Regional Municipality of
Niagara - Port Robinson**

Chippawa Parkway, Lots 199, 200
Thorold

Sector: Sewage Municipal
Ministry Office: Niagara

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
TOTAL SUSPENDED SOLIDS								
C of A Non-Compliance								
September 1, 2005 - September 30, 2005	25	mg/L	/mon	1 exceedance	36.9		Ceased Operations	Voluntary Abatement Program Underway
November 2005	40	mg/L	any	3 exceedances	41.5	47.6	Ceased Operations	Voluntary Abatement Program Underway
Total C of A Non-Compliance = 4 exceedances								

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to October 2006. For up-to-date information, please contact the appropriate district or area office."

2005 Municipal/Private Sewage Monthly Summary - West Central Region

**The Regional Municipality of
Waterloo - Alt Heidelberg**

Part of Lot 14, G.C.T
Woolwich

Sector: Sewage Municipal
Ministry Office: Guelph

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

ESCHERICHIA COLI

C of A Non-Compliance

December 2005	200	CT/100 mL	/mon	1 exceedance	233.6		Other	Assessment Complete - No Action Required
---------------	-----	--------------	------	--------------	-------	--	-------	---

Total C of A Non-Compliance = 1 exceedance

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to October 2006. For up-to-date information, please contact the appropriate district or area office."

2005 Municipal/Private Sewage Monthly Summary - West Central Region

**The Regional Municipality of
Waterloo - Elmira**

80 First St. East
Woolwich

Sector: Sewage Municipal
Ministry Office: Guelph

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

PHOSPHORUS

C of A Non-Compliance

September 1, 2005 - September 30, 2005	0.5	mg/L	/mon	1 exceedance	0.64		Additional monitoring underway	Assessment Complete - No Further Action Required
---	-----	------	------	--------------	------	--	-----------------------------------	---

Total C of A Non-Compliance = 1 exceedance

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to October 2006. For up-to-date information, please contact the appropriate district or area office."

2005 Municipal/Private Sewage Monthly Summary - West Central Region

**The Regional Municipality of
Waterloo - Kitchener**

368 Mill Park Drive
Kitchener

Sector: Sewage Municipal
Ministry Office: Guelph

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
ESCHERICHIA COLI								
C of A Non-Compliance								
February 1, 2005 - February 28, 2005	200	CT/100 mL	/mon	1 exceedance	593		Action Plan Submitted - Implementing Improvements	Assessment Complete - No Action Required

Total C of A Non-Compliance = 1 exceedance

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to October 2006. For up-to-date information, please contact the appropriate district or area office."

2005 Municipal/Private Sewage Monthly Summary - West Central Region

**The Regional Municipality of
Waterloo - New Hamburg**

1673 Haysville Road
Wilmot

Sector: Sewage Municipal
Ministry Office: Guelph

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

AMMONIA

C of A Non-Compliance

February 14, 2005 - February 15, 2005	2	mg/L	/d	1 exceedance	4.6		Operational Process Modification	Assessment Complete - Incident Resolved
--	---	------	----	--------------	-----	--	-------------------------------------	--

Total C of A Non-Compliance = 1 exceedance

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to October 2006. For up-to-date information, please contact the appropriate district or area office."

2005 Municipal/Private Sewage Monthly Summary - West Central Region

**Wellington Catholic District
School Board - St. John Brebeuf**

30 Millwood Road
Erin

Sector: Miscellaneous
Ministry Office: Guelph

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

BIOCHEMICAL OXYGEN DEMAND

C of A Non-Compliance

January 1, 2005 - December 31, 2005	10	mg/L	/annum	1 exceedance	11		Conducting Study	Assessment Underway
--	----	------	--------	--------------	----	--	------------------	---------------------

Total C of A Non-Compliance = 1 exceedance

NITRATES

C of A Non-Compliance

October 2005	3.5	mg/L	/3 months	1 exceedance	6.8		Operational Process Modification	Voluntary Abatement Program Underway
--------------	-----	------	-----------	--------------	-----	--	-------------------------------------	---

Total C of A Non-Compliance = 1 exceedance

TOTAL SUSPENDED SOLIDS

C of A Non-Compliance

October 2005	10	mg/L	/annum	1 exceedance	11		Operational Process Modification	Voluntary Abatement Program Underway
--------------	----	------	--------	--------------	----	--	-------------------------------------	---

Total C of A Non-Compliance = 1 exceedance

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to October 2006. For up-to-date information, please contact the appropriate district or area office."