

2006 Industrial Sewage Monthly Summary - Southwestern Region

Bruce Power Inc. - Bruce A

Lot 28, Conc A Plan
Kincardine

Sector: Electric Power Generation
Ministry Office: Owen Sound

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

AMMONIA

C of A/Permit Non-Compliance

September 10, 2006 - September 11, 2006	5	mg/L	/mon	1 exceedance	6.1	6.1	Other	Assessment Complete - Incident Resolved
--	---	------	------	--------------	-----	-----	-------	--

Total C of A/Permit Non-Compliance = 1 exceedance

TEMPERATURE

C of A/Permit Non-Compliance

August 2006	32.2	deg. C	rolling avg	1 exceedance	32.47	32.47	Ceased Operations	Assessment Complete - No Action Required
August 2006	32.2	deg. C	24hr avg	1 exceedance	32.36	32.36	Ceased Operations, Other	Assessment Complete - Incident Resolved

Total C of A/Permit Non-Compliance = 2 exceedances

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Industrial Sewage Monthly Summary - Southwestern Region

Bruce Power Inc. - Bruce B

Lot 11- 20 Conc, Lake Range Plan
Kincardine

Sector: Electric Power Generation
Ministry Office: Owen Sound

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

ACUTE LETHALITY DAPHNIA

Legislation Non-Compliance

May 2006	Pass	acute toxicity	any	2 exceedances	Fail	Fail	Additional Monitoring Underway	Assessment complete - Incident resolved
----------	------	----------------	-----	---------------	------	------	--------------------------------	---

Total Legislation Non-Compliance = 2 exceedances

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Industrial Sewage Monthly Summary - Southwestern Region

Bruce Power Inc. - Bruce Nuclear Power Development

Lot 28, Conc A Plan
Kincardine

Sector: Electric Power Generation
Ministry Office: Owen Sound

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

LOW PH EFFLUENT

Legislation Non-Compliance

April 13, 2006 - April 14, 2006	6	pH	any	2 exceedances	5.8	5.8	Equipment Modified, Repaired, Replaced or Re- calibrated	Assessment Complete - Incident Resolved
------------------------------------	---	----	-----	---------------	-----	-----	--	--

Total Legislation Non-Compliance = 2 exceedances

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Industrial Sewage Monthly Summary - Southwestern Region

Cabot Canada Ltd.

800 Tashmoo Avenue
Sarnia

Sector: Inorganic Chemicals
Ministry Office: Sarnia

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

ALUMINUM

Legislation Non-Compliance

October 2006	3.5	kg/d	24hr avg	1 exceedance	5.26	5.26	Action Plan Submitted - Implementing Improvements	Assessment underway, Voluntary Abatement Program Underway
--------------	-----	------	----------	--------------	------	------	--	---

Total Legislation Non-Compliance = 1 exceedance

DISSOLVED ORGANIC CARBON

Legislation Non-Compliance

August 2006	29	kg/d	24hr avg	1 exceedance	33	33	Equipment Modified, Repaired, Replaced or Re- calibrated	Assessment Complete - Incident Resolved
-------------	----	------	----------	--------------	----	----	--	--

Total Legislation Non-Compliance = 1 exceedance

SUSPENDED SOLIDS

Legislation Non-Compliance

February 2006	48	kg/d	24hr avg	1 exceedance	68.47	68.47	Conducting Study	Assessment underway, Voluntary Abatement Program Underway
May 2006	48	kg/d	24hr avg	1 exceedance	153	153	Conducting Study	Assessment underway, Voluntary Abatement Program Underway

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Industrial Sewage Monthly Summary - Southwestern Region

Cabot Canada Ltd.

800 Tashmoo Avenue
Sarnia

Sector: Inorganic Chemicals
Ministry Office: Sarnia

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
August 2, 2006 - August 3, 2006	48	kg/d	24hr avg	1 exceedance	182	182	Action Plan Submitted - Implementing Improvements	Assessment Underway
December 2006	48	kg/d	24hr avg	1 exceedance	79.3	79.3	Action Plan Submitted - Implementing Improvements	Assessment Underway

Total Legislation Non-Compliance = 4 exceedances

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Industrial Sewage Monthly Summary - Southwestern Region

Chinook Global Limited - Sombra Site

224 Holt Line W
St. Clair

Sector: Organic Chemicals Manufacturing
Ministry Office: Sarnia

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

LOW PH EFFLUENT

Legislation Non-Compliance

October 2006	6	pH	any	1 exceedance	5.26	5.26	Equipment Modified, Repaired, Replaced or Re-calibrated	Assessment Complete - No Action Required
--------------	---	----	-----	--------------	------	------	---	--

Total Legislation Non-Compliance = 1 exceedance

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Industrial Sewage Monthly Summary - Southwestern Region

Cold Water Fisheries Inc.

12297 Highway 12, Coldwater
Severn

Sector: Miscellaneous
Ministry Office: Barrie

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

PHOSPHORUS

C of A/Permit Non-Compliance

February 1, 2006 - February 28, 2006	0.5	mg/L	/mon	1 exceedance	1	1	Operational Process Modification	Assessment Complete - No Action Required
June 2006	0.5	mg/L	/mon	1 exceedance	1.1	1.1	None Required	Assessment Complete - No Action Required

Total C of A/Permit Non-Compliance = 2 exceedances

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Industrial Sewage Monthly Summary - Southwestern Region

**Dow Chemical Canada Inc. -
LaSalle Landfill Site**

463 LaSalle Line
St. Clair

Sector: Organic Chemicals Manufacturing
Ministry Office: Sarnia

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

SUSPENDED SOLIDS

Legislation Non-Compliance

November 2006	160	kg	24hr	1 exceedance	630	630	Action Plan Submitted - Implementing Improvements	Voluntary Abatement Program Underway
---------------	-----	----	------	--------------	-----	-----	--	---

Total Legislation Non-Compliance = 1 exceedance

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Industrial Sewage Monthly Summary - Southwestern Region

Dow Chemical Canada Inc. - Sarnia Site

1425 Vidal St S
Sarnia

Sector: Organic Chemicals Manufacturing
Ministry Office: Sarnia

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

CARBON TETRACHLORIDE

C of A/Permit Non-Compliance

December 2006	5	µg/L	/d	1 exceedance	5.5	5.5	Operational Process Modification	Assessment underway, Voluntary Abatement Program Underway
---------------	---	------	----	--------------	-----	-----	----------------------------------	---

Total C of A/Permit Non-Compliance = 1 exceedance

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Industrial Sewage Monthly Summary - Southwestern Region

Ethyl Canada Inc.

220 St. Clair Parkway
St. Clair

Sector: Organic Chemicals Manufacturing
Ministry Office: Sarnia

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

CHLORINE RESIDUAL

C of A/Permit Non-Compliance

October 30, 2006 - October 31, 2006	0.01	mg/L	any	2 exceedances	0.0112	0.0149	Operational Process Modification	Assessment Complete - Incident Resolved
--	------	------	-----	---------------	--------	--------	-------------------------------------	--

Total C of A/Permit Non-Compliance = 2 exceedances

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Industrial Sewage Monthly Summary - Southwestern Region

**Ford Motor Company of Canda
Limited - Windsor**

1 Quality Way
Windsor

Sector: Metal Casting
Ministry Office: Windsor

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

SUSPENDED SOLIDS

C of A/Permit Non-Compliance

January 2006	15	mg/L	/2wk	1 exceedance	60	60	Other	Assessment Complete - Incident Resolved, Assessment Complete - No Action Required
--------------	----	------	------	--------------	----	----	-------	--

Total C of A/Permit Non-Compliance = 1 exceedance

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Industrial Sewage Monthly Summary - Southwestern Region

Gay Lea Foods Co-Operative Limited

21 Clinton Street North
South Bruce

Sector: Miscellaneous
Ministry Office: Owen Sound

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

ESCHERICHIA COLI

C of A/Permit Non-Compliance

May 2006	200	CT/100 mL	/mon	1 exceedance	1560	200	Other	Assessment Complete - No Action Required
----------	-----	--------------	------	--------------	------	-----	-------	--

Total C of A/Permit Non-Compliance = 1 exceedance

FLOW

C of A/Permit Non-Compliance

December 1, 2006 - December 31, 2006	245	m3	mon avg	1 exceedance	259	259	Equipment Modified, Repaired, Replaced or Re- calibrated	Assessment Complete - Incident Resolved
---	-----	----	---------	--------------	-----	-----	--	--

Total C of A/Permit Non-Compliance = 1 exceedance

PHOSPHORUS

C of A/Permit Non-Compliance

March 2006	2	mg/L	/d	1 exceedance	2.54	1518	Other	Assessment Complete - No Action Required
------------	---	------	----	--------------	------	------	-------	--

Total C of A/Permit Non-Compliance = 1 exceedance

SUSPENDED SOLIDS

C of A/Permit Non-Compliance

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Industrial Sewage Monthly Summary - Southwestern Region

Gay Lea Foods Co-Operative Limited

21 Clinton Street North
South Bruce

Sector: Miscellaneous
Ministry Office: Owen Sound

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
March 2006	30	mg/L	/d	1 exceedance	33	2005	Action Plan Submitted - Implementing Improvements	Provincial Officer's Order issued
November 2006	30	mg/L	/d	1 exceedance	35.8	35.8	Operational Process Modification	Other Abatement Action Taken, Voluntary Abatement Program Underway
December 2006	30	mg/L	/d	1 exceedance	33	33	New Equipment or Treatment Process Installed	Assessment Underway

Total C of A/Permit Non-Compliance = 3 exceedances

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Industrial Sewage Monthly Summary - Southwestern Region

Harold Sutherland Construction Limited - Keppel Quarry

Grey Rd. 17, Keppel Twp.
Georgian Bluffs

Sector: Miscellaneous
Ministry Office: Owen Sound

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
AMMONIA								
C of A/Permit Non-Compliance								
June 1, 2006 - June 30, 2006	0.01	mg/L	mon avg	1 exceedance	0.017	0.017	Additional Monitoring Underway, Operational Process Modification	Assessment Underway, Other Abatement Action Taken
July 1, 2006 - July 31, 2006	0.01	mg/L	mon avg	1 exceedance	0.018	0.018	Additional Monitoring Underway, Operational Process Modification	Assessment Underway, Other Abatement Action Taken
August 1, 2006 - August 31, 2006	0.01	mg/L	mon avg	1 exceedance	0.03	0.03	Additional Monitoring Underway, Operational Process Modification	Assessment Underway, Other Abatement Action Taken
September 1, 2006 - September 30, 2006	0.01	mg/L	mon avg	1 exceedance	0.015	0.015	Additional Monitoring Underway, Operational Process Modification	Assessment Underway, Other Abatement Action Taken
October 1, 2006 - October 31, 2006	0.01	mg/L	mon avg	1 exceedance	0.012	0.012	Additional Monitoring Underway, Operational Process Modification	Assessment Underway, Other Abatement Action Taken

Total C of A/Permit Non-Compliance = 5 exceedances

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Industrial Sewage Monthly Summary - Southwestern Region

KWH Pipe (Canada) Ltd.

37 Centre St.,
Huntsville

Sector: Miscellaneous
Ministry Office: Barrie

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

TEMPERATURE

C of A/Permit Non-Compliance

May 2006	2	deg. C	/d	1 exceedance	2.9	2.9	New Equipment or Treatment Process Installed	Assessment Complete - Incident Resolved
----------	---	--------	----	--------------	-----	-----	--	---

Total C of A/Permit Non-Compliance = 1 exceedance

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Industrial Sewage Monthly Summary - Southwestern Region

NOVA Chemicals Corporation

510 Moore Line Road
St. Clair

Sector: Organic Chemicals Manufacturing
Ministry Office: Sarnia

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

ALUMINUM

Legislation Non-Compliance

December 2006	2.6	kg/d	/d	1 exceedance	3.38	3.38	Operational Process Modification	Voluntary Abatement Program Underway
---------------	-----	------	----	--------------	------	------	----------------------------------	--------------------------------------

Total Legislation Non-Compliance = 1 exceedance

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Industrial Sewage Monthly Summary - Southwestern Region

Ontario Power Generation Inc. - Lambton Generating Station

1886 St Clair Pky Lots 15 16 & 17 Front Con
St. Clair

Sector: Electric Power Generation
Ministry Office: Sarnia

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

ACUTE LETHALITY - TROUT

C of A/Permit Non-Compliance

May 2006	Pass	acute toxicity	any	1 exceedance	Fail	1	Ceased Operations	Assessment Complete - Incident Resolved
----------	------	----------------	-----	--------------	------	---	-------------------	---

Total C of A/Permit Non-Compliance = 1 exceedance

ACUTE LETHALITY DAPHNIA

C of A/Permit Non-Compliance

February 2006	Pass	acute toxicity	any	1 exceedance	Fail	1	Additional Monitoring Underway	Assessment Complete - No Action Required
February 2006	Pass	acute toxicity	any	1 exceedance	Fail	1	Conducting Study	Assessment underway

Total C of A/Permit Non-Compliance = 2 exceedances

ALUMINUM

C of A/Permit Non-Compliance

January 2006	0.8	mg/L	any	1 exceedance	1.1	1.1	Additional Monitoring Underway	Assessment underway
--------------	-----	------	-----	--------------	-----	-----	--------------------------------	---------------------

Total C of A/Permit Non-Compliance = 1 exceedance

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Industrial Sewage Monthly Summary - Southwestern Region

Prestressed Systems Incorporated

4955 Walker Road
Tecumseh

Sector: Miscellaneous
Ministry Office: Windsor

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

SUSPENDED SOLIDS

C of A/Permit Non-Compliance

March 1, 2006 - March 31, 2006	15	mg/L	mon avg	1 exceedance	17.64	17.64	Equipment Modified, Repaired, Replaced or Re- calibrated	Assessment Complete - Incident Resolved
April 1, 2006 - April 30, 2006	15	mg/L	mon avg	1 exceedance	29.65	29.65	None Required	Assessment Complete - No Action Required
July 1, 2006 - July 31, 2006	15	mg/L	mon avg	1 exceedance	21	21	None Required	Assessment Complete - No Action Required

Total C of A/Permit Non-Compliance = 3 exceedances

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Industrial Sewage Monthly Summary - Southwestern Region

**Shell Canada Products Limited -
Sarnia**

150 St. Clair Parkway
St. Clair

Sector: Petroleum Refineries
Ministry Office: Sarnia

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

VOLATILE SUSPENDED SOLIDS

C of A/Permit Non-Compliance

August 2006	15	ppm	any	3 exceedances	22.6	437	Conducting Study	Voluntary Abatement Program Underway
October 2006	15	ppm	any	2 exceedances	31.1	790	Action Plan Submitted - Implementing Improvements	Voluntary Abatement Program Underway

Total C of A/Permit Non-Compliance = 5 exceedances

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Industrial Sewage Monthly Summary - Southwestern Region

Sifto Canada Corp.

300 North Harbour Road West
Goderich

Sector: Miscellaneous
Ministry Office: Sarnia

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

CHLORIDE

C of A/Permit Non-Compliance

September 1, 2006 - September 30, 2006	7700	mg/L	/mon	1 exceedance	25000	25000	Operational Process Modification	Assessment Underway
---	------	------	------	--------------	-------	-------	-------------------------------------	---------------------

Total C of A/Permit Non-Compliance = 1 exceedance

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Industrial Sewage Monthly Summary - Southwestern Region

Sofina Foods Inc./Aliments Sofina Inc.

147 John Street, Dublin
West Perth

Sector: Miscellaneous
Ministry Office: London

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

BIOCHEMICAL OXYGEN DEMAND

Order Non-Compliance

August 18, 2006 - August 23, 2006	10	mg/L	rolling avg	4 exceedances	11.8	19.8	Conducting Study	Assessment Underway, Provincial Officer's Order Issued
August 15, 2006 - August 18, 2006	15	mg/L	/d	3 exceedances	18	24	Conducting Study	Assessment Underway, Provincial Officer's Order Issued

Total Order Non-Compliance = 7 exceedances

DISSOLVED OXYGEN

Order Non-Compliance

August 2006	4	mg/L	/d	1 exceedance	2.4	2.4	Conducting Study	Assessment Underway, Provincial Officer's Order Issued
-------------	---	------	----	--------------	-----	-----	------------------	--

Total Order Non-Compliance = 1 exceedance

FLOW

Order Non-Compliance

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Industrial Sewage Monthly Summary - Southwestern Region

Sofina Foods Inc./Aliments Sofina Inc.

147 John Street, Dublin
West Perth

Sector: Miscellaneous
Ministry Office: London

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
August 23, 2006 - August 24, 2006	500	m3	/d	2 exceedances	510	540	Conducting Study	Assessment Underway, Provincial Officer's Order Issued

Total Order Non-Compliance = 2 exceedances

HIGH PH EFFLUENT

C of A/Permit Non-Compliance

December 2006	8.5	pH	/d	1 exceedance	8.9	8.9	Conducting Study	Assessment Underway, Provincial Officer's Order Issued
---------------	-----	----	----	--------------	-----	-----	------------------	--

Total C of A/Permit Non-Compliance = 1 exceedance

SUSPENDED SOLIDS

C of A/Permit Non-Compliance

November 3, 2006 - December 22, 2006	10	mg/L	rolling avg	3 exceedances	11.5	13.8	Conducting Study	Assessment Underway, Provincial Officer's Order Issued
November 7, 2006 - December 29, 2006	15	mg/L	/d	5 exceedances	15.3	18.5	Conducting Study	Assessment Underway, Provincial Officer's Order Issued

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Industrial Sewage Monthly Summary - Southwestern Region

Sofina Foods Inc./Aliments Sofina Inc.

147 John Street, Dublin
West Perth

Sector: Miscellaneous
Ministry Office: London

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
November 5, 2006 - December 29, 2006	54	kg/d	/d	2 exceedances	59.1	60	Conducting Study	Assessment Underway, Provincial Officer's Order Issued

Total C of A/Permit Non-Compliance = 10 exceedances

Order Non-Compliance

August 18, 2006 - August 29, 2006	10	mg/L	rolling avg	7 exceedances	15.3	21.5	Conducting Study	Assessment Underway, Provincial Officer's Order Issued
August 15, 2006 - August 29, 2006	15	mg/L	/d	9 exceedances	17	28	Conducting Study	Assessment Underway, Provincial Officer's Order Issued

Total Order Non-Compliance = 16 exceedances

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Industrial Sewage Monthly Summary - Southwestern Region

Sun-Canadian Pipe Line Company Limited

Sun Avenue
Sarnia

Sector: Miscellaneous
Ministry Office: Sarnia

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

SUSPENDED SOLIDS

C of A/Permit Non-Compliance

March 2006	25	mg/L	/2wk	1 exceedance	42	42	Action Plan Submitted - Implementing Improvements	Assessment Complete - Incident Resolved
------------	----	------	------	--------------	----	----	--	--

Total C of A/Permit Non-Compliance = 1 exceedance

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Industrial Sewage Monthly Summary - Southwestern Region

**Suncor Energy Products Inc. -
Sarnia**

1900 River Road
Sarnia

Sector: Petroleum Refineries
Ministry Office: Sarnia

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

PHENOL

Legislation Non-Compliance

January 2006	0.42	kg	/d	1 exceedance	1.15	1.15	Conducting Study	Assessment underway
February 2006	0.47	kg	/d	2 exceedances	0.79	1.25	conducting study	Assessment underway

Total Legislation Non-Compliance = 3 exceedances

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Industrial Sewage Monthly Summary - Southwestern Region

Terra International (Canada) Inc.

161 Bickford Line, Courtright
St. Clair

Sector: Inorganic Chemicals
Ministry Office: Sarnia

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

ALUMINUM

Legislation Non-Compliance

March 2006	8.9	kg/d	/d	1 exceedance	14.89	14.89	Additional Monitoring Underway	Assessment Complete - No Action Required
August 2006	8.9	kg/d	/d	1 exceedance	13.56	13.56	Additional Monitoring Underway	Assessment Complete - Incident Resolved
November 2006	8.9	kg/d	/d	1 exceedance	9.86	9.86	Additional Monitoring Underway	Assessment Complete - No Action Required

Total Legislation Non-Compliance = 3 exceedances

FLUORIDE

Legislation Non-Compliance

March 2006	4	kg/d	/d	1 exceedance	9.8	9.8	Additional Monitoring Underway	Assessment Complete - No Action Required
June 2006	4	kg/d	/d	1 exceedance	9.8	9.8	Additional Monitoring Underway	Assessment Complete - No Action Required
August 2006	4	kg/d	/d	1 exceedance	10.47	10.47	Additional Monitoring Underway	Assessment Complete - No Action Required

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Industrial Sewage Monthly Summary - Southwestern Region

Terra International (Canada) Inc.

161 Bickford Line, Courtright
St. Clair

Sector: Inorganic Chemicals
Ministry Office: Sarnia

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
November 2006	4	kg/d	/d	1 exceedance	10.75	10.75	Additional Monitoring Underway	Assessment Complete - No Action Required

Total Legislation Non-Compliance = 4 exceedances

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Industrial Sewage Monthly Summary - Southwestern Region

**The Canadian Salt Company
Limited**

200 Morton Dr
Windsor

Sector: Industrial Minerals
Ministry Office: Windsor

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

ACUTE LETHALITY - TROUT

C of A/Permit Non-Compliance

September 2006	Pass	acute toxicity	any	1 exceedance	Fail	1	Operational Process Modification	Assessment Complete - Incident Resolved
----------------	------	----------------	-----	--------------	------	---	----------------------------------	---

Total C of A/Permit Non-Compliance = 1 exceedance

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."