

2006 Municipal/Private Sewage Monthly Summary - Central Region

**1319536 Ontario Ltd. - Royal
Ontario Golf Club**

6378 Trafalgar Road, Hornby
Milton

Sector: Miscellaneous
Ministry Office: Halton-Peel

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
(AMMONIA + AMMONIUM) NITROGEN								
C of A/Permit Non-Compliance								
April 1, 2006 - April 30, 2006	5	mg/L	mon avg	1 exceedance	16	16	Action Plan Submitted - Implementing Improvements	Assessment Underway
May 1, 2006 - May 31, 2006	5	mg/L	mon avg	1 exceedance	30	30	Action Plan Submitted - Implementing Improvements	Assessment Underway
June 1, 2006 - June 30, 2006	5	mg/L	mon avg	1 exceedance	8.8	8.8	Action Plan Submitted - Implementing Improvements	Assessment Underway
July 1, 2006 - July 31, 2006	5	mg/L	mon avg	1 exceedance	6.1	6.1	Action Plan Submitted - Implementing Improvements	Assessment Underway
August 1, 2006 - August 31, 2006	5	mg/L	mon avg	1 exceedance	32	32	Action Plan Submitted - Implementing Improvements	Assessment Underway
September 1, 2006 - September 30, 2006	5	mg/L	mon avg	1 exceedance	16	16	Action Plan Submitted - Implementing Improvements	Assessment Underway
October 1, 2006 - October 31, 2006	5	mg/L	mon avg	1 exceedance	15	15	Action Plan Submitted - Implementing Improvements	Assessment Underway
December 1, 2006 - December 31, 2006	5	mg/L	mon avg	1 exceedance	6	6	Action Plan Submitted - Implementing Improvements	Assessment Underway

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Municipal/Private Sewage Monthly Summary - Central Region

**1319536 Ontario Ltd. - Royal
Ontario Golf Club**

6378 Trafalgar Road, Hornby
Milton

Sector: Miscellaneous
Ministry Office: Halton-Peel

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

Total C of A/Permit Non-Compliance = 8 exceedances

CARBONACEOUS BIOCHEMICAL OXYGEN DEMAND

C of A/Permit Non-Compliance

May 1, 2006 - May 31, 2006	30	mg/L	mon avg	1 exceedance	71	71	Action Plan Submitted - Implementing Improvements	Assessment Underway
-------------------------------	----	------	---------	--------------	----	----	--	---------------------

Total C of A/Permit Non-Compliance = 1 exceedance

ESCHERICHIA COLI

C of A/Permit Non-Compliance

April 1, 2006 - April 30, 2006	200	CT/100 mL	mon avg	1 exceedance	1240	1240	Action Plan Submitted - Implementing Improvements	Assessment Underway
May 1, 2006 - May 31, 2006	200	CT/100 mL	mon avg	1 exceedance	8900	8900	Action Plan Submitted - Implementing Improvements	Assessment Underway
June 1, 2006 - June 30, 2006	200	CT/100 mL	mon avg	1 exceedance	3800	3800	Action Plan Submitted - Implementing Improvements	Assessment Underway
August 1, 2006 - August 31, 2006	200	CT/100 mL	mon avg	1 exceedance	3200	3200	Action Plan Submitted - Implementing Improvements	Assessment Underway

Total C of A/Permit Non-Compliance = 4 exceedances

LOW PH EFFLUENT

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Municipal/Private Sewage Monthly Summary - Central Region

**1319536 Ontario Ltd. - Royal
Ontario Golf Club**

6378 Trafalgar Road, Hornby
Milton

Sector: Miscellaneous
Ministry Office: Halton-Peel

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

C of A/Permit Non-Compliance

October 1, 2006 - October 31, 2006	6	pH	none	1 exceedance	5.87	5.87	Action Plan Submitted - Implementing Improvements	Assessment Underway
---------------------------------------	---	----	------	--------------	------	------	--	---------------------

Total C of A/Permit Non-Compliance = 1 exceedance

PHOSPHORUS

C of A/Permit Non-Compliance

May 1, 2006 - May 31, 2006	10	mg/L	mon avg	1 exceedance	11	11	Action Plan Submitted - Implementing Improvements	Assessment Underway
June 1, 2006 - June 30, 2006	10	mg/L	mon avg	1 exceedance	15	15	Action Plan Submitted - Implementing Improvements	Assessment Underway
August 1, 2006 - August 31, 2006	10	mg/L	mon avg	1 exceedance	13	13	Action Plan Submitted - Implementing Improvements	Assessment Underway
September 1, 2006 - September 30, 2006	10	mg/L	mon avg	1 exceedance	12	12	Action Plan Submitted - Implementing Improvements	Assessment Underway
October 1, 2006 - October 31, 2006	10	mg/L	mon avg	1 exceedance	14	14	Action Plan Submitted - Implementing Improvements	Assessment Underway

Total C of A/Permit Non-Compliance = 5 exceedances

SUSPENDED SOLIDS

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Municipal/Private Sewage Monthly Summary - Central Region

**1319536 Ontario Ltd. - Royal
Ontario Golf Club**

6378 Trafalgar Road, Hornby
Milton

Sector: Miscellaneous
Ministry Office: Halton-Peel

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
C of A/Permit Non-Compliance								
May 1, 2006 - May 31, 2006	30	mg/L	mon avg	1 exceedance	78	78	Action Plan Submitted - Implementing Improvements	Assessment Underway
June 1, 2006 - June 30, 2006	30	mg/L	mon avg	1 exceedance	36	36	Action Plan Submitted - Implementing Improvements	Assessment Underway

Total C of A/Permit Non-Compliance = 2 exceedances

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Municipal/Private Sewage Monthly Summary - Central Region

351658 Ontario Limited - Kaneff Headquarters

8501 Mississauga Rd
Brampton

Sector: Miscellaneous
Ministry Office: Halton-Peel

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

SUSPENDED SOLIDS

C of A/Permit Non-Compliance

February 23, 2006 - June 26, 2006	10	mg/L	rolling avg	9 exceedances	11	15.25	New Equipment or Treatment Process Installed	Voluntary Abatement Program Underway
September 7, 2006 - December 29, 2006	10	mg/L	rolling avg	13 exceedances	11	21.75	Action Plan Submitted - Implementing Improvements	Other Abatement Action Taken, Voluntary Abatement Program Underway

Total C of A/Permit Non-Compliance = 22 exceedances

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Municipal/Private Sewage Monthly Summary - Central Region

**Azimuth Environmental
Consulting Inc., Clublink
Corporation**

14001 Warden Avenue, Stouffville
Whitchurch-Stouffville

Sector: Miscellaneous
Ministry Office: York-Durham

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

AMMONIA

C of A/Permit Non-Compliance

April 1, 2006 - April 30, 2006	2.5	mg/L	mon avg	1 exceedance	8.7	8.7	None Required	Assessment Complete - Incident Resolved
-----------------------------------	-----	------	---------	--------------	-----	-----	---------------	--

Total C of A/Permit Non-Compliance = 1 exceedance

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Municipal/Private Sewage Monthly Summary - Central Region

City of Toronto - Humber WPCP

130 The Queensway
Toronto

Sector: Sewage Municipal
Ministry Office: Toronto

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
PHOSPHORUS								
C of A/Permit Non-Compliance								
September 1, 2006 - September 30, 2006	1	mg/L	mon avg	1 exceedance	1.62	1.62	Additional Monitoring Underway, Operational Process Modification	Assessment Complete - Incident Resolved

Total C of A/Permit Non-Compliance = 1 exceedance

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Municipal/Private Sewage Monthly Summary - Central Region

Clublink Corporation - Blue Spring Golf Club

13448 Dublin Line
Halton Hills

Sector: Miscellaneous
Ministry Office: Halton-Peel

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

AMMONIA

C of A/Permit Non-Compliance

May 1, 2006 - May 31, 2006	2.5	mg/L	mon avg	1 exceedance	3.01	3.01	Equipment Modified, Repaired, Replaced or Re- calibrated	Assessment Complete - Incident Resolved
-------------------------------	-----	------	---------	--------------	------	------	--	--

Total C of A/Permit Non-Compliance = 1 exceedance

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Municipal/Private Sewage Monthly Summary - Central Region

Clublink Corporation - King Valley Golf Club

15675 Dufferin Street, King City
King

Sector: Miscellaneous
Ministry Office: York-Durham

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

BIOCHEMICAL OXYGEN DEMAND

C of A/Permit Non-Compliance

January 1, 2006 - December 31, 2006	30	mg/L	mon avg	3 exceedances	38	49	Equipment Modified, Repaired, Replaced or Re- calibrated	Voluntary Abatement Program Underway
--	----	------	---------	---------------	----	----	--	---

Total C of A/Permit Non-Compliance = 3 exceedances

ESCHERICHIA COLI

C of A/Permit Non-Compliance

January 1, 2006 - December 31, 2006	50	cfu/100 ml (memb rane filtratio n)	mon avg	2 exceedances	239	727	Equipment Modified, Repaired, Replaced or Re- calibrated	Voluntary Abatement Program Underway
--	----	---	---------	---------------	-----	-----	--	---

Total C of A/Permit Non-Compliance = 2 exceedances

SUSPENDED SOLIDS

C of A/Permit Non-Compliance

December 1, 2006 - December 31, 2006	30	mg/L	mon avg	1 exceedance	31	31	Equipment Modified, Repaired, Replaced or Re- calibrated	Voluntary Abatement Program Underway
---	----	------	---------	--------------	----	----	--	---

Total C of A/Permit Non-Compliance = 1 exceedance

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Municipal/Private Sewage Monthly Summary - Central Region

Clublink Corporation - King Valley Golf Club

15675 Dufferin Street, King City
King

Sector: Miscellaneous
Ministry Office: York-Durham

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

TOTAL AMMONIA NITROGEN

C of A/Permit Non-Compliance

January 1, 2006 - December 31, 2006	2.5	mg/L	mon avg	12 exceedances	12.2	29	Equipment Modified, Repaired, Replaced or Re- calibrated	Voluntary Abatement Program Underway
--	-----	------	---------	----------------	------	----	--	---

Total C of A/Permit Non-Compliance = 12 exceedances

TOTAL NITROGEN

C of A/Permit Non-Compliance

January 1, 2006 - December 31, 2006	22	mg/L	mon avg	7 exceedances	24	34	Equipment Modified, Repaired, Replaced or Re- calibrated	Voluntary Abatement Program Underway
--	----	------	---------	---------------	----	----	--	---

Total C of A/Permit Non-Compliance = 7 exceedances

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Municipal/Private Sewage Monthly Summary - Central Region

Clublink Corporation - King's Riding Golf Club

Lot 17, Con. 2
King

Sector: Miscellaneous
Ministry Office: York-Durham

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

ESCHERICHIA COLI

C of A/Permit Non-Compliance

June 1, 2006 - June 30, 2006	100	cfu/100 ml (membrane filtration)	mon avg	1 exceedance	167	167	Equipment Modified, Repaired, Replaced or Re- calibrated	Assessment Complete - Incident Resolved
---------------------------------	-----	---	---------	--------------	-----	-----	--	--

Total C of A/Permit Non-Compliance = 1 exceedance

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Municipal/Private Sewage Monthly Summary - Central Region

ClubLink Corporation - Rattlesnake Point Golf Club

25 - 5405 Regional Rd
Milton

Sector: Miscellaneous
Ministry Office: Halton-Peel

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

AMMONIA NITROGEN

C of A/Permit Non-Compliance

January 1, 2006 - December 31, 2006	2.5	mg/L	annual avg	1 exceedance	4.77	4.77	Action Plan Submitted - Implementing Improvements, Additional Monitoring Underway, Conducting Study, Equipment Modified, Repaired, Replaced or Re- calibrated	Voluntary Abatement Program Underway
--	-----	------	------------	--------------	------	------	---	---

Total C of A/Permit Non-Compliance = 1 exceedance

ESCHERICHIA COLI

C of A/Permit Non-Compliance

July 1, 2006 - July 31, 2006	200	CT/100 mL	mon avg	1 exceedance	1306	1306	Action Plan Submitted - Implementing Improvements, Conducting Study	Voluntary Abatement Program Underway
---------------------------------	-----	--------------	---------	--------------	------	------	---	---

Total C of A/Permit Non-Compliance = 1 exceedance

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Municipal/Private Sewage Monthly Summary - Central Region

**The Regional Municipality of
Durham - Duffin Creek WPCP**

901 McKay Rd
Pickering

Sector: Sewage Municipal
Ministry Office: York-Durham

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

PHOSPHORUS

C of A/Permit Non-Compliance

May 1, 2006 - May 31, 2006	1	mg/L	mon avg	1 exceedance	1.17	1.17	Additional Monitoring Underway	Assessment Complete - Incident Resolved
-------------------------------	---	------	---------	--------------	------	------	-----------------------------------	--

Total C of A/Permit Non-Compliance = 1 exceedance

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Municipal/Private Sewage Monthly Summary - Central Region

**The Regional Municipality of
Durham - Harmony Creek WPCP**

785 Colonel Sam Drive
Oshawa

Sector: Sewage Municipal
Ministry Office: York-Durham

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
ESCHERICHIA COLI								
C of A/Permit Non-Compliance								
May 1, 2006 - May 31, 2006	200	cfu/100 ml (memb rane filtratio n)	mon avg. on a geo. mean density	1 exceedance	10089	10089	Other	Assessment Complete - Incident Resolved
June 1, 2006 - June 30, 2006	200	cfu/100 ml (memb rane filtratio n)	mon avg. on a geo. mean density	1 exceedance	1734	1734	Other	Assessment Complete - Incident Resolved
July 1, 2006 - July 31, 2006	200	cfu/100 ml (memb rane filtratio n)	mon avg. on a geo. mean density	1 exceedance	2207	2207	Other	Assessment Complete - Incident Resolved

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Municipal/Private Sewage Monthly Summary - Central Region

**The Regional Municipality of
Durham - Harmony Creek WPCP**

785 Colonel Sam Drive
Oshawa

Sector: Sewage Municipal
Ministry Office: York-Durham

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
August 1, 2006 - August 31, 2006	200	cfu/100 ml (membrane filtration)	mon avg. on a geo. mean density	1 exceedance	1864	1864	Other	Assessment Complete - Incident Resolved
September 1, 2006 - September 30, 2006	200	cfu/100 ml (membrane filtration)	mon avg. on a geo. mean density	1 exceedance	814	814	Other	Assessment Complete - Incident Resolved

Total C of A/Permit Non-Compliance = 5 exceedances

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Municipal/Private Sewage Monthly Summary - Central Region

The Regional Municipality of Durham - Nonquon River WPCP

1730 Scugog Line 8
Scugog

Sector: Sewage Municipal
Ministry Office: York-Durham

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

AMMONIA

C of A/Permit Non-Compliance

February 1, 2006 - February 28, 2006	3	mg/L	mon avg	1 exceedance	12.86	12.86	Conducting Study	Assessment Underway
February 1, 2006 - February 28, 2006	11.7	kg/d	mon avg	1 exceedance	59.7	59.7	Conducting Study	Assessment Underway
March 1, 2006 - March 31, 2006	10	mg/L	mon avg	1 exceedance	12.85	12.85	Action Plan Submitted - Implementing Improvements, Additional Monitoring Underway	Provincial Officer's Order Issued, Voluntary Abatement Program Underway
March 1, 2006 - March 31, 2006	38.7	kg/d	mon avg	1 exceedance	90.6	90.6	Action Plan Submitted - Implementing Improvements, Additional Monitoring Underway	Provincial Officer's Order Issued, Voluntary Abatement Program Underway
April 1, 2006 - April 30, 2006	5	mg/L	mon avg	1 exceedance	6.29	6.29	Conducting Study	Assessment Underway
April 1, 2006 - April 30, 2006	19.4	kg/d	mon avg	1 exceedance	40.2	40.2	Conducting Study	Assessment Underway

Total C of A/Permit Non-Compliance = 6 exceedances

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Municipal/Private Sewage Monthly Summary - Central Region

The Regional Municipality of Peel - Lakeview WPCP

1300 Lakeshore Rd E
Mississauga

Sector: Sewage Municipal
Ministry Office: Halton-Peel

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
PHOSPHORUS								
C of A/Permit Non-Compliance								
July 1, 2006 - July 31, 2006	1	mg/L	mon avg	1 exceedance	1.07	1.07	Operational Process Modification	Voluntary Abatement Program Underway
November 1, 2006 - November 30, 2006	1	mg/L	mon avg	1 exceedance	1.155	1.155	Action Plan Submitted - Implementing Improvements	Voluntary Abatement Program Underway

Total C of A/Permit Non-Compliance = 2 exceedances

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Municipal/Private Sewage Monthly Summary - Central Region

**The Regional Municipality of
York - Stouffville WPCP**

4 Park Drive
Whitchurch-Stouffville

Sector: Sewage Municipal
Ministry Office: York-Durham

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

ESCHERICHIA COLI

C of A/Permit Non-Compliance

April 1, 2006 - April 30, 2006	200	cfu/100 ml (membrane filtration)	mon avg	1 exceedance	342	342	Other	Assessment Complete - No Action Required
-----------------------------------	-----	---	---------	--------------	-----	-----	-------	---

Total C of A/Permit Non-Compliance = 1 exceedance

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Municipal/Private Sewage Monthly Summary - Central Region

**The Regional Municipality of
York - Sutton WPCP**

5741 Black River Rd
Georgina

Sector: Sewage Municipal
Ministry Office: York-Durham

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

ESCHERICHIA COLI

C of A/Permit Non-Compliance

October 2006	100	CT/100 mL	mon avg	1 exceedance	181	181	Other	Assessment Complete - No Action Required
--------------	-----	--------------	---------	--------------	-----	-----	-------	---

Total C of A/Permit Non-Compliance = 1 exceedance

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."