

2006 Municipal/Private Sewage Monthly Summary - Northern Region

City of Greater Sudbury - Dowling STP

Riverside Drive, Dowling
Greater Sudbury

Sector: Sewage Municipal
Ministry Office: Sudbury

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

ESCHERICHIA COLI

C of A/Permit Non-Compliance

November 1, 2006 - November 30, 2006	200	CT/100 mL	mon avg	1 exceedance	10000	10000	Other	Assessment Underway
-----------------------------------------	-----	--------------	---------	--------------	-------	-------	-------	---------------------

Total C of A/Permit Non-Compliance = 1 exceedance

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Municipal/Private Sewage Monthly Summary - Northern Region

**City of Greater Sudbury -
Sudbury STP**

1173 Kelly Lake Rd
Greater Sudbury

Sector: Sewage Municipal
Ministry Office: Sudbury

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
ESCHERICHIA COLI								
C of A/Permit Non-Compliance								
August 1, 2006 - August 31, 2006	500	CT/100 mL	mon avg	1 exceedance	10000	10000	Training/Procedure Change	Assessment Complete - Incident Resolved
December 1, 2006 - December 31, 2006	500	CT/100 mL	mon avg	1 exceedance	10000	10000	None Required	Assessment Complete - No Action Required

Total C of A/Permit Non-Compliance = 2 exceedances

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Municipal/Private Sewage Monthly Summary - Northern Region

City of Greater Sudbury - Walden STP

Lot: 10, Conc: 3, Walden STP
Greater Sudbury

Sector: Sewage Municipal
Ministry Office: Sudbury

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

ESCHERICHIA COLI

C of A/Permit Non-Compliance

December 1, 2006 - December 31, 2006	200	CT/100 mL	mon avg	1 exceedance	10000	10000	None Required	Assessment Complete - No Action Required
-----------------------------------------	-----	--------------	---------	--------------	-------	-------	---------------	---------------------------------------------

Total C of A/Permit Non-Compliance = 1 exceedance

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Municipal/Private Sewage Monthly Summary - Northern Region

**The Corporation of the City of
Temiskaming Shores - Haileybury**

100 View Street
Haileybury

Sector: Sewage Municipal
Ministry Office: North Bay

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

SUSPENDED SOLIDS

CofA/Permit Non-Compliance

January 1, 2006 - December 31, 2006	25	mg/L	annual avg	1 exceedance	27.4	27.4	None Required	Assessment Complete - Incident Resolved
----------------------------------------	----	------	------------	--------------	------	------	---------------	--------------------------------------------

Total CofA/Permit Non-Compliance = 1 exceedance

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Municipal/Private Sewage Monthly Summary - Northern Region

**The Corporation of the City of
Temiskaming Shores - New
Liskeard**

Lot 6 & 7, Conc 3
Dymond

Sector: Sewage Municipal
Ministry Office: North Bay

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

PHOSPHORUS

C of A/Permit Non-Compliance

January 1, 2006 - December 31, 2006	1	mg/L	annual avg	1 exceedance	1.55	1.55	Additional Monitoring Underway, New Equipment or Treatment Process Installed	Voluntary Abatement Program Underway
----------------------------------------	---	------	------------	--------------	------	------	------------------------------------------------------------------------------------	-----------------------------------------

Total C of A/Permit Non-Compliance = 1 exceedance

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Municipal/Private Sewage Monthly Summary - Northern Region

The Corporation of the Town of Blind River

15 Martin Street
Blind River

Sector: Sewage Municipal
Ministry Office: Sault Ste. Marie

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

SUSPENDED SOLIDS

C of A/Permit Non-Compliance

March 1, 2006 - March 31, 2006	25	mg/L	mon avg	1 exceedance	26	26	Other	Assessment Underway
-----------------------------------	----	------	---------	--------------	----	----	-------	---------------------

Total C of A/Permit Non-Compliance = 1 exceedance

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Municipal/Private Sewage Monthly Summary - Northern Region

The Corporation of the Town of Espanola

200 Bois St
Espanola

Sector: Sewage Municipal
Ministry Office: Sudbury

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

PHOSPHORUS

C of A/Permit Non-Compliance

August 1, 2006 - August 31, 2006	1	mg/L	/mon	1 exceedance	1.09	1.09	Operational Process Modification	Assessment Complete - Incident Resolved
September 1, 2006 - September 30, 2006	1	mg/L	/mon	1 exceedance	1.27	1.27	Operational Process Modification	Assessment Complete - Incident Resolved

Total C of A/Permit Non-Compliance = 2 exceedances

SUSPENDED SOLIDS

C of A/Permit Non-Compliance

February 1, 2006 - February 28, 2006	25	mg/L	/mon	1 exceedance	51.75	51.75	Operational Process Modification	Assessment Complete - Incident Resolved
-----------------------------------------	----	------	------	--------------	-------	-------	-------------------------------------	--------------------------------------------

Total C of A/Permit Non-Compliance = 1 exceedance

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Municipal/Private Sewage Monthly Summary - Northern Region

**The Corporation of the Town of
Fort Frances**

200 McIrvine Rd
Fort Frances

Sector: Sewage Municipal
Ministry Office: Kenora

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

SUSPENDED SOLIDS

C of A/Permit Non-Compliance

December 2006	25	mg/L	/d	1 exceedance	44	44	Equipment Modified, Repaired, Replaced or Re- calibrated	Assessment Complete - No Action Required
---------------	----	------	----	--------------	----	----	----------------------------------------------------------------	---------------------------------------------

Total C of A/Permit Non-Compliance = 1 exceedance

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Municipal/Private Sewage Monthly Summary - Northern Region

**The Corporation of the Town of
Moosonee**

P.O. Box 127
Moosonee

Sector: Sewage Municipal
Ministry Office: Timmins

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

ESCHERICHIA COLI

C of A/Permit Non-Compliance

April 2006	300	CT/100 mL	any	1 exceedance	150	300	Ceased Operations	Assessment Underway, Voluntary Abatement Program Underway
------------	-----	--------------	-----	--------------	-----	-----	-------------------	-----------------------------------------------------------------

Total C of A/Permit Non-Compliance = 1 exceedance

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Municipal/Private Sewage Monthly Summary - Northern Region

**The Corporation of the Town of
Smooth Rock Falls**

1 Mill Road
Smooth Rock Falls

Sector: Sewage Municipal
Ministry Office: Timmins

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

SUSPENDED SOLIDS

C of A/Permit Non-Compliance

May 1, 2006 - May 31, 2006	25	mg/L	mon avg	1 exceedance	30.2	30.2	Conducting Study	Assessment Underway, Voluntary Abatement Program Underway
-------------------------------	----	------	---------	--------------	------	------	------------------	-----------------------------------------------------------------

Total C of A/Permit Non-Compliance = 1 exceedance

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Municipal/Private Sewage Monthly Summary - Northern Region

The Corporation of the Township of Ear Falls

KM275, Part 1 Aspen Street
Ear Falls

Sector: Sewage Municipal
Ministry Office: Kenora

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
ESCHERICHIA COLI								
C of A/Permit Non-Compliance								
April 2006	200	cfu/100 /d ml (membrane filtration)		1 exceedance	900	900	Additional monitoring underway, Equipment Modified, Repaired, Replaced or Re-calibrated	Assessment Complete - No Action Required
April 2006	200	cfu/100 /d ml (membrane filtration)		2 exceedances	300	4200	Equipment Modified, Repaired, Replaced or Re- calibrated	Assessment Complete - No Action Required
April 2006	200	cfu/100 /d ml (membrane filtration)		1 exceedance	8000	8000	Equipment Modified, Repaired, Replaced or Re- calibrated, New/Modified Sampling Program Underway	Assessment Complete - No Action Required

Total C of A/Permit Non-Compliance = 4 exceedances

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Municipal/Private Sewage Monthly Summary - Northern Region

The Corporation of the Township of Manitowadge

Lot M179, Conc BLKA
Manitowadge

Sector: Sewage Municipal
Ministry Office: Thunder Bay

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

BIOCHEMICAL OXYGEN DEMAND

C of A/Permit Non-Compliance

June 2006	25	mg/L	/d	1 exceedance	26	26	Other	Assessment Underway
September 7, 2006 - September 8, 2006	25	mg/L	/d	15 exceedances	27	63	Operational Process Modification, Other	Assessment Underway

Total C of A/Permit Non-Compliance = 16 exceedances

SUSPENDED SOLIDS

C of A/Permit Non-Compliance

April 2006	30	mg/L	/d	1 exceedance	56	56	Other	Assessment Underway
June 6, 2006 - June 14, 2006	30	mg/L	/d	3 exceedances	35	48	Other	Assessment Underway

Total C of A/Permit Non-Compliance = 4 exceedances

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Municipal/Private Sewage Monthly Summary - Northern Region

The Corporation of the Township of Red Rock

10 Rankin Street
Red Rock

Sector: Sewage Municipal
Ministry Office: Thunder Bay

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

SUSPENDED SOLIDS

Policy/Guideline Non-Conformance

January 1, 2006 - December 31, 2006	50	% remova 1	/annum	1 exceedance	43	43	Other	Assessment Underway
----------------------------------------	----	------------------	--------	--------------	----	----	-------	---------------------

Total Policy/Guideline Non-Conformance = 1 exceedance

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."