

2006 Municipal/Private Sewage Monthly Summary - Southwestern Region

1078385 Ontario Limited

340 Dalhousie St.
Amherstburg

Sector: Miscellaneous
Ministry Office: Windsor

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

SUSPENDED SOLIDS

C of A/Permit Non-Compliance

December 1, 2006 - December 31, 2006	15	mg/L	mon avg	1 exceedance	19.7	19.7	None Required	Assessment Complete - Incident Resolved
---	----	------	---------	--------------	------	------	---------------	--

Total C of A/Permit Non-Compliance = 1 exceedance

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Municipal/Private Sewage Monthly Summary - Southwestern Region

395321 Ontario Limited - Silver Creek Estates Mobile Home Park

1292 Carlyon Line Line
Severn

Sector: Miscellaneous
Ministry Office: Barrie

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

SUSPENDED SOLIDS

C of A/Permit Non-Compliance

December 1, 2006 - December 31, 2006	10	mg/L	mon avg	1 exceedance	41.3	41.3	None Required	Assessment Complete - Incident Resolved
---	----	------	---------	--------------	------	------	---------------	--

Total C of A/Permit Non-Compliance = 1 exceedance

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Municipal/Private Sewage Monthly Summary - Southwestern Region

Anthony's Mobile Home Park Limited

3100 Dorchester Rd
Thames Centre

Sector: Miscellaneous
Ministry Office: London

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

BIOCHEMICAL OXYGEN DEMAND

Policy/Guideline Non-Conformance

January 1, 2006 - December 31, 2006	25	mg/L	/annum	1 exceedance	34.5	34.5	Operational Process Modification	Other Abatement Action Taken
--	----	------	--------	--------------	------	------	-------------------------------------	------------------------------

Total Policy/Guideline Non-Conformance = 1 exceedance

PHOSPHORUS

Policy/Guideline Non-Conformance

October 1, 2006 - October 31, 2006	1	mg/L	mon avg	1 exceedance	1.01	1.01	Operational Process Modification	Other Abatement Action Taken
---------------------------------------	---	------	---------	--------------	------	------	-------------------------------------	------------------------------

Total Policy/Guideline Non-Conformance = 1 exceedance

SUSPENDED SOLIDS

Policy/Guideline Non-Conformance

January 1, 2006 - January 31, 2006	25	mg/L	/annum	1 exceedance	26.5	26.5	Operational Process Modification	Other Abatement Action Taken
---------------------------------------	----	------	--------	--------------	------	------	-------------------------------------	------------------------------

Total Policy/Guideline Non-Conformance = 1 exceedance

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Municipal/Private Sewage Monthly Summary - Southwestern Region

Castle Glen Development Corporation

Lot 10, Conc 3
The Blue Mountains

Sector: Miscellaneous
Ministry Office: Owen Sound

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

SUSPENDED SOLIDS

C of A/Permit Non-Compliance

January 31, 2006 - December 31, 2006	40	mg/L	annual avg	1 exceedance	41.5	41.5	Equipment Modified, Repaired, Replaced or Re- calibrated	Assessment Complete - No Action Required
---	----	------	------------	--------------	------	------	--	---

Total C of A/Permit Non-Compliance = 1 exceedance

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Municipal/Private Sewage Monthly Summary - Southwestern Region

ClubLink Corporation - National Pines Golf Club

Lot 11 Conc 10
Innisfil

Sector: Miscellaneous
Ministry Office: Barrie

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

AMMONIA

C of A/Permit Non-Compliance

June 1, 2006 - June 30, 2006	2.5	mg/L	mon avg	1 exceedance	11.3	11.3	Additional Monitoring Underway	Assessment Underway
October 1, 2006 - October 31, 2006	2.5	mg/L	mon avg	1 exceedance	2.9	2.9	Additional Monitoring Underway	Assessment Underway

Total C of A/Permit Non-Compliance = 2 exceedances

BIOCHEMICAL OXYGEN DEMAND

C of A/Permit Non-Compliance

May 1, 2006 - May 31, 2006	15	mg/L	mon avg	1 exceedance	26	26	Additional Monitoring Underway	Assessment Underway
June 1, 2006 - June 30, 2006	15	mg/L	mon avg	1 exceedance	27	27	Additional Monitoring Underway	Assessment Underway

Total C of A/Permit Non-Compliance = 2 exceedances

ESCHERICHIA COLI

C of A/Permit Non-Compliance

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Municipal/Private Sewage Monthly Summary - Southwestern Region

ClubLink Corporation - National Pines Golf Club

Lot 11 Conc 10
Innisfil

Sector: Miscellaneous
Ministry Office: Barrie

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
August 1, 2006 - August 31, 2006	100	cfu/100 ml (membrane filtration)	mon avg	1 exceedance	274	274	Additional Monitoring Underway	Assessment Underway
November 1, 2006 - November 30, 2006	100	cfu/100 ml (membrane filtration)	mon avg	1 exceedance	106	106	Additional Monitoring Underway	Assessment Underway

Total C of A/Permit Non-Compliance = 2 exceedances

PHOSPHORUS

C of A/Permit Non-Compliance

May 1, 2006 - May 31, 2006	2.5	mg/L	mon avg	1 exceedance	3.1	3.1	Additional Monitoring Underway	Assessment Underway
June 1, 2006 - June 30, 2006	2.5	mg/L	mon avg	1 exceedance	4.3	4.3	Additional Monitoring Underway	Assessment Underway
July 1, 2006 - July 31, 2006	2.5	mg/L	mon avg	1 exceedance	4.9	4.9	Additional Monitoring Underway	Assessment Underway

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Municipal/Private Sewage Monthly Summary - Southwestern Region

ClubLink Corporation - National Pines Golf Club

Lot 11 Conc 10
Innisfil

Sector: Miscellaneous
Ministry Office: Barrie

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
August 1, 2006 - August 31, 2006	2.5	mg/L	mon avg	1 exceedance	6.6	6.6	Additional Monitoring Underway	Assessment Underway
September 1, 2006 - September 30, 2006	2.5	mg/L	mon avg	1 exceedance	5.4	5.4	Additional Monitoring Underway	Assessment Underway
October 1, 2006 - October 31, 2006	2.5	mg/L	mon avg	1 exceedance	6.7	6.7	Additional Monitoring Underway	Assessment Underway
November 1, 2006 - November 30, 2006	2.5	mg/L	mon avg	1 exceedance	4	4	Additional Monitoring Underway	Assessment Underway

Total C of A/Permit Non-Compliance = 7 exceedances

SUSPENDED SOLIDS

C of A/Permit Non-Compliance

May 1, 2006 - May 31, 2006	15	mg/L	mon avg	1 exceedance	24	24	Additional Monitoring Underway	Assessment Underway
July 1, 2006 - July 31, 2006	15	mg/L	mon avg	1 exceedance	18	18	Additional Monitoring Underway	Assessment Underway

Total C of A/Permit Non-Compliance = 2 exceedances

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Municipal/Private Sewage Monthly Summary - Southwestern Region

Crest Support Services (Meadowcrest) Inc.

13570 Elginfield Rd
Lucan Biddulph

Sector: Miscellaneous
Ministry Office: London

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

AMMONIA

C of A/Permit Non-Compliance

November 1, 2006 - November 30, 2006	3	mg/L	mon avg	1 exceedance	4.88	4.88	Equipment Modified, Repaired, Replaced or Re- calibrated, Operational Process Modification, Other	Assessment Complete - No Action Required, Other Abatement Action Taken
---	---	------	---------	--------------	------	------	--	--

Total C of A/Permit Non-Compliance = 1 exceedance

CHLORINE RESIDUAL

C of A/Permit Non-Compliance

August 1, 2006 - August 31, 2006	0.5	mg/L	mon avg	1 exceedance	0.69	0.69	Equipment Modified, Repaired, Replaced or Re- calibrated, Operational Process Modification, Other	Assessment Complete - No Action Required, Other Abatement Action Taken
-------------------------------------	-----	------	---------	--------------	------	------	--	--

Total C of A/Permit Non-Compliance = 1 exceedance

ESCHERICHIA COLI

C of A/Permit Non-Compliance

October 1, 2006 - October 31, 2006	200	CT/100 /mon mL		1 exceedance	315.39	315.39	Equipment Modified, Repaired, Replaced or Re- calibrated, Operational Process Modification, Other	Assessment Complete - No Action Required, Other Abatement Action Taken
---------------------------------------	-----	-------------------	--	--------------	--------	--------	--	--

Total C of A/Permit Non-Compliance = 1 exceedance

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Municipal/Private Sewage Monthly Summary - Southwestern Region

**Crest Support Services
(Meadowcrest) Inc.**

13570 Elginfield Rd
Lucan Biddulph

Sector: Miscellaneous
Ministry Office: London

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

FLOW

C of A/Permit Non-Compliance

November 1, 2006 - November 30, 2006	14.13	m3/d	mon avg	1 exceedance	14.57	14.57	Equipment Modified, Repaired, Replaced or Re- calibrated, Operational Process Modification, Other	Assessment Complete - No Action Required, Other Abatement Action Taken
---	-------	------	---------	--------------	-------	-------	--	--

Total C of A/Permit Non-Compliance = 1 exceedance

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Municipal/Private Sewage Monthly Summary - Southwestern Region

Fern Resort Ltd.

4432 Fern Resort Road
Ramara

Sector: Miscellaneous
Ministry Office: Barrie

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

LOW PH EFFLUENT

C of A/Permit Non-Compliance

July 2006	6	pH	none	1 exceedance	5.98	5.98	Ceased Operations, Equipment Modified, Repaired, Replaced or Re- calibrated	Assessment Complete - No Action Required
-----------	---	----	------	--------------	------	------	--	---

Total C of A/Permit Non-Compliance = 1 exceedance

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Municipal/Private Sewage Monthly Summary - Southwestern Region

Husky Oil Operations Limited - Husky Oil Carl Truck Stop

46 - 4040 Essex Rd
Tecumseh

Sector: Miscellaneous
Ministry Office: Windsor

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

AMMONIA

C of A/Permit Non-Compliance

February 1, 2006 - June 30, 2006	4	mg/L	mon avg	5 exceedances	8.9	27.7	Operational Process Modification	Assessment Complete - No Action Required
-------------------------------------	---	------	---------	---------------	-----	------	-------------------------------------	---

Total C of A/Permit Non-Compliance = 5 exceedances

AMMONIA NITROGEN

C of A/Permit Non-Compliance

January 1, 2006 - January 31, 2006	4	mg/L	mon avg	2 exceedances	6.69	10.6	Operational Process Modification	Provincial Officer's Order issued
---------------------------------------	---	------	---------	---------------	------	------	-------------------------------------	--------------------------------------

Total C of A/Permit Non-Compliance = 2 exceedances

PHOSPHORUS

C of A/Permit Non-Compliance

February 1, 2006 - June 30, 2006	0.5	mg/L	mon avg	2 exceedances	1.25	3.99	Operational Process Modification	Assessment Complete - No Action Required
July 1, 2006 - August 31, 2006	0.5	mg/L	mon avg	2 exceedances	2.5	5.6	New Equipment or Treatment Process Installed	Assessment Complete - No Action Required
September 1, 2006 - September 30, 2006	0.5	mg/L	mon avg	1 exceedance	3	3	Operational Process Modification	Assessment Complete - No Action Required

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Municipal/Private Sewage Monthly Summary - Southwestern Region

Husky Oil Operations Limited - Husky Oil Carl Truck Stop

46 - 4040 Essex Rd
Tecumseh

Sector: Miscellaneous
Ministry Office: Windsor

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
October 1, 2006 - October 31, 2006	0.5	mg/L	mon avg	1 exceedance	2.13	2.13	Operational Process Modification	Assessment Complete - No Action Required
November 1, 2006 - November 30, 2006	0.5	mg/L	mon avg	1 exceedance	1.61	1.61	Operational Process Modification	Assessment Complete - No Action Required
December 1, 2006 - December 31, 2006	0.5	mg/L	mon avg	1 exceedance	1.51	1.51	Operational Process Modification	Assessment Complete - No Action Required

Total C of A/Permit Non-Compliance = 8 exceedances

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Municipal/Private Sewage Monthly Summary - Southwestern Region

Lambton Kent District School Board

14 Notre-Dame
Chatham-Kent

Sector: Miscellaneous
Ministry Office: Windsor

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

AMMONIA

C of A/Permit Non-Compliance

September 1, 2006 - September 30, 2006	3	mg/L	/mon	1 exceedance	10	10	Other	Other Abatement Action Taken
---	---	------	------	--------------	----	----	-------	------------------------------

Total C of A/Permit Non-Compliance = 1 exceedance

PHOSPHORUS

C of A/Permit Non-Compliance

June 1, 2006 - June 30, 2006	1	mg/L	/mon	1 exceedance	2.22	2.22	None Required	Assessment Complete - No Action Required
September 1, 2006 - September 30, 2006	1	mg/L	/mon	1 exceedance	1.44	1.44	Other	Other Abatement Action Taken
November 1, 2006 - November 30, 2006	1	mg/L	/mon	1 exceedance	1.04	1.04	Other	Assessment Complete - No Action Required

Total C of A/Permit Non-Compliance = 3 exceedances

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Municipal/Private Sewage Monthly Summary - Southwestern Region

London District Catholic School Board - Regina Mundi Catholic College

5250 Wellington Rd S
London

Sector: Miscellaneous
Ministry Office: London

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

AMMONIA

C of A/Permit Non-Compliance

January 1, 2006 - December 31, 2006	4	mg/L	/d	40 exceedances	5.5	90	Action Plan Submitted - Implementing Improvements, Other	Other Abatement Action Taken
--	---	------	----	----------------	-----	----	--	------------------------------

Total C of A/Permit Non-Compliance = 40 exceedances

ESCHERICHIA COLI

C of A/Permit Non-Compliance

January 1, 2006 - December 31, 2006	200	CT/100 mL	mon avg	10 exceedances	220	5598	Action Plan Submitted - Implementing Improvements, Other	Other Abatement Action Taken
--	-----	--------------	---------	----------------	-----	------	--	------------------------------

Total C of A/Permit Non-Compliance = 10 exceedances

PHOSPHORUS

C of A/Permit Non-Compliance

February 1, 2006 - December 31, 2006	1	mg/L	mon avg	6 exceedances	1.4	3.2	Action Plan Submitted - Implementing Improvements, Other	Other Abatement Action Taken
---	---	------	---------	---------------	-----	-----	--	------------------------------

Total C of A/Permit Non-Compliance = 6 exceedances

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Municipal/Private Sewage Monthly Summary - Southwestern Region

Municipality of Huron East - Seaforth STP

79468 Hannah Line
Huron East

Sector: Sewage Municipal
Ministry Office: Sarnia

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

SUSPENDED SOLIDS

C of A/Permit Non-Compliance

January 1, 2006 - January 31, 2006	28.5	kg/d	mon avg	1 exceedance	30.93	30.93	Other	Assessment underway
---------------------------------------	------	------	---------	--------------	-------	-------	-------	---------------------

Total C of A/Permit Non-Compliance = 1 exceedance

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Municipal/Private Sewage Monthly Summary - Southwestern Region

**Ontario Realty Corporation -
Ontario Educational Leadership
Centre - OCWA**

7098 Rama Road
Ramara

Sector: Miscellaneous
Ministry Office: Barrie

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

AMMONIA

C of A/Permit Non-Compliance

June 1, 2006 - June 30, 2006	3	mg/L	mon avg	1 exceedance	3.375	3.375	Equipment Modified, Repaired, Replaced or Re- calibrated	Assessment Complete - Incident Resolved
---------------------------------	---	------	---------	--------------	-------	-------	--	--

Total C of A/Permit Non-Compliance = 1 exceedance

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Municipal/Private Sewage Monthly Summary - Southwestern Region

OslerBrook Golf & Country Club Inc.

2634 Conc 10
Collingwood

Sector: Miscellaneous
Ministry Office: Barrie

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

CARBONACEOUS BIOCHEMICAL OXYGEN DEMAND

C of A/Permit Non-Compliance

July 1, 2006 - July 31, 2006	10	mg/L	mon avg	1 exceedance	35.33	35.33	Additional Monitoring Underway	Assessment Underway
---------------------------------	----	------	---------	--------------	-------	-------	-----------------------------------	---------------------

Total C of A/Permit Non-Compliance = 1 exceedance

NITROGEN

C of A/Permit Non-Compliance

July 1, 2006 - July 31, 2006	5	mg/L	mon avg	1 exceedance	19.57	19.57	Additional Monitoring Underway	Assessment Underway
---------------------------------	---	------	---------	--------------	-------	-------	-----------------------------------	---------------------

Total C of A/Permit Non-Compliance = 1 exceedance

PHOSPHORUS

C of A/Permit Non-Compliance

July 1, 2006 - July 31, 2006	1	mg/L	mon avg	1 exceedance	1.92	1.92	Additional Monitoring Underway	Assessment Underway
---------------------------------	---	------	---------	--------------	------	------	-----------------------------------	---------------------

Total C of A/Permit Non-Compliance = 1 exceedance

SUSPENDED SOLIDS

C of A/Permit Non-Compliance

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Municipal/Private Sewage Monthly Summary - Southwestern Region

OslerBrook Golf & Country Club Inc.

2634 Conc 10
Collingwood

Sector: Miscellaneous
Ministry Office: Barrie

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
July 1, 2006 - July 31, 2006	10	mg/L	mon avg	1 exceedance	26.67	26.67	Additional Monitoring Underway	Assessment Underway

Total C of A/Permit Non-Compliance = 1 exceedance

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Municipal/Private Sewage Monthly Summary - Southwestern Region

Petro-Canada - Innisfil

Lot 6 Conc. 1
Innisfil

Sector: Miscellaneous
Ministry Office: Barrie

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

AMMONIA

C of A/Permit Non-Compliance

July 1, 2006 - July 31, 2006	1	mg/L	mon avg	1 exceedance	1.7	1.7	Additional monitoring underway	Assessment Complete - No Action Required
---------------------------------	---	------	---------	--------------	-----	-----	-----------------------------------	---

Total C of A/Permit Non-Compliance = 1 exceedance

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Municipal/Private Sewage Monthly Summary - Southwestern Region

RioCan Holdings Inc. - Orillia Aquare Mall

1029 Brodie Drive
Orillia

Sector: Miscellaneous
Ministry Office: Barrie

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

AMMONIA

C of A/Permit Non-Compliance

March 1, 2006 - March 31, 2006	5	mg	mon avg	1 exceedance	5.1	5.1	None Required	Assessment Complete - No Action Required
May 1, 2006 - May 31, 2006	2	mg/L	mon avg	1 exceedance	6.5	6.5	None Required	Assessment Complete - No Action Required
June 1, 2006 - June 30, 2006	2	mg/L	mon avg	1 exceedance	14	14	Additional Monitoring Underway	Assessment Underway
July 1, 2006 - July 31, 2006	2	mg/L	mon avg	1 exceedance	26.5	26.5	Equipment Modified, Repaired, Replaced or Re- calibrated	Assessment Complete - No Action Required

Total C of A/Permit Non-Compliance = 4 exceedances

BIOCHEMICAL OXYGEN DEMAND

C of A/Permit Non-Compliance

July 1, 2006 - July 31, 2006	15	mg/L	mon avg	1 exceedance	17	17	Equipment Modified, Repaired, Replaced or Re- calibrated	Assessment Complete - No Action Required
---------------------------------	----	------	---------	--------------	----	----	--	---

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Municipal/Private Sewage Monthly Summary - Southwestern Region

RioCan Holdings Inc. - Orillia Aquare Mall

1029 Brodie Drive
Orillia

Sector: Miscellaneous
Ministry Office: Barrie

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
August 1, 2006 - August 31, 2006	15	mg/L	mon avg	1 exceedance	19	19	Equipment Modified, Repaired, Replaced or Re- calibrated	Assessment Complete - No Action Required

Total C of A/Permit Non-Compliance = 2 exceedances

PHOSPHORUS

C of A/Permit Non-Compliance

July 1, 2006 - July 31, 2006	0.3	mg/L	mon avg	1 exceedance	0.83	0.83	Equipment Modified, Repaired, Replaced or Re- calibrated	Assessment Complete - No Action Required
---------------------------------	-----	------	---------	--------------	------	------	--	---

Total C of A/Permit Non-Compliance = 1 exceedance

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Municipal/Private Sewage Monthly Summary - Southwestern Region

**The Corporation of the City of
Barrie - Barrie WPCP**

249 Bradford St
Barrie

Sector: Sewage Municipal
Ministry Office: Barrie

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

AMMONIA

C of A/Permit Non-Compliance

February 1, 2006 - February 28, 2006	10	mg/L	mon avg	1 exceedance	10.32	10.32	Equipment Modified, Repaired, Replaced or Re- calibrated	Assessment Complete - No Action Required
April 1, 2006 - April 30, 2006	10	mg/L	mon avg	1 exceedance	10.32	10.32	Equipment Modified, Repaired, Replaced or Re- calibrated	Assessment Complete - No Action Required
April 1, 2006 - April 30, 2006	571	kg/d	mon avg	1 exceedance	615	615	Equipment Modified, Repaired, Replaced or Re- calibrated	Assessment Complete - No Action Required

Total C of A/Permit Non-Compliance = 3 exceedances

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Municipal/Private Sewage Monthly Summary - Southwestern Region

**The Corporation of the City of
London - Greenway WPCP**

109 Greenside Ave
London

Sector: Sewage Municipal
Ministry Office: London

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
FLOW								
C of A/Permit Non-Compliance								
February 2006	37520	m3	/d	1 exceedance	37800	37800	None Required	Assessment Complete - No Action Required
February 7, 2006 - March 15, 2006	51140	m3	/d	4 exceedances	51600	57600	None Required	Assessment Complete - No Action Required

Total C of A/Permit Non-Compliance = 5 exceedances

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Municipal/Private Sewage Monthly Summary - Southwestern Region

**The Corporation of the City of
London - Oxford WPCP**

1450 Oxford St W
London

Sector: Sewage Municipal
Ministry Office: London

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
AMMONIA								
C of A/Permit Non-Compliance								
January 2006	5	mg/L	mon avg	1 exceedance	5.6	5.6	Operational Process Modification	Assessment Complete - No Action Required
June 2006	3	mg/L	mon avg	1 exceedance	3.2	3.2	Operational Process Modification	Assessment Complete - No Action Required

Total C of A/Permit Non-Compliance = 2 exceedances

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Municipal/Private Sewage Monthly Summary - Southwestern Region

**The Corporation of the City of
Sarnia - Bright's Grove**

Lots 3, 4 & 5, Front Conc
Sarnia

Sector: Sewage Municipal
Ministry Office: Sarnia

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

AMMONIA

C of A/Permit Non-Compliance

September 2006	3	mg/L	24hr	4 exceedances	3.79	28.8	Other	Other Abatement Action Taken
October 2006	3	mg/L	24hr	4 exceedances	8.4	12	Other	Assessment Complete - Incident Resolved
November 2006	3	mg/L	24hr	8 exceedances	5.53	15.8	Other	Assessment Complete - Incident Resolved

Total C of A/Permit Non-Compliance = 16 exceedances

BIOCHEMICAL OXYGEN DEMAND

C of A/Permit Non-Compliance

September 1, 2006 - September 30, 2006	10	mg/L	mon avg	1 exceedance	16.25	16.25	Other	Other Abatement Action Taken
---	----	------	---------	--------------	-------	-------	-------	------------------------------

Total C of A/Permit Non-Compliance = 1 exceedance

DISSOLVED OXYGEN

C of A/Permit Non-Compliance

October 1, 2006 - October 31, 2006	4	mg/L	mon avg	1 exceedance	2.79	2.79	Other	Other Abatement Action Taken
---------------------------------------	---	------	---------	--------------	------	------	-------	------------------------------

Total C of A/Permit Non-Compliance = 1 exceedance

PHOSPHORUS

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Municipal/Private Sewage Monthly Summary - Southwestern Region

**The Corporation of the City of
Sarnia - Bright's Grove**

Lots 3, 4 & 5, Front Conc
Sarnia

Sector: Sewage Municipal
Ministry Office: Sarnia

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
C of A/Permit Non-Compliance								
September 1, 2006 - September 30, 2006	0.5	mg/L	mon avg	1 exceedance	0.54	0.54	Other	Assessment Complete - Incident Resolved, Assessment Complete - No Action Required
October 1, 2006 - October 31, 2006	0.5	mg/L	mon avg	1 exceedance	1.22	1.22	Other	Other Abatement Action Taken

Total C of A/Permit Non-Compliance = 2 exceedances

SUSPENDED SOLIDS

C of A/Permit Non-Compliance								
October 1, 2006 - October 31, 2006	10	mg/L	mon avg	1 exceedance	16.7	16.7	Other	Other Abatement Action Taken
November 1, 2006 - November 30, 2006	10	mg/L	mon avg	1 exceedance	12.9	12.9	Other	Other Abatement Action Taken

Total C of A/Permit Non-Compliance = 2 exceedances

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Municipal/Private Sewage Monthly Summary - Southwestern Region

**The Corporation of the City of
Sarnia - Sarnia WPCP**

333 St. Andrews Street
Sarnia

Sector: Sewage Municipal
Ministry Office: Sarnia

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
AMMONIA								
C of A/Permit Non-Compliance								
January 1, 2006 - January 31, 2006	3	mg/L	mon avg	1 exceedance	9.2	9.2	Action Plan Submitted - Implementing Improvements, Equipment Modified, Repaired, Replaced or Re- calibrated, Operational Process Modification	Other Abatement Action Taken
February 1, 2006 - February 28, 2006	3	mg/L	mon avg	1 exceedance	7.52	7.52	Action Plan Submitted - Implementing Improvements, Equipment Modified, Repaired, Replaced or Re- calibrated, Operational Process Modification	Other Abatement Action Taken
March 1, 2006 - March 31, 2006	3	mg/L	mon avg	1 exceedance	15.47	15.47	Action Plan Submitted - Implementing Improvements, Equipment Modified, Repaired, Replaced or Re- calibrated, Operational Process Modification	Other Abatement Action Taken

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Municipal/Private Sewage Monthly Summary - Southwestern Region

**The Corporation of the City of
Sarnia - Sarnia WPCP**

333 St. Andrews Street
Sarnia

Sector: Sewage Municipal
Ministry Office: Sarnia

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
April 1, 2006 - April 30, 2006	3	mg/L	mon avg	1 exceedance	11.45	11.45	Action Plan Submitted - Implementing Improvements, Equipment Modified, Repaired, Replaced or Re- calibrated, Operational Process Modification	Other Abatement Action Taken
May 1, 2006 - May 31, 2006	1.5	mg/L	mon avg	1 exceedance	14.7	14.7	Action Plan Submitted - Implementing Improvements, Equipment Modified, Repaired, Replaced or Re- calibrated, Operational Process Modification	Other Abatement Action Taken
June 1, 2006 - June 30, 2006	1.5	mg/L	mon avg	1 exceedance	9.57	9.57	Action Plan Submitted - Implementing Improvements, Equipment Modified, Repaired, Replaced or Re- calibrated, Operational Process Modification	Other Abatement Action Taken
July 1, 2006 - July 31, 2006	1.5	mg/L	mon avg	1 exceedance	5.3	5.3	Action Plan Submitted - Implementing Improvements, Equipment Modified, Repaired, Replaced or Re- calibrated, Operational Process Modification	Other Abatement Action Taken

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Municipal/Private Sewage Monthly Summary - Southwestern Region

**The Corporation of the City of
Sarnia - Sarnia WPCP**

333 St. Andrews Street
Sarnia

Sector: Sewage Municipal
Ministry Office: Sarnia

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
August 1, 2006 - August 31, 2006	1.5	mg/L	mon avg	1 exceedance	3.28	3.28	Action Plan Submitted - Implementing Improvements, Equipment Modified, Repaired, Replaced or Re- calibrated, Operational Process Modification	Other Abatement Action Taken
September 1, 2006 - September 30, 2006	1.5	mg/L	mon avg	1 exceedance	3.26	3.26	Action Plan Submitted - Implementing Improvements, Equipment Modified, Repaired, Replaced or Re- calibrated, Operational Process Modification	Other Abatement Action Taken
October 1, 2006 - October 31, 2006	1.5	mg/L	mon avg	1 exceedance	4.62	4.62	Action Plan Submitted - Implementing Improvements, Equipment Modified, Repaired, Replaced or Re- calibrated, Operational Process Modification	Other Abatement Action Taken
November 1, 2006 - November 30, 2006	3	mg/L	mon avg	1 exceedance	4.61	4.61	Action Plan Submitted - Implementing Improvements, Equipment Modified, Repaired, Replaced or Re- calibrated, Operational Process Modification	Other Abatement Action Taken

Total C of A/Permit Non-Compliance = 11 exceedances

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Municipal/Private Sewage Monthly Summary - Southwestern Region

**The Corporation of the City of
Sarnia - Sarnia WPCP**

333 St. Andrews Street
Sarnia

Sector: Sewage Municipal
Ministry Office: Sarnia

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
ESCHERICHIA COLI								
C of A/Permit Non-Compliance								
July 1, 2006 - July 31, 2006	200	cfu/100 ml (memb rane filtratio n)	mon avg. on a geo. mean density	1 exceedance	2077.91	2077.91	Action Plan Submitted - Implementing Improvements, Equipment Modified, Repaired, Replaced or Re- calibrated, Operational Process Modification	Other Abatement Action Taken
August 2, 2006 - August 31, 2006	200	cfu/100 ml (memb rane filtratio n)	mon avg. on a geo. mean density	1 exceedance	224.03	224.03	Action Plan Submitted - Implementing Improvements, Equipment Modified, Repaired, Replaced or Re- calibrated, Operational Process Modification	Other Abatement Action Taken
October 1, 2006 - October 31, 2006	200	cfu/100 ml (memb rane filtratio n)	mon avg. on a geo. mean density	1 exceedance	325.82	325.82	Action Plan Submitted - Implementing Improvements, Equipment Modified, Repaired, Replaced or Re- calibrated, Operational Process Modification	Other Abatement Action Taken

Total C of A/Permit Non-Compliance = 3 exceedances

SUSPENDED SOLIDS

C of A/Permit Non-Compliance

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Municipal/Private Sewage Monthly Summary - Southwestern Region

**The Corporation of the City of
Sarnia - Sarnia WPCP**

333 St. Andrews Street
Sarnia

Sector: Sewage Municipal
Ministry Office: Sarnia

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
October 1, 2006 - October 31, 2006	15	mg/L	mon avg	1 exceedance	34.2	34.2	Action Plan Submitted - Implementing Improvements, Equipment Modified, Repaired, Replaced or Re- calibrated, Operational Process Modification	Other Abatement Action Taken
November 1, 2006 - November 30, 2006	15	mg/L	mon avg	1 exceedance	16.3	16.3	Action Plan Submitted - Implementing Improvements, Equipment Modified, Repaired, Replaced or Re- calibrated, Operational Process Modification	Other Abatement Action Taken

Total C of A/Permit Non-Compliance = 2 exceedances

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Municipal/Private Sewage Monthly Summary - Southwestern Region

The Corporation of the County of Oxford - Norwich STP

Conc 5 Lot 7 Norwich
Norwich

Sector: Sewage Municipal
Ministry Office: London

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

AMMONIA

C of A/Permit Non-Compliance

January 1, 2006 - January 31, 2006	5	mg/L	mon avg	1 exceedance	5.13	5.13	None Required	Assessment Complete - No Action Required
---------------------------------------	---	------	---------	--------------	------	------	---------------	---

Total C of A/Permit Non-Compliance = 1 exceedance

ESCHERICHIA COLI

C of A/Permit Non-Compliance

September 1, 2006 - September 30, 2006	200	cfu/1 ml (HPC)	mon avg	2 exceedances	3037	6293	None Required	Assessment Complete - No Action Required
---	-----	----------------------	---------	---------------	------	------	---------------	---

Total C of A/Permit Non-Compliance = 2 exceedances

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Municipal/Private Sewage Monthly Summary - Southwestern Region

The Corporation of the County of Oxford - Thamesford STP

10 Middleton St Thamesford
Zorra

Sector: Sewage Municipal
Ministry Office: London

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

PHOSPHORUS

C of A/Permit Non-Compliance

April 1, 2006 - July 30, 2006	0.5	mg/L	mon avg	3 exceedances	0.55	0.74	Equipment Modified, Repaired, Replaced or Re- calibrated	Assessment Complete - No Action Required
----------------------------------	-----	------	---------	---------------	------	------	--	---

Total C of A/Permit Non-Compliance = 3 exceedances

SUSPENDED SOLIDS

C of A/Permit Non-Compliance

May 1, 2006 - May 31, 2006	10	mg/L	mon avg	1 exceedance	14	14	Equipment Modified, Repaired, Replaced or Re- calibrated	Assessment Complete - No Action Required
-------------------------------	----	------	---------	--------------	----	----	--	---

Total C of A/Permit Non-Compliance = 1 exceedance

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Municipal/Private Sewage Monthly Summary - Southwestern Region

The Corporation of the Municipality of Arran-Elderslie - Paisley STP

Goldie Street
Arran-Elderslie

Sector: Sewage Municipal
Ministry Office: Owen Sound

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

ESCHERICHIA COLI

C of A/Permit Non-Compliance

May 1, 2006 - May 31, 2006	200	cfu/100 ml (membrane filtration)	mon avg. on a geo. mean density	1 exceedance	764	764	Operational process modification	Assessment complete - no action required
September 1, 2006 - September 30, 2006	200	cfu/100 ml (membrane filtration)	mon avg. on a geo. mean density	1 exceedance	394	394	Operational process modification	Assessment complete - no action required

Total C of A/Permit Non-Compliance = 2 exceedances

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Municipal/Private Sewage Monthly Summary - Southwestern Region

The Corporation of the Municipality of Bluewater - Bayfield STP

Lot 7, Bayfield Conc Road
Bluewater

Sector: Sewage Municipal
Ministry Office: Sarnia

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

ESCHERICHIA COLI

C of A/Permit Non-Compliance

October 31, 2006 - November 30, 2006	200	cfu/100 ml (membrane filtration)	mon avg	2 exceedances	210	1105	Operational Process Modification	Assessment Underway
---	-----	--	---------	---------------	-----	------	-------------------------------------	---------------------

Total C of A/Permit Non-Compliance = 2 exceedances

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Municipal/Private Sewage Monthly Summary - Southwestern Region

The Corporation of the Municipality of Bluewater - Zurich Lagoon

Lot 19, Conc. 10
Bluewater

Sector: Sewage Municipal
Ministry Office: Sarnia

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

SUSPENDED SOLIDS

Policy/Guideline Non-Conformance

January 1, 2006 - December 31, 2006	25	mg/L	annual avg	1 exceedance	25.9	25.9	Equipment Modified, Repaired, Replaced or Re- calibrated	Assessment Complete - Incident Resolved
--	----	------	------------	--------------	------	------	--	--

Total Policy/Guideline Non-Conformance = 1 exceedance

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Municipal/Private Sewage Monthly Summary - Southwestern Region

**The Corporation of the
Municipality of Central Huron -
Clinton STP**

32 Walker Street
Central Huron

Sector: Sewage Municipal
Ministry Office: Sarnia

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

PHOSPHORUS

C of A/Permit Non-Compliance

May 1, 2006 - May 31, 2006	0.4	mg/L	/mon	1 exceedance	0.41	0.41	Equipment Modified, Repaired, Replaced or Re- calibrated	Assessment Complete - No Action Required
-------------------------------	-----	------	------	--------------	------	------	--	---

Total C of A/Permit Non-Compliance = 1 exceedance

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Municipal/Private Sewage Monthly Summary - Southwestern Region

The Corporation of the Municipality of Chatham-Kent - Clearville Park STP

18498 Clearville Road
Chatham-Kent

Sector: Sewage Municipal
Ministry Office: Windsor

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

AMMONIA

C of A/Permit Non-Compliance

June 1, 2006 - June 30, 2006	5	mg/L	mon avg	1 exceedance	8.79	8.79	Conducting Study	Voluntary Abatement Program Underway
July 1, 2006 - July 31, 2006	5	mg/L	mon avg	1 exceedance	15.8	15.8	Operational Process Modification	Assessment underway, Voluntary Abatement Program Underway

Total C of A/Permit Non-Compliance = 2 exceedances

PHOSPHORUS

C of A/Permit Non-Compliance

June 1, 2006 - June 30, 2006	0.7	mg/L	mon avg	1 exceedance	1.24	1.24	Conducting Study	Voluntary Abatement Program Underway
---------------------------------	-----	------	---------	--------------	------	------	------------------	---

Total C of A/Permit Non-Compliance = 1 exceedance

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Municipal/Private Sewage Monthly Summary - Southwestern Region

The Corporation of the Municipality of Chatham-Kent - Ridgetown STP

Lot 9, Conc 8 & 9, Chatham-Kent
Chatham-Kent

Sector: Sewage Municipal
Ministry Office: Windsor

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

ESCHERICHIA COLI

C of A/Permit Non-Compliance

August 1, 2006 - August 16, 2006	200	CT/100 mL	mon avg	2 exceedances	449	697	Conducting Study	Voluntary Abatement Program Underway
-------------------------------------	-----	--------------	---------	---------------	-----	-----	------------------	---

Total C of A/Permit Non-Compliance = 2 exceedances

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Municipal/Private Sewage Monthly Summary - Southwestern Region

**The Corporation of the
Municipality of Chatham-Kent -
Tilbury WPCP**

Lot 20 & 21, Conc 3
Lakeshore

Sector: Sewage Municipal
Ministry Office: Windsor

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

PHOSPHORUS

C of A/Permit Non-Compliance

December 1, 2006 - December 31, 2006	0.5	ng/L	mon avg	1 exceedance	0.59	0.59	None Required	Assessment Complete - No Action Required
---	-----	------	---------	--------------	------	------	---------------	---

Total C of A/Permit Non-Compliance = 1 exceedance

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Municipal/Private Sewage Monthly Summary - Southwestern Region

The Corporation of the Municipality of Dutton/Dunwich - Dutton/Dunwich WPCP

Conc A Lot 10 Dutton/Dunwich
Dutton/Dunwich

Sector: Sewage Municipal
Ministry Office: London

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

PHOSPHORUS

C of A/Permit Non-Compliance

November 2006	0.5	mg/L	mon avg	1 exceedance	0.59	0.59	Equipment Modified, Repaired, Replaced or Re-calibrated	Assessment Complete - Incident Resolved
---------------	-----	------	---------	--------------	------	------	---	---

Total C of A/Permit Non-Compliance = 1 exceedance

SUSPENDED SOLIDS

C of A/Permit Non-Compliance

November 1, 2006 - November 30, 2006	10	mg/L	mon avg	1 exceedance	11	11	Equipment Modified, Repaired, Replaced or Re-calibrated	Assessment Complete - No Action Required
--------------------------------------	----	------	---------	--------------	----	----	---	--

Total C of A/Permit Non-Compliance = 1 exceedance

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Municipal/Private Sewage Monthly Summary - Southwestern Region

**The Corporation of the
Municipality of Kincardine -
Kincardine STP**

520 Bruce Ave
Kincardine

Sector: Sewage Municipal
Ministry Office: Owen Sound

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

ESCHERICHIA COLI

C of A/Permit Non-Compliance

October 1, 2006 - October 31, 2006	200	cfu/100 ml (membrane filtration)	/mon	1 exceedance	295	295	New Equipment or Treatment Process Installed, None Required	Assessment Complete - Incident Resolved
---------------------------------------	-----	---	------	--------------	-----	-----	---	--

Total C of A/Permit Non-Compliance = 1 exceedance

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Municipal/Private Sewage Monthly Summary - Southwestern Region

The Corporation of the Municipality of Meaford - Meaford WPCP

35 Grant Avenue
Meaford

Sector: Sewage Municipal
Ministry Office: Owen Sound

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

AMMONIA NITRATE

C of A/Permit Non-Compliance

February 1, 2006 - February 28, 2006	5	mg/L	/mon	1 exceedance	6.13	6.13	Conducting Study	Assessment Complete - No Action Required
---	---	------	------	--------------	------	------	------------------	---

Total C of A/Permit Non-Compliance = 1 exceedance

ESCHERICHIA COLI

C of A/Permit Non-Compliance

January 1, 2006 - January 31, 2006	200	CT/100 mL	/mon	2 exceedances	1518	2164	Conducting Study	Assessment Complete - No Action Required
February 1, 2006 - February 28, 2006	200	CT/100 mL	/mon	1 exceedance	2005	200	Conducting Study	Assessment Complete - No Action Required
August 1, 2006 - August 31, 2006	200	CT/100 mL	/mon	1 exceedance	232	200	Conducting Study	Assessment Complete - Incident Resolved

Total C of A/Permit Non-Compliance = 4 exceedances

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Municipal/Private Sewage Monthly Summary - Southwestern Region

The Corporation of the Municipality of Southwest Middlesex - Wardsville WPCP

Conc Range 1 Part Lot 17
Southwest Middlesex

Sector: Sewage Municipal
Ministry Office: London

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

AMMONIA

C of A/Permit Non-Compliance

January 1, 2006 - December 31, 2006	3	mg/L	/d	2 exceedances	6.03	6.03	Additional Monitoring Underway	Assessment Underway, Other Abatement Action Taken
January 1, 2006 - December 31, 2006	4.5	mg/L	/d	7 exceedances	4.51	19.4	Additional Monitoring Underway	Assessment Underway, Other Abatement Action Taken
January 1, 2006 - December 31, 2006	7.5	mg/L	/d	7 exceedances	8.4	12.6	Additional Monitoring Underway	Assessment Underway, Other Abatement Action Taken
January 1, 2006 - December 31, 2006	5	mg/L	mon avg	2 exceedances	10.75	10.75	Equipment Modified, Repaired, Replaced or Re- calibrated	Other Abatement Action Taken

Total C of A/Permit Non-Compliance = 18 exceedances

DISSOLVED OXYGEN

C of A/Permit Non-Compliance

January 1, 2006 - December 31, 2006	4	mg/L	/d	7 exceedances	3.99	1.67	Additional Monitoring Underway	Assessment Underway, Other Abatement Action Taken
--	---	------	----	---------------	------	------	-----------------------------------	--

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Municipal/Private Sewage Monthly Summary - Southwestern Region

The Corporation of the Municipality of Southwest Middlesex - Wardsville WPCP

Conc Range 1 Part Lot 17
Southwest Middlesex

Sector: Sewage Municipal
Ministry Office: London

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
January 1, 2006 - December 31, 2006	5	mg/L	mon avg	1 exceedance	4.61	4.61	Additional Monitoring Underway	Assessment Underway, Other Abatement Action Taken

Total C of A/Permit Non-Compliance = 8 exceedances

ESCHERICHIA COLI

C of A/Permit Non-Compliance

January 1, 2006 - December 31, 2006	200	cfu/100 ml (memb rane filtratio n)	mon avg	1 exceedance	3545	3545	Operational Process Modification	Assessment Underway
January 1, 2006 - December 31, 2006	1000	cfu/100 /d ml (memb rane filtratio n)		8 exceedances	1020	10800	Operational Process Modification	Assessment Underway

Total C of A/Permit Non-Compliance = 9 exceedances

PHOSPHORUS

C of A/Permit Non-Compliance

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Municipal/Private Sewage Monthly Summary - Southwestern Region

The Corporation of the Municipality of Southwest Middlesex - Wardsville WPCP

Conc Range 1 Part Lot 17
Southwest Middlesex

Sector: Sewage Municipal
Ministry Office: London

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
July 1, 2006 - December 31, 2006	0.5	mg/L	mon avg	2 exceedances	0.81	0.81	Equipment Modified, Repaired, Replaced or Re- calibrated	Other Abatement Action Taken
January 1, 2006 - December 31, 2006	1	mg/L	/d	3 exceedances	1.02	1.77	Equipment Modified, Repaired, Replaced or Re- calibrated	Other Abatement Action Taken

Total C of A/Permit Non-Compliance = 5 exceedances

SUSPENDED SOLIDS

C of A/Permit Non-Compliance

January 1, 2006 - August 31, 2006	10	mg/L	mon avg	1 exceedance	28.6	28.6	Equipment Modified, Repaired, Replaced or Re- calibrated	Other Abatement Action Taken
January 1, 2006 - December 31, 2006	15	mg/L	/d	5 exceedances	16	69	Equipment Modified, Repaired, Replaced or Re- calibrated	Other Abatement Action Taken

Total C of A/Permit Non-Compliance = 6 exceedances

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Municipal/Private Sewage Monthly Summary - Southwestern Region

The Corporation of the Town of Essex - Colchester South Lagoon

125 Cornwall Road
Essex

Sector: Sewage Municipal
Ministry Office: Windsor

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

BIOCHEMICAL OXYGEN DEMAND

C of A/Permit Non-Compliance

May 1, 2006 - May 31, 2006	25	mg/L	mon avg	1 exceedance	29.6	29.6	Equipment Modified, Repaired, Replaced or Re- calibrated	Assessment Complete - Incident Resolved
-------------------------------	----	------	---------	--------------	------	------	--	--

Total C of A/Permit Non-Compliance = 1 exceedance

SUSPENDED SOLIDS

C of A/Permit Non-Compliance

May 1, 2006 - May 31, 2006	30	mg/L	mon avg	1 exceedance	49.6	49.6	Equipment Modified, Repaired, Replaced or Re- calibrated	Assessment Complete - Incident Resolved
June 1, 2006 - June 30, 2006	30	mg/L	mon avg	1 exceedance	31.25	31.25	Equipment Modified, Repaired, Replaced or Re- calibrated, Operational Process Modification	Assessment Complete - Incident Resolved
September 1, 2006 - September 30, 2006	30	mg/L	mon avg	1 exceedance	43	43	Additional Monitoring Underway, Operational Process Modification	Assessment Complete - No Action Required

Total C of A/Permit Non-Compliance = 3 exceedances

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Municipal/Private Sewage Monthly Summary - Southwestern Region

The Corporation of the Town of Essex - Essex North East Waste Stabilization Ponds

401 County Road 8 (Victoria Street)
Essex

Sector: Sewage Municipal
Ministry Office: Windsor

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

PHOSPHORUS

C of A/Permit Non-Compliance

February 13, 2006 - February 20, 2006	13.4	kg/d	/wk	1 exceedance	13.6	13.6	None Required	Other Abatement Action taken
--	------	------	-----	--------------	------	------	---------------	------------------------------

Total C of A/Permit Non-Compliance = 1 exceedance

SUSPENDED SOLIDS

C of A/Permit Non-Compliance

February 13, 2006 - February 20, 2006	401	kg/d	/wk	1 exceedance	483.6	483.6	None Required	Other Abatement Action taken
--	-----	------	-----	--------------	-------	-------	---------------	------------------------------

Total C of A/Permit Non-Compliance = 1 exceedance

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Municipal/Private Sewage Monthly Summary - Southwestern Region

**The Corporation of the Town of
Essex - Harrow Lagoon**

2215 Rosebough Road
Essex

Sector: Sewage Municipal
Ministry Office: Windsor

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

SUSPENDED SOLIDS

C of A/Permit Non-Compliance

May 1, 2006 - May 31, 2006	10	mg/L	mon avg	1 exceedance	17.6	17.6	Operational Process Modification	Assessment Complete - No Action Required
-------------------------------	----	------	---------	--------------	------	------	-------------------------------------	---

Total C of A/Permit Non-Compliance = 1 exceedance

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Municipal/Private Sewage Monthly Summary - Southwestern Region

**The Corporation of the Town of
Hanover - Hanover WPCP**

718 7th Avenue
Hanover

Sector: Sewage Municipal
Ministry Office: Owen Sound

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

ESCHERICHIA COLI

C of A/Permit Non-Compliance

August 2006	200	cfu/100 ml (membrane filtration)	any	1 exceedance	800	800	Other	Assessment Complete - Incident Resolved
-------------	-----	--	-----	--------------	-----	-----	-------	--

Total C of A/Permit Non-Compliance = 1 exceedance

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Municipal/Private Sewage Monthly Summary - Southwestern Region

**The Corporation of the Town of
Innisfil - Lakeshore WPCP**

2155 25th Sideroad Lots 26 & 27, Conc 8
Innisfil

Sector: Sewage Municipal
Ministry Office: Barrie

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

AMMONIA

C of A/Permit Non-Compliance

May 1, 2006 - May 31, 2006	5	mg/L	mon avg	2 exceedances	6.3	8.6	Other	Assessment Complete - No Action Required
-------------------------------	---	------	---------	---------------	-----	-----	-------	---

Total C of A/Permit Non-Compliance = 2 exceedances

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Municipal/Private Sewage Monthly Summary - Southwestern Region

**The Corporation of the Town of
Lakeshore - Belle River -
Maidstone WPCP**

276 Rourke Line Road, Belle River
Lakeshore

Sector: Sewage Municipal
Ministry Office: Windsor

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

BIOCHEMICAL OXYGEN DEMAND

C of A/Permit Non-Compliance

January 1, 2006 - January 31, 2006	15	mg/L	mon avg	1 exceedance	15.4	15.4	None Required	Voluntary Abatement Program Underway
---------------------------------------	----	------	---------	--------------	------	------	---------------	---

Total C of A/Permit Non-Compliance = 1 exceedance

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Municipal/Private Sewage Monthly Summary - Southwestern Region

**The Corporation of the Town of
Lakeshore - South Woodslee
WPCP**

Hamlet of S. Woodslee, 1711 King St
Lakeshore

Sector: Sewage Municipal
Ministry Office: Windsor

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

PHOSPHORUS

C of A/Permit Non-Compliance

January 1, 2006 - January 31, 2006	0.3	mg/L	mon avg	1 exceedance	0.39	0.39	Action Plan Submitted - Implementing Improvements	Voluntary Abatement Program Underway
---------------------------------------	-----	------	---------	--------------	------	------	--	---

Total C of A/Permit Non-Compliance = 1 exceedance

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Municipal/Private Sewage Monthly Summary - Southwestern Region

**The Corporation of the Town of
Leamington - Leamington
Pollution Control Centre**

435 Seacliff Drive East
Leamington

Sector: Sewage Municipal
Ministry Office: Windsor

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

PHOSPHORUS

C of A/Permit Non-Compliance

July 1, 2006 - July 31, 2006	1	mg/L	mon avg	1 exceedance	1.4	1.4	Operational Process Modification	Assessment Complete - Incident Resolved
---------------------------------	---	------	---------	--------------	-----	-----	-------------------------------------	--

Total C of A/Permit Non-Compliance = 1 exceedance

SUSPENDED SOLIDS

C of A/Permit Non-Compliance

November 1, 2006 - November 30, 2006	15	mg/L	mon avg	1 exceedance	18.9	18.9	Other	Assessment Underway
---	----	------	---------	--------------	------	------	-------	---------------------

Total C of A/Permit Non-Compliance = 1 exceedance

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Municipal/Private Sewage Monthly Summary - Southwestern Region

The Corporation of the Town of New Tecumseth - New Tecumseth Regional WPCP

Lot 2 Conc. 13
New Tecumseth

Sector: Sewage Municipal
Ministry Office: Barrie

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

AMMONIA

C of A/Permit Non-Compliance

June 1, 2006 - June 30, 2006	0.5	mg/L	mon avg	1 exceedance	2.3	2.3	Action Plan Submitted - Implementing Improvements, Operational Process Modification	Assessment Complete - No Action Required
July 1, 2006 - July 31, 2006	0.5	mg/L	mon avg	1 exceedance	2.5	2.5	Action Plan Submitted - Implementing Improvements	Director's Order Issued
December 1, 2006 - December 31, 2006	2.5	kg/d	annual avg	1 exceedance	4.7	4.7	Action Plan Submitted - Implementing Improvements	Director's Order Issued

Total C of A/Permit Non-Compliance = 3 exceedances

BIOCHEMICAL OXYGEN DEMAND

C of A/Permit Non-Compliance

July 1, 2006 - July 31, 2006	15	mg/L	mon avg	1 exceedance	28	28	Action Plan Submitted - Implementing Improvements	Director's Order Issued
---------------------------------	----	------	---------	--------------	----	----	--	-------------------------

Total C of A/Permit Non-Compliance = 1 exceedance

ESCHERICHIA COLI

C of A/Permit Non-Compliance

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Municipal/Private Sewage Monthly Summary - Southwestern Region

The Corporation of the Town of New Tecumseth - New Tecumseth Regional WPCP

Lot 2 Conc. 13
New Tecumseth

Sector: Sewage Municipal
Ministry Office: Barrie

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
January 1, 2006 - February 28, 2006	200	CT/100 mL	mon avg. on a geo. mean density	2 exceedances	423	486	Action Plan Submitted - Implementing Improvements	Director's Order Issued
June 1, 2006 - June 30, 2006	200	CT/100 mL	mon avg. on a geo. mean density	1 exceedance	934	934	Action Plan Submitted - Implementing Improvements, Operational Process Modification	Assessment Complete - No Action Required
July 1, 2006 - July 31, 2006	200	CT/100 mL	mon avg. on a geo. mean density	1 exceedance	289	289	Action Plan Submitted - Implementing Improvements	Director's Order Issued

Total C of A/Permit Non-Compliance = 4 exceedances

PHOSPHORUS

C of A/Permit Non-Compliance

December 1, 2006 - December 31, 2006	0.15	mg/L	mon avg	1 exceedance	0.2	0.2	Action Plan Submitted - Implementing Improvements	Director's Order Issued
January 1, 2006 - December 31, 2006	0.8	kg/d	annual avg	1 exceedance	0.9	0.9	Action Plan Submitted - Implementing Improvements	Director's Order Issued

Total C of A/Permit Non-Compliance = 2 exceedances

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Municipal/Private Sewage Monthly Summary - Southwestern Region

**The Corporation of the Town of
New Tecumseth - Tottenham
WPCP**

6830 4th Line
New Tecumseth

Sector: Sewage Municipal
Ministry Office: Barrie

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

AMMONIA

C of A/Permit Non-Compliance

September 1, 2006 - September 30, 2006	0.5	mg/L	mon avg	2 exceedances	0.8	0.9	Operational Process Modification	Assessment Complete - No Action Required
---	-----	------	---------	---------------	-----	-----	-------------------------------------	---

Total C of A/Permit Non-Compliance = 2 exceedances

PHOSPHORUS

C of A/Permit Non-Compliance

September 1, 2006 - September 30, 2006	0.1	mg/L	mon avg	1 exceedance	0.12	0.12	Operational Process Modification	Assessment Complete - No Action Required
---	-----	------	---------	--------------	------	------	-------------------------------------	---

Total C of A/Permit Non-Compliance = 1 exceedance

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Municipal/Private Sewage Monthly Summary - Southwestern Region

The Corporation of the Town of Penetanguishene - Penetanguishene STP

24 Main St
Penetanguishene

Sector: Sewage Municipal
Ministry Office: Barrie

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

PHOSPHORUS

C of A/Permit Non-Compliance

March 1, 2006 - March 31, 2006	0.2	mg/L	mon avg	1 exceedance	0.26	0.26	Operational Process Modification	Assessment Complete - No Action Required
August 1, 2006 - August 31, 2006	0.15	mg/L	mon avg	1 exceedance	0.27	0.27	Operational Process Modification	Assessment Complete - No Action Required

Total C of A/Permit Non-Compliance = 2 exceedances

SUSPENDED SOLIDS

C of A/Permit Non-Compliance

March 1, 2006 - March 31, 2006	15	mg/L	mon avg	1 exceedance	18.3	18.3	Operational Process Modification	Assessment Complete - No Action Required
-----------------------------------	----	------	---------	--------------	------	------	-------------------------------------	---

Total C of A/Permit Non-Compliance = 1 exceedance

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Municipal/Private Sewage Monthly Summary - Southwestern Region

The Corporation of the Township of Clearview - Creemore WPCP

81- 83 Mary Street, Creemore
Clearview

Sector: Sewage Municipal
Ministry Office: Barrie

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

PHOSPHORUS

C of A/Permit Non-Compliance

February 1, 2006 - February 28, 2006	0.2	mg/L	mon avg	1 exceedance	1.97	1.97	Other	Assessment Complete - No Action Required
February 1, 2006 - February 28, 2006	0.28	kg/d	mon avg	1 exceedance	0.91	0.91	Other	Assessment Complete - No Action Required

Total C of A/Permit Non-Compliance = 2 exceedances

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Municipal/Private Sewage Monthly Summary - Southwestern Region

The Corporation of the Township of Essa - Angus STP

143 Centre Street
Essa

Sector: Sewage Municipal
Ministry Office: Barrie

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

ESCHERICHIA COLI

C of A/Permit Non-Compliance

January 1, 2006 - February 28, 2006	200	CT/100 mL	mon avg. on a geo. mean density (monthly average - over 2 months)	2 exceedances	291	317	New Equipment or Treatment Process Installed	Assessment Complete - No Action Required
--	-----	--------------	--	---------------	-----	-----	---	---

Total C of A/Permit Non-Compliance = 2 exceedances

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Municipal/Private Sewage Monthly Summary - Southwestern Region

The Corporation of the Township of Middlesex Centre - Iderton WPCP

22534 Hyde Park Road
Middlesex Centre

Sector: Sewage Municipal
Ministry Office: London

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

AMMONIA

C of A/Permit Non-Compliance

January 1, 2006 - December 31, 2006	2	mg/L	mon avg	1 exceedance	4.33	4.33	Conducting Study	Assessment Underway, Provincial Officer's Order Issued
--	---	------	---------	--------------	------	------	------------------	--

Total C of A/Permit Non-Compliance = 1 exceedance

BIOCHEMICAL OXYGEN DEMAND

C of A/Permit Non-Compliance

January 1, 2006 - December 31, 2006	10	mg/L	mon avg	1 exceedance	23.5	23.5	Conducting Study	Assessment Underway, Provincial Officer's Order Issued
--	----	------	---------	--------------	------	------	------------------	--

Total C of A/Permit Non-Compliance = 1 exceedance

FLOW

C of A/Permit Non-Compliance

January 1, 2006 - December 31, 2006	640	m3	annual avg	1 exceedance	679	679	Conducting Study	Assessment Underway, Provincial Officer's Order Issued
--	-----	----	------------	--------------	-----	-----	------------------	--

Total C of A/Permit Non-Compliance = 1 exceedance

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Municipal/Private Sewage Monthly Summary - Southwestern Region

The Corporation of the Township of Middlesex Centre - Iderton WPCP

22534 Hyde Park Road
Middlesex Centre

Sector: Sewage Municipal
Ministry Office: London

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

PHOSPHORUS

C of A/Permit Non-Compliance

April 1, 2006 - December 31, 2006	0.3	mg/L	mon avg	7 exceedances	0.34	2.45	Operational Process Modification	Voluntary Abatement Program Underway
April 1, 2006 - December 31, 2006	0.5	mg/L	mon avg	1 exceedance	0.54	0.54	Operational Process Modification	Voluntary Abatement Program Underway
January 1, 2006 - December 31, 2006	0.75	mg/L	mon avg	1 exceedance	0.93	0.93	Conducting Study	Assessment Underway, Provincial Officer's Order Issued

Total C of A/Permit Non-Compliance = 9 exceedances

SUSPENDED SOLIDS

C of A/Permit Non-Compliance

September 1, 2006 - September 30, 2006	10	mg/L	mon avg	1 exceedance	10.5	10.5	Operational Process Modification	Voluntary Abatement Program Underway
January 1, 2006 - December 31, 2006	10	mg/L	mon avg	3 exceedances	14.5	50.5	Conducting Study	Assessment Underway, Provincial Officer's Order Issued

Total C of A/Permit Non-Compliance = 4 exceedances

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Municipal/Private Sewage Monthly Summary - Southwestern Region

The Corporation of the Township of North Huron - Blyth WPCP

Lot 42, Conc.1
North Huron

Sector: Sewage Municipal
Ministry Office: Sarnia

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

CHLORINE RESIDUAL

C of A/Permit Non-Compliance

May 12, 2006 - October 1, 2006	0.2	mg/L	/d	6 exceedances	0.21	0.33	Operational Process Modification	Voluntary Abatement Program Underway
-----------------------------------	-----	------	----	---------------	------	------	-------------------------------------	---

Total C of A/Permit Non-Compliance = 6 exceedances

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Municipal/Private Sewage Monthly Summary - Southwestern Region

The Corporation of the Township of Southgate - Dundalk STP

Part Lots 238 & 239 Conc 2, Proton Southgate

Sector: Sewage Municipal
Ministry Office: Owen Sound

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

BIOCHEMICAL OXYGEN DEMAND

C of A/Permit Non-Compliance

February 1, 2006 - February 28, 2006	10	mg/L	mon avg	1 exceedance	10.5	10.5	Ceased Operations, Equipment Modified, Repaired, Replaced or Re-calibrated, Operational Process Modification	Assessment Complete - Incident Resolved
April 1, 2006 - April 30, 2006	10	mg/L	mon avg	1 exceedance	16	16	Ceased Operations, Equipment Modified, Repaired, Replaced or Re-calibrated, Operational Process Modification	Assessment Complete - Incident Resolved

Total C of A/Permit Non-Compliance = 2 exceedances

PHOSPHORUS

C of A/Permit Non-Compliance

January 1, 2006 - January 31, 2006	1.47	kg/d	mon avg	1 exceedance	5.1	5.1	Training/Procedure Change	Assessment Complete - Incident Resolved
------------------------------------	------	------	---------	--------------	-----	-----	---------------------------	---

Total C of A/Permit Non-Compliance = 1 exceedance

SUSPENDED SOLIDS

C of A/Permit Non-Compliance

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Municipal/Private Sewage Monthly Summary - Southwestern Region

The Corporation of the Township of Southgate - Dundalk STP

Part Lots 238 & 239 Conc 2, Proton Southgate

Sector: Sewage Municipal
Ministry Office: Owen Sound

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
February 1, 2006 - February 28, 2006	10	mg/L	mon avg	1 exceedance	12.5	12.5	Ceased Operations, Equipment Modified, Repaired, Replaced or Re-calibrated, Operational Process Modification	Assessment Complete - Incident Resolved
April 1, 2006 - April 30, 2006	10	mg/L	mon avg	1 exceedance	13	1	Ceased Operations, Equipment Modified, Repaired, Replaced or Re-calibrated, Operational Process Modification	Assessment Complete - Incident Resolved

Total C of A/Permit Non-Compliance = 2 exceedances

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Municipal/Private Sewage Monthly Summary - Southwestern Region

The Corporation of the Township of Springwater - Elmvale STP

Lot 4 Conc 10
Springwater

Sector: Sewage Municipal
Ministry Office: Barrie

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

PHOSPHORUS

C of A/Permit Non-Compliance

July 1, 2006 - July 31, 2006	0.17	mg/L	mon avg	1 exceedance	0.2	0.2	New/Modified Sampling Program Underway	Assessment Complete - No Action Required
---------------------------------	------	------	---------	--------------	-----	-----	--	--

Total C of A/Permit Non-Compliance = 1 exceedance

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Municipal/Private Sewage Monthly Summary - Southwestern Region

**The Corporation of the Township
of Tay - Port McNicoll WPCP**

551 First St
Tay

Sector: Sewage Municipal
Ministry Office: Barrie

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

PHOSPHORUS

C of A/Permit Non-Compliance

August 1, 2006 - September 30, 2006	0.25	mg/L	mon avg	2 exceedances	0.29	0.32	Operational Process Modification	Assessment Complete - No Action Required
--	------	------	---------	---------------	------	------	-------------------------------------	---

Total C of A/Permit Non-Compliance = 2 exceedances

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Municipal/Private Sewage Monthly Summary - Southwestern Region

The Corporation of the Village of Newbury - Newbury WPCP

Conc 2 Lot 18
Newbury

Sector: Sewage Municipal
Ministry Office: London

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

BIOCHEMICAL OXYGEN DEMAND

C of A/Permit Non-Compliance

August 1, 2006 - August 31, 2006	10	mg/L	mon avg	1 exceedance	10.2	10.2	None Required	Assessment Complete - Incident Resolved
-------------------------------------	----	------	---------	--------------	------	------	---------------	--

Total C of A/Permit Non-Compliance = 1 exceedance

SUSPENDED SOLIDS

C of A/Permit Non-Compliance

September 1, 2006 - September 30, 2006	10	mg/L	mon avg	1 exceedance	16.5	16.5	None Required	Assessment Complete - Incident Resolved
---	----	------	---------	--------------	------	------	---------------	--

Total C of A/Permit Non-Compliance = 1 exceedance

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Municipal/Private Sewage Monthly Summary - Southwestern Region

The Forest-Cliff Camps, Incorporated

8324 Glendale Drive
Lambton Shores

Sector: Miscellaneous
Ministry Office: Sarnia

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

AMMONIA

C of A/Permit Non-Compliance

July 1, 2006 - July 31, 2006	3	mg/L	mon avg	1 exceedance	17	17	Conducting Study	Assessment underway, Voluntary Abatement Program Underway
---------------------------------	---	------	---------	--------------	----	----	------------------	---

Total C of A/Permit Non-Compliance = 1 exceedance

SUSPENDED SOLIDS

C of A/Permit Non-Compliance

July 1, 2006 - July 31, 2006	10	mg/L	mon avg	1 exceedance	107	107	Conducting Study	Assessment underway, Voluntary Abatement Program Underway
---------------------------------	----	------	---------	--------------	-----	-----	------------------	---

Total C of A/Permit Non-Compliance = 1 exceedance

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Municipal/Private Sewage Monthly Summary - Southwestern Region

The Municipality of North Perth - Listowel STP

Conc. 2 Lots 13 & 14 Elma
North Perth

Sector: Sewage Municipal
Ministry Office: London

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

AMMONIA

C of A/Permit Non-Compliance

July 1, 2006 - July 31, 2006	2.2	mg/L	mon avg	1 exceedance	2.6	2.6	Equipment Modified, Repaired, Replaced or Re- calibrated	Assessment Complete - Incident Resolved
---------------------------------	-----	------	---------	--------------	-----	-----	--	--

Total C of A/Permit Non-Compliance = 1 exceedance

ESCHERICHIA COLI

C of A/Permit Non-Compliance

July 1, 2006 - September 30, 2006	200	CT/100 mL	mon avg	2 exceedances	229	336	Equipment Modified, Repaired, Replaced or Re- calibrated	Assessment Complete - Incident Resolved
--------------------------------------	-----	--------------	---------	---------------	-----	-----	--	--

Total C of A/Permit Non-Compliance = 2 exceedances

SUSPENDED SOLIDS

C of A/Permit Non-Compliance

July 1, 2006 - July 31, 2006	10	mg/L	mon avg	1 exceedance	19.4	19.4	Equipment Modified, Repaired, Replaced or Re- calibrated	Assessment Complete - Incident Resolved
July 1, 2006 - July 31, 2006	90.4	kg/d	mon avg	1 exceedance	93.5	93.5	Equipment Modified, Repaired, Replaced or Re- calibrated	Assessment Complete - Incident Resolved

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Municipal/Private Sewage Monthly Summary - Southwestern Region

The Municipality of North Perth - Listowel STP

Conc. 2 Lots 13 & 14 Elma
North Perth

Sector: Sewage Municipal
Ministry Office: London

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

Total C of A/Permit Non-Compliance = 2 exceedances

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Municipal/Private Sewage Monthly Summary - Southwestern Region

Windsor Essex Catholic District School Board

2800 North Townline
LaSalle

Sector: Miscellaneous
Ministry Office: Windsor

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

AMMONIA

C of A/Permit Non-Compliance

January 1, 2006 - January 31, 2006	2	mg/L	mon avg	1 exceedance	6.35	6.35	Conducting Study	Provincial Officer's Order issued
May 1, 2006 - May 31, 2006	2	mg/L	mon avg	1 exceedance	4.17	4.17	Action Plan Submitted - Implementing Improvements, Operational Process Modification	Provincial Officer's Order issued, Voluntary Abatement Program Underway

Total C of A/Permit Non-Compliance = 2 exceedances

SUSPENDED SOLIDS

C of A/Permit Non-Compliance

February 1, 2006 - February 28, 2006	10	mg/L	/mon	1 exceedance	16	16	Conducting Study	Provincial Officer's Order issued
March 1, 2006 - March 31, 2006	2	mg/L	mon avg	1 exceedance	2.33	2.33	Conducting Study	Provincial Officer's Order issued

Total C of A/Permit Non-Compliance = 2 exceedances

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Municipal/Private Sewage Monthly Summary - Southwestern Region

YMCA of London - Camp Queen Elizabeth

Camp Queen Elizabeth, Beausoleil Island
Georgian Bay

Sector: Miscellaneous
Ministry Office: Barrie

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

AMMONIA

C of A/Permit Non-Compliance

July 1, 2006 - July 31, 2006	3	mg/L	mon avg	1 exceedance	19.46	19.46	Equipment Modified, Repaired, Replaced or Re- calibrated	Assessment Complete - No Action Required
August 1, 2006 - August 31, 2006	3	mg/L	mon avg	1 exceedance	3.05	3.05	Equipment Modified, Repaired, Replaced or Re- calibrated	Assessment Complete - No Action Required

Total C of A/Permit Non-Compliance = 2 exceedances

AMMONIA NITRATE

C of A/Permit Non-Compliance

July 1, 2006 - July 31, 2006	0.1	mg/L	mon avg	1 exceedance	0.309	0.309	Equipment Modified, Repaired, Replaced or Re- calibrated	Assessment Complete - No Action Required
August 1, 2006 - August 31, 2006	0.1	mg/L	mon avg	1 exceedance	0.167	0.167	Other	Assessment Complete - Incident Resolved

Total C of A/Permit Non-Compliance = 2 exceedances

PHOSPHORUS

C of A/Permit Non-Compliance

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Municipal/Private Sewage Monthly Summary - Southwestern Region

YMCA of London - Camp Queen Elizabeth

Camp Queen Elizabeth, Beausoleil Island
Georgian Bay

Sector: Miscellaneous
Ministry Office: Barrie

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
June 1, 2006 - June 30, 2006	0.5	mg/L	mon avg	1 exceedance	0.71	0.71	Operational Process Modification	Assessment Complete - No Action Required
August 1, 2006 - August 31, 2006	0.5	mg/L	mon avg	1 exceedance	0.506	0.506	Equipment Modified, Repaired, Replaced or Re- calibrated	Assessment Complete - No Action Required

Total C of A/Permit Non-Compliance = 2 exceedances

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."