

2006 Municipal/Private Sewage Monthly Summary - West Central Region

Parkbridge G/P Inc. - Antrium Glen STP

140 Glenariff Dr., 1264 8th Conc W.
Hamilton

Sector: Miscellaneous
Ministry Office: Hamilton

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

AMMONIA NITROGEN

C of A/Permit Non-Compliance

May 1, 2006 - May 31, 2006	1.5	mg/L	/mon	1 exceedance	2.15	2.15	Operational Process Modification	Assessment Complete - No Action Required
-------------------------------	-----	------	------	--------------	------	------	-------------------------------------	---

Total C of A/Permit Non-Compliance = 1 exceedance

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Municipal/Private Sewage Monthly Summary - West Central Region

Sherkston Shores Inc.

490 Empire Rd
Port Colborne

Sector: Miscellaneous
Ministry Office: Niagara

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

ESCHERICHIA COLI

C of A/Permit Non-Compliance

August 1, 2006 - August 31, 2006	200	CT/100 mL	mon avg	1 exceedance	285	285	New/Modified Sampling Program Underway	Assessment Complete - Incident Resolved
-------------------------------------	-----	--------------	---------	--------------	-----	-----	---	--

Total C of A/Permit Non-Compliance = 1 exceedance

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Municipal/Private Sewage Monthly Summary - West Central Region

**The Corporation of Haldimand
County - Caledonia WPCP**

320 Lanark Street
Haldimand

Sector: Sewage Municipal
Ministry Office: Hamilton

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

AMMONIA

C of A/Permit Non-Compliance

January 1, 2006 - January 31, 2006	2	mg/L	/mon	1 exceedance	2.33	2.33	Additional monitoring underway, New Equipment or Treatment Process Installed, Operational Process Modification	Voluntary Abatement Program Underway
---------------------------------------	---	------	------	--------------	------	------	--	---

Total C of A/Permit Non-Compliance = 1 exceedance

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Municipal/Private Sewage Monthly Summary - West Central Region

The Corporation of the Town of Shelburne

300 Centennial Rd L0N 1S4
Shelburne

Sector: Sewage Municipal
Ministry Office: Guelph

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

AMMONIA NITROGEN

C of A/Permit Non-Compliance

June 1, 2006 - June 30, 2006	1	mg/L	mon avg	1 exceedance	1.05	1.05	Equipment Modified, Repaired, Replaced or Re- calibrated, New Equipment or Treatment Process Installed	Assessment Complete - Incident Resolved, Assessment Complete - No Action Required
July 2006	3	mg/L	/d	1 exceedance	3.8	3.8	Equipment Modified, Repaired, Replaced or Re- calibrated, New Equipment or Treatment Process Installed	Assessment Complete - Incident Resolved, Assessment Complete - No Action Required

Total C of A/Permit Non-Compliance = 2 exceedances

SUSPENDED SOLIDS

C of A/Permit Non-Compliance

January 1, 2006 - January 31, 2006	6	mg/L	mon avg	2 exceedances	6.6	7	Equipment Modified, Repaired, Replaced or Re- calibrated	Assessment Complete - Incident Resolved
April 1, 2006 - April 30, 2006	6	mg/L	mon avg	1 exceedance	12.3	12.3	Equipment Modified, Repaired, Replaced or Re- calibrated	Assessment Complete - Incident Resolved

Total C of A/Permit Non-Compliance = 3 exceedances

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Municipal/Private Sewage Monthly Summary - West Central Region

The Corporation of the Township of Centre Wellington - Elora

49 Guelph Road, Elora
Centre Wellington

Sector: Sewage Municipal
Ministry Office: Guelph

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

ESCHERICHIA COLI

C of A/Permit Non-Compliance

January 1, 2006 - January 31, 2006	200	CT/100 mL	mon avg	1 exceedance	3044	3044	Operational Process Modification	Assessment Complete - Incident Resolved
January 1, 2006 - January 31, 2006	200	CT/100 mL	mon avg	1 exceedance	440	440	New Equipment or Treatment Process Installed	Assessment Complete - No Action Required

Total C of A/Permit Non-Compliance = 2 exceedances

PHOSPHORUS

C of A/Permit Non-Compliance

September 1, 2006 - September 30, 2006	1	mg/L	mon avg	1 exceedance	1.1	1	New Equipment or Treatment Process Installed	Assessment Complete - No Action Required
---	---	------	---------	--------------	-----	---	---	---

Total C of A/Permit Non-Compliance = 1 exceedance

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Municipal/Private Sewage Monthly Summary - West Central Region

The Corporation of the Township of Mapleton

7101 Sideroad 15, Drayton
Mapleton

Sector: Sewage Municipal
Ministry Office: Guelph

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

AMMONIA NITROGEN

C of A/Permit Non-Compliance

March 1, 2006 - March 31, 2006	5	mg/L	mon avg	1 exceedance	6.3	6.3	Action Plan Submitted - Implementing Improvements, Equipment Modified, Repaired, Replaced or Re- calibrated	Assessment Underway, Voluntary Abatement Program Underway
-----------------------------------	---	------	---------	--------------	-----	-----	---	---

Total C of A/Permit Non-Compliance = 1 exceedance

CARBONACEOUS BIOCHEMICAL OXYGEN DEMAND

C of A/Permit Non-Compliance

April 1, 2006 - April 30, 2006	7.5	mg/L	mon avg	1 exceedance	17	17	Action Plan Submitted - Implementing Improvements, Equipment Modified, Repaired, Replaced or Re- calibrated	Assessment Underway, Voluntary Abatement Program Underway
-----------------------------------	-----	------	---------	--------------	----	----	---	---

Total C of A/Permit Non-Compliance = 1 exceedance

PHOSPHORUS

C of A/Permit Non-Compliance

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Municipal/Private Sewage Monthly Summary - West Central Region

The Corporation of the Township of Mapleton

7101 Sideroad 15, Drayton
Mapleton

Sector: Sewage Municipal
Ministry Office: Guelph

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
March 1, 2006 - March 31, 2006	0.5	mg/L	mon avg	1 exceedance	0.89	0.89	Action Plan Submitted - Implementing Improvements, Equipment Modified, Repaired, Replaced or Re- calibrated	Assessment Underway, Voluntary Abatement Program Underway
April 1, 2006 - April 30, 2006	0.5	mg/L	mon avg	1 exceedance	0.94	0.94	Action Plan Submitted - Implementing Improvements, Equipment Modified, Repaired, Replaced or Re- calibrated	Assessment Underway, Voluntary Abatement Program Underway

Total C of A/Permit Non-Compliance = 2 exceedances

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Municipal/Private Sewage Monthly Summary - West Central Region

**The Regional Municipality of
Niagara - Baker Road**

347 Baker Rd
Grimsby

Sector: Sewage Municipal
Ministry Office: Niagara

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
ESCHERICHIA COLI								
C of A/Permit Non-Compliance								
September 1, 2006 - September 30, 2006	200	CT/100 mL	mon avg	1 exceedance	877.82	877.82	Additional Monitoring Underway, New/Modified Sampling Program Underway, Other	Voluntary Abatement Program Underway
October 1, 2006 - October 31, 2006	200	CT/100 mL	mon avg	1 exceedance	270.5	270.5	Additional Monitoring Underway, New/Modified Sampling Program Underway, Other	Voluntary Abatement Program Underway

Total C of A/Permit Non-Compliance = 2 exceedances

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Municipal/Private Sewage Monthly Summary - West Central Region

**The Regional Municipality of
Niagara - Welland**

505 River Rd
Welland

Sector: Sewage Municipal
Ministry Office: Niagara

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
TOTAL AMMONIA NITROGEN								
C of A/Permit Non-Compliance								
August 1, 2006 - August 31, 2006	12	mg/L	mon avg	1 exceedance	12.67	12.67	Ceased Operations	Assessment Complete - Incident Resolved

Total C of A/Permit Non-Compliance = 1 exceedance

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Municipal/Private Sewage Monthly Summary - West Central Region

**The Regional Municipality of
Waterloo - Ayr**

Lot 37, Con. 7
North Dumfries

Sector: Sewage Municipal
Ministry Office: Guelph

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
AMMONIA NITROGEN								
C of A/Permit Non-Compliance								
May 1, 2006 - May 31, 2006	3	mg/L	mon avg	2 exceedances	3.5	8.24	New Equipment or Treatment Process Installed	Assessment Complete - Incident Resolved
May 1, 2006 - May 31, 2006	4.5	kg/d	mon avg	1 exceedance	10	10	New Equipment or Treatment Process Installed	Assessment Complete - Incident Resolved
Total C of A/Permit Non-Compliance = 3 exceedances								

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Municipal/Private Sewage Monthly Summary - West Central Region

**The Regional Municipality of
Waterloo - Conestogo**

Lot 41, 43-56, Woolwich
Woolwich

Sector: Sewage Municipal
Ministry Office: Guelph

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

AMMONIA NITROGEN

C of A/Permit Non-Compliance

July 1, 2006 - July 31, 2006	2	mg/L	mon avg	1 exceedance	2.66	2.66	Equipment Modified, Repaired, Replaced or Re- calibrated	Assessment Complete - Incident Resolved, Assessment Complete - No Action Required
---------------------------------	---	------	---------	--------------	------	------	--	--

Total C of A/Permit Non-Compliance = 1 exceedance

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Municipal/Private Sewage Monthly Summary - West Central Region

**The Regional Municipality of
Waterloo - Elmira**

80 First St E
Woolwich

Sector: Sewage Municipal
Ministry Office: Guelph

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
AMMONIA NITROGEN								
C of A/Permit Non-Compliance								
May 1, 2006 - May 31, 2006	0.7	mg/L	mon avg	1 exceedance	2.28	2.28	Conducting Study	Assessment Underway
June 1, 2006 - June 30, 2006	0.7	mg/L	mon avg	1 exceedance	1.44	1.44	Conducting Study	Assessment Underway
July 1, 2006 - July 31, 2006	0.7	mg/L	mon avg	1 exceedance	1.345	1.345	Conducting Study	Assessment Underway

Total C of A/Permit Non-Compliance = 3 exceedances

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Municipal/Private Sewage Monthly Summary - West Central Region

**The Regional Municipality of
Waterloo - Kitchener**

368 Mill Park Drive
Kitchener

Sector: Sewage Municipal
Ministry Office: Guelph

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
ESCHERICHIA COLI								
C of A/Permit Non-Compliance								
February 1, 2006 - February 28, 2006	200	CT/100 mL	mon avg	1 exceedance	374	374	Operational Process Modification	Assessment Underway

Total C of A/Permit Non-Compliance = 1 exceedance

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Municipal/Private Sewage Monthly Summary - West Central Region

**The Regional Municipality of
Waterloo - Preston**

395 Montrose St. South
Cambridge

Sector: Sewage Municipal
Ministry Office: Guelph

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

BIOCHEMICAL OXYGEN DEMAND

C of A/Permit Non-Compliance

August 17, 2006 - August 25, 2006	15	mg/L	mon avg	1 exceedance	46.42	46.42	Operational Process Modification	Assessment Complete - Incident Resolved
--------------------------------------	----	------	---------	--------------	-------	-------	-------------------------------------	--

Total C of A/Permit Non-Compliance = 1 exceedance

PHOSPHORUS

C of A/Permit Non-Compliance

August 17, 2006 - August 25, 2006	0.7	mg/L	mon avg	1 exceedance	2.421	2.421	Operational Process Modification	Assessment Complete - Incident Resolved
--------------------------------------	-----	------	---------	--------------	-------	-------	-------------------------------------	--

Total C of A/Permit Non-Compliance = 1 exceedance

SUSPENDED SOLIDS

C of A/Permit Non-Compliance

August 17, 2006 - August 25, 2006	15	mg/L	mon avg	1 exceedance	59.231	59.231	Operational Process Modification	Assessment Complete - Incident Resolved
--------------------------------------	----	------	---------	--------------	--------	--------	-------------------------------------	--

Total C of A/Permit Non-Compliance = 1 exceedance

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Municipal/Private Sewage Monthly Summary - West Central Region

**The Regional Municipality of
Waterloo - Wellesley**

Lot 17, Conc. 4
Wilmot

Sector: Sewage Municipal
Ministry Office: Guelph

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
AMMONIA NITROGEN								
C of A/Permit Non-Compliance								
February 1, 2006 - February 28, 2006	0.75	mg/L	mon avg	1 exceedance	0.768	0.768	None Required, Other	Assessment Complete - No Action Required

Total C of A/Permit Non-Compliance = 1 exceedance

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."

2006 Municipal/Private Sewage Monthly Summary - West Central Region

Upper Grand District School Board

South West Half of Lot 16, Conc 10
Erin

Sector: Miscellaneous
Ministry Office: Guelph

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

NITRATE NITROGEN

C of A/Permit Non-Compliance

January 1, 2006 - February 28, 2006	3.6	mg/L	/mon	2 exceedances	10.2	23.6	Equipment Modified, Repaired, Replaced or Re- calibrated	Assessment Complete - Incident Resolved
--	-----	------	------	---------------	------	------	--	--

Total C of A/Permit Non-Compliance = 2 exceedances

"This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2007. For up-to-date information, please contact the appropriate district or area office."