

2007 Industrial Sewage Monthly Summary - West Central Region

**Abitibi-Consolidated Company of
Canada - Thorold**

2 Allanburg Rd
Thorold

Sector: Pulp and Paper
Ministry Office: Niagara

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

TOLUENE

Legislation Non-Compliance

November 2007	0.226	kg/d	/d	1 exceedance	0.3325	0.3325	Other	Assessment Underway
---------------	-------	------	----	--------------	--------	--------	-------	---------------------

Total Legislation Non-Compliance = 1 exceedance

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to September 2008. For up-to-date information, please contact the appropriate district or area office.

2007 Industrial Sewage Monthly Summary - West Central Region

CanGro Foods Inc.

329 Four Mile Creek Road
Niagara-on-the-Lake

Sector: Miscellaneous
Ministry Office: Niagara

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

AMMONIA NITROGEN

C of A/Permit Non-Compliance

June 2007	0.5	mg/L	any	4 exceedances	0.68	1.77	Ceased Operations	Assessment Complete - No Action Required
-----------	-----	------	-----	---------------	------	------	-------------------	--

Total C of A/Permit Non-Compliance = 4 exceedances

CARBONACEOUS BIOCHEMICAL OXYGEN DEMAND

C of A/Permit Non-Compliance

June 2007	15	mg/L	any	2 exceedances	19	20	Ceased Operations	Assessment Complete - No Action Required
-----------	----	------	-----	---------------	----	----	-------------------	--

Total C of A/Permit Non-Compliance = 2 exceedances

PHOSPHORUS

C of A/Permit Non-Compliance

June 2007	0.3	mg/L	any	3 exceedances	0.33	0.47	Ceased Operations	Assessment Complete - No Action Required
-----------	-----	------	-----	---------------	------	------	-------------------	--

Total C of A/Permit Non-Compliance = 3 exceedances

SUSPENDED SOLIDS

C of A/Permit Non-Compliance

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to September 2008. For up-to-date information, please contact the appropriate district or area office.

2007 Industrial Sewage Monthly Summary - West Central Region

CanGro Foods Inc.

329 Four Mile Creek Road
Niagara-on-the-Lake

Sector: Miscellaneous
Ministry Office: Niagara

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
May 2007	25	mg/L	any	1 exceedance	35	35	Ceased Operations	Assessment Complete - No Action Required
June 2007	25	mg/L	any	3 exceedances	28	80	Ceased Operations	Assessment Complete - No Action Required

Total C of A/Permit Non-Compliance = 4 exceedances

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to September 2008. For up-to-date information, please contact the appropriate district or area office.

2007 Industrial Sewage Monthly Summary - West Central Region

Carmeuse Lime (Canada) Limited - Dundas 600 Highway 5
Hamilton

Sector: Industrial Minerals
Ministry Office: Hamilton

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
SUSPENDED SOLIDS								
Legislation Non-Compliance								
March 12, 2007 - March 18, 2007	50	mg/L	/wk	1 exceedance	54	54	None Required	Assessment Complete - No Action Required
March 2007	50	mg/L	/d	1 exceedance	54	54	None Required	Voluntary Abatement Program Underway

Total Legislation Non-Compliance = 2 exceedances

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to September 2008. For up-to-date information, please contact the appropriate district or area office.

2007 Industrial Sewage Monthly Summary - West Central Region

CGC Inc.

55 Third Line Road
Haldimand

Sector: Industrial Minerals
Ministry Office: Hamilton

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

SUSPENDED SOLIDS

Legislation Non-Compliance

September 1, 2007 - September 30, 2007	25	mg/L	mon avg	1 exceedance	92	92	Action Plan Submitted - Implementing Improvements	Assessment Complete - Incident Resolved
September 2007	50	mg/L	/wk	1 exceedance	358	358	Action Plan Submitted - Implementing Improvements	Environmental Penalty Order Issued

Total Legislation Non-Compliance = 2 exceedances

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to September 2008. For up-to-date information, please contact the appropriate district or area office.

2007 Industrial Sewage Monthly Summary - West Central Region

Cytec Canada Inc.

9061 Garner Road
Niagara Falls

Sector: Inorganic Chemicals
Ministry Office: Niagara

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

ACUTE LETHALITY DAPHNIA

Legislation Non-Compliance

May 2007	Pass	acute toxicity	any	1 exceedance	Fail	Fail	Equipment Modified, Repaired, Replaced or Re-calibrated	Other Abatement Action Taken
August 2007	Pass	acute toxicity	any	1 exceedance	Fail	Fail	Equipment Modified, Repaired, Replaced or Re-calibrated	Other Abatement Action Taken

Total Legislation Non-Compliance = 2 exceedances

LOW PH EFFLUENT

Legislation Non-Compliance

August 2007	6	pH	any	1 exceedance	3.1	3.1	Equipment Modified, Repaired, Replaced or Re-calibrated	Other Abatement Action Taken
-------------	---	----	-----	--------------	-----	-----	---	------------------------------

Total Legislation Non-Compliance = 1 exceedance

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to September 2008. For up-to-date information, please contact the appropriate district or area office.

2007 Industrial Sewage Monthly Summary - West Central Region

GDX Canada Inc.

100 Kennedy St
Welland

Sector: Miscellaneous
Ministry Office: Niagara

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

OIL

C of A/Permit Non-Compliance

January 2007	15	mg/L	/wk	1 exceedance	22	22	New Equipment or Treatment Process Installed	Other Abatement Action Taken
--------------	----	------	-----	--------------	----	----	--	------------------------------

Total C of A/Permit Non-Compliance = 1 exceedance

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to September 2008. For up-to-date information, please contact the appropriate district or area office.

2007 Industrial Sewage Monthly Summary - West Central Region

Georgia-Pacific Canada, Inc. - Caledonia

350 Argyle St North, Caledonia
Haldimand

Sector: Industrial Minerals
Ministry Office: Hamilton

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

SUSPENDED SOLIDS

Legislation Non-Compliance

January 2007	50	ppm	mon avg	1 exceedance	116	116	None Required	Other Abatement Action Taken
--------------	----	-----	---------	--------------	-----	-----	---------------	------------------------------

Total Legislation Non-Compliance = 1 exceedance

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to September 2008. For up-to-date information, please contact the appropriate district or area office.

2007 Industrial Sewage Monthly Summary - West Central Region

Imperial Oil Limited - Nanticoke

225 2nd Conc
Haldimand

Sector: Petroleum Refineries
Ministry Office: Hamilton

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

DISSOLVED ORGANIC CARBON

Legislation Non-Compliance

March 2007	285	kg	/d	1 exceedance	614	614	New Equipment or Treatment Process Installed, Operational Process Modification	Assessment Complete - Incident Resolved
------------	-----	----	----	--------------	-----	-----	--	---

Total Legislation Non-Compliance = 1 exceedance

SUSPENDED SOLIDS

Legislation Non-Compliance

December 2007	265	kg	/d	1 exceedance	382.5	382.5	Other	Assessment Underway
---------------	-----	----	----	--------------	-------	-------	-------	---------------------

Total Legislation Non-Compliance = 1 exceedance

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to September 2008. For up-to-date information, please contact the appropriate district or area office.

2007 Industrial Sewage Monthly Summary - West Central Region

Jungbunzlauer Canada Inc.

1555 Elm St
Port Colborne

Sector: Miscellaneous
Ministry Office: Niagara

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

PHOSPHORUS

C of A/Permit Non-Compliance

June 2007	1	mg/L	any	1 exceedance	4	4	Equipment Modified, Repaired, Replaced or Re- calibrated	Assessment Complete - Incident Resolved
-----------	---	------	-----	--------------	---	---	--	--

Total C of A/Permit Non-Compliance = 1 exceedance

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to September 2008. For up-to-date information, please contact the appropriate district or area office.

2007 Industrial Sewage Monthly Summary - West Central Region

**Maple Leaf Foods Inc. - Rothsay
Dundas**

880 Highway 5 W
Hamilton

Sector: Miscellaneous
Ministry Office: Hamilton

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

SUSPENDED SOLIDS

C of A/Permit Non-Compliance

December 2007	10	mg/L	/d	1 exceedance	11	11	Other	Assessment Underway
---------------	----	------	----	--------------	----	----	-------	---------------------

Total C of A/Permit Non-Compliance = 1 exceedance

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to September 2008. For up-to-date information, please contact the appropriate district or area office.

2007 Industrial Sewage Monthly Summary - West Central Region

**Maple Leaf Foods Inc. - Rothsay
Moorefield**

Wellington County Road 7
Mapleton

Sector: Miscellaneous
Ministry Office: Guelph

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

SUSPENDED SOLIDS

C of A/Permit Non-Compliance

December 2007	15	mg/L	any	1 exceedance	24	24	Ceased Operations	Other Abatement Action Taken
---------------	----	------	-----	--------------	----	----	-------------------	------------------------------

Total C of A/Permit Non-Compliance = 1 exceedance

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to September 2008. For up-to-date information, please contact the appropriate district or area office.

2007 Industrial Sewage Monthly Summary - West Central Region

Newalta Industrial Services Inc.

112 Adams Blvd
Brantford

Sector: Miscellaneous
Ministry Office: Guelph

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

SUSPENDED SOLIDS

C of A/Permit Non-Compliance

June 2007	15	ppm	/wk	1 exceedance	247	247	Action Plan Submitted - Implementing Improvements	Assessment Complete - Incident Resolved, Voluntary Abatement Program Underway
July 2007	15	ppm	/wk	2 exceedances	34	35	Action Plan Submitted - Implementing Improvements	Assessment Complete - No Action Required

Total C of A/Permit Non-Compliance = 3 exceedances

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to September 2008. For up-to-date information, please contact the appropriate district or area office.

2007 Industrial Sewage Monthly Summary - West Central Region

Ontario Power Generation Inc. - Nanticoke

Lot 7, 8, 9, Conc. 1, Walpole
Haldimand

Sector: Electric Power Generation
Ministry Office: Hamilton

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

ACUTE LETHALITY DAPHNIA

Legislation Non-Compliance

August 2007	Pass	acute toxicity	any	1 exceedance	Fail	Fail	Conducting Study	Assessment Complete - No Action Required
August 2007	Pass	acute toxicity	any	1 exceedance	Fail	Fail	Conducting Study	Assessment Underway
October 2007	Pass	acute toxicity	any	3 exceedances	Fail	Fail	Additional Monitoring Underway	Voluntary Abatement Program Underway

Total Legislation Non-Compliance = 5 exceedances

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to September 2008. For up-to-date information, please contact the appropriate district or area office.

2007 Industrial Sewage Monthly Summary - West Central Region

Oxy Vinyls Canada Inc.

8800 Thorold Townline Road
Thorold

Sector: Inorganic Chemicals
Ministry Office: Niagara

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

PHENOL

Legislation Non-Compliance

December 2007	0.32	kg	/d	1 exceedance	1.05	1.05	Conducting Study, Operational Process Modification, Training/Procedure Change	Assessment Underway
---------------	------	----	----	--------------	------	------	--	---------------------

Total Legislation Non-Compliance = 1 exceedance

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to September 2008. For up-to-date information, please contact the appropriate district or area office.

2007 Industrial Sewage Monthly Summary - West Central Region

Strabag Inc.

2520 Stanley Ave
Niagara Falls

Sector: Miscellaneous
Ministry Office: Niagara

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

CHLORIDE

C of A/Permit Non-Compliance

February 2007	150	mg/L	any	2 exceedances	181	227	Equipment Modified, Repaired, Replaced or Re-calibrated	Assessment Complete - Incident Resolved
February 2007	150	mg/L	any	1 exceedance	156	156	New Equipment or Treatment Process Installed	Provincial Officer's Order Issued
February 2007	150	mg/L	any	1 exceedance	153	153	Training/Procedure Change	Provincial Officer's Order Issued
April 2007	150	mg/L	any	1 exceedance	281	281	New Equipment or Treatment Process Installed, Operational Process Modification	Assessment Underway, Other Abatement Action Taken
May 11, 2007 - May 12, 2007	150	mg/L	any	1 exceedance	173	173	Action Plan Submitted - Implementing Improvements	Assessment Underway, Other Abatement Action Taken

Total C of A/Permit Non-Compliance = 6 exceedances

CHLORINE RESIDUAL

C of A/Permit Non-Compliance

February 2007	0.01	mg/L	any	1 exceedance	0.018	0.018	Training/Procedure Change	Provincial Officer's Order Issued
---------------	------	------	-----	--------------	-------	-------	---------------------------	-----------------------------------

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to September 2008. For up-to-date information, please contact the appropriate district or area office.

2007 Industrial Sewage Monthly Summary - West Central Region

Strabag Inc.

2520 Stanley Ave
Niagara Falls

Sector: Miscellaneous
Ministry Office: Niagara

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

Total C of A/Permit Non-Compliance = 1 exceedance

HIGH PH EFFLUENT

C of A/Permit Non-Compliance

April 2007	9.5	pH	any	1 exceedance	9.83	9.83	Conducting Study	Assessment Underway
April 2007	9.5	pH	any	1 exceedance	9.88	9.88	Conducting Study	Other Abatement Action Taken

Total C of A/Permit Non-Compliance = 2 exceedances

LOW PH EFFLUENT

C of A/Permit Non-Compliance

April 2007	6.5	pH	any	1 exceedance	5.05	5.05	Conducting Study	Other Abatement Action Taken
------------	-----	----	-----	--------------	------	------	------------------	------------------------------

Total C of A/Permit Non-Compliance = 1 exceedance

OIL AND GREASE

C of A/Permit Non-Compliance

March 2007	15	mg/L	/d	6 exceedances	25	37	Action Plan Submitted - Implementing Improvements	Assessment Underway
March 14, 2007 - March 15, 2007	15	mg/L	/d	1 exceedance	60	60	Conducting Study	Assessment Underway

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to September 2008. For up-to-date information, please contact the appropriate district or area office.

2007 Industrial Sewage Monthly Summary - West Central Region

Strabag Inc.

2520 Stanley Ave
Niagara Falls

Sector: Miscellaneous
Ministry Office: Niagara

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
March 2007	15	mg/L	/d	2 exceedances	16	41	Conducting Study, Operational Process Modification	Assessment Underway, Provincial Officer's Order Issued
March 2007	15	mg/L	/d	18 exceedances	16	41	Conducting Study, Operational Process Modification	Other Abatement Action Taken, Provincial Officer's Order Issued
March 6, 2007 - March 7, 2007	15	mg/L	/d	2 exceedances	32	41	Other	Assessment Underway
April 2007	15	mg/L	/d	2 exceedances	20	21	Conducting Study, Operational Process Modification	Assessment Underway, Other Abatement Action Taken
June 13, 2007 - June 14, 2007	15	mg/L	/d	1 exceedance	42	42	New Equipment or Treatment Process Installed	Provincial Officer's Order Issued

Total C of A/Permit Non-Compliance = 32 exceedances

SUSPENDED SOLIDS

C of A/Permit Non-Compliance

April 2007	25	mg/L	any	1 exceedance	28	28	Conducting Study	Other Abatement Action Taken
April 2007	25	mg/L	any	1 exceedance	41	41	Conducting Study, Operational Process Modification	Assessment Underway, Other Abatement Action Taken

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to September 2008. For up-to-date information, please contact the appropriate district or area office.

2007 Industrial Sewage Monthly Summary - West Central Region

Strabag Inc.

2520 Stanley Ave
Niagara Falls

Sector: Miscellaneous
Ministry Office: Niagara

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
October 2007	25	mg/L	any	1 exceedance	26	26	New Equipment or Treatment Process Installed	Assessment Complete - Incident Resolved

Total C of A/Permit Non-Compliance = 3 exceedances

TOLUENE

C of A/Permit Non-Compliance

July 2007	0.0008	mg/L	/d	1 exceedance	0.631	0.631	Equipment Modified, Repaired, Replaced or Re-calibrated, Operational Process Modification	Provincial Officer's Order Issued
July 2007	0.0008	mg/L	/d	1 exceedance	0.0027	0.0027	New Equipment or Treatment Process Installed	Provincial Officer's Order Issued
August 2007	0.0008	mg/L	/d	4 exceedances	0.00102	0.0171	New Equipment or Treatment Process Installed	Voluntary Abatement Program Underway
August 2007	0.0008	mg/L	/d	2 exceedances	0.173	0.633	Operational Process Modification	Provincial Officer's Order Issued
September 2007	0.0008	mg/L	/d	5 exceedances	0.0222	0.0639	Additional Monitoring Underway, Operational Process Modification	Assessment Complete - Incident Resolved
September 2007	0.0008	mg/L	/d	1 exceedance	0.0237	0.0237	New Equipment or Treatment Process Installed	Assessment Complete - Incident Resolved

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to September 2008. For up-to-date information, please contact the appropriate district or area office.

2007 Industrial Sewage Monthly Summary - West Central Region

Strabag Inc.

2520 Stanley Ave
Niagara Falls

Sector: Miscellaneous
Ministry Office: Niagara

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
October 2007	0.0008	mg/L	/d	1 exceedance	0.0014	0.0014	Equipment Modified, Repaired, Replaced or Re-calibrated	Other Abatement Action Taken

Total C of A/Permit Non-Compliance = 15 exceedances

XYLENE

C of A/Permit Non-Compliance

July 2007	0.002	mg/L	/d	1 exceedance	0.003	0.003	Equipment Modified, Repaired, Replaced or Re-calibrated, Operational Process Modification	Provincial Officer's Order Issued
July 2007	0.002	mg/L	/d	1 exceedance	0.003	0.003	New Equipment or Treatment Process Installed	Provincial Officer's Order Issued

Total C of A/Permit Non-Compliance = 2 exceedances

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to September 2008. For up-to-date information, please contact the appropriate district or area office.

2007 Industrial Sewage Monthly Summary - West Central Region

**The Corporation of the City of
Thorold - Rice Road**

Part Lot 160 Rice Road
Thorold

Sector: Miscellaneous
Ministry Office: Niagara

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

PHOSPHORUS

C of A/Permit Non-Compliance

April 1, 2007 - April 30, 2007	0.03	mg/L	mon avg	1 exceedance	0.04	0.04	None Required	Assessment Complete - No Action Required
May 1, 2007 - May 31, 2007	0.03	mg/L	mon avg	1 exceedance	0.06	0.06	None Required	Assessment Complete - No Action Required
July 1, 2007 - July 31, 2007	0.03	mg/L	mon avg	1 exceedance	0.06	0.06	None Required	Assessment Complete - No Action Required
August 1, 2007 - August 31, 2007	0.03	mg/L	mon avg	1 exceedance	0.05	0.05	None Required	Assessment Complete - No Action Required

Total C of A/Permit Non-Compliance = 4 exceedances

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to September 2008. For up-to-date information, please contact the appropriate district or area office.

2007 Industrial Sewage Monthly Summary - West Central Region

U.S. Steel Canada Inc. - Hamilton Works

386 Wilcox St
Hamilton

Sector: Iron and Steel
Ministry Office: Hamilton

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

ACUTE LETHALITY - TROUT

Legislation Non-Compliance

February 2007	Pass	acute toxicity	any	1 exceedance	Fail	Fail	Other	Assessment Underway
---------------	------	----------------	-----	--------------	------	------	-------	---------------------

Total Legislation Non-Compliance = 1 exceedance

ACUTE LETHALITY DAPHNIA

Legislation Non-Compliance

February 2007	Pass	acute toxicity	any	1 exceedance	Fail	Fail	Other	Assessment Underway
---------------	------	----------------	-----	--------------	------	------	-------	---------------------

Total Legislation Non-Compliance = 1 exceedance

LOW PH EFFLUENT

C of A/Permit Non-Compliance

May 2007	6	pH	any	1 exceedance	5.77	5.77	Other	Assessment Complete - Incident Resolved
----------	---	----	-----	--------------	------	------	-------	---

Total C of A/Permit Non-Compliance = 1 exceedance

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to September 2008. For up-to-date information, please contact the appropriate district or area office.

2007 Industrial Sewage Monthly Summary - West Central Region

U.S. Steel Canada Inc. - Lake Erie Works

2330 Regional Road No.3
Haldimand

Sector: Iron and Steel
Ministry Office: Hamilton

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

PHOSPHORUS

Legislation Non-Compliance

February 1, 2007 - February 28, 2007	37.7	kg/d	mon avg	1 exceedance	39.25	39.25	Action Plan Submitted - Implementing Improvements	Assessment Complete - Incident Resolved
---	------	------	---------	--------------	-------	-------	--	--

Total Legislation Non-Compliance = 1 exceedance

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to September 2008. For up-to-date information, please contact the appropriate district or area office.

2007 Industrial Sewage Monthly Summary - West Central Region

Washington Mills Electro Minerals Corporation

7780 Stanley Ave
Niagara Falls

Sector: Inorganic Chemicals
Ministry Office: Niagara

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
SUSPENDED SOLIDS								
Legislation Non-Compliance								
February 2007	395	kg/d	/d	1 exceedance	522	522	Operational Process Modification	Other Abatement Action Taken

Total Legislation Non-Compliance = 1 exceedance

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to September 2008. For up-to-date information, please contact the appropriate district or area office.