

2007 Municipal/Private Sewage Monthly Summary - Central Region

1319536 Ontario Limited - Royal Ontario Golf Course

6378 Trafalgar Road
Milton

Sector: Miscellaneous
Ministry Office: Halton-Peel

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

ESCHERICHIA COLI

C of A/Permit Non-Compliance

November 1, 2007 - November 30, 2007	200	CT/100 mL	mon avg	1 exceedance	520	520	Equipment Modified, Repaired, Replaced or Re- calibrated, New Equipment or Treatment Process Installed	Assessment Underway
---	-----	--------------	---------	--------------	-----	-----	---	---------------------

Total C of A/Permit Non-Compliance = 1 exceedance

PHOSPHORUS

C of A/Permit Non-Compliance

October 1, 2007 - October 31, 2007	10	mg/L	mon avg	1 exceedance	13.4	13.4	Equipment Modified, Repaired, Replaced or Re- calibrated, New Equipment or Treatment Process Installed	Assessment Underway
November 1, 2007 - November 30, 2007	10	mg/L	mon avg	1 exceedance	11	11	Equipment Modified, Repaired, Replaced or Re- calibrated, New Equipment or Treatment Process Installed	Assessment Underway
December 1, 2007 - December 31, 2007	10	mg/L	mon avg	1 exceedance	12	12	Other	Assessment Underway

Total C of A/Permit Non-Compliance = 3 exceedances

SUSPENDED SOLIDS

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to September 2008. For up-to-date information, please contact the appropriate district or area office.

2007 Municipal/Private Sewage Monthly Summary - Central Region

1319536 Ontario Limited - Royal Ontario Golf Course

6378 Trafalgar Road
Milton

Sector: Miscellaneous
Ministry Office: Halton-Peel

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

C of A/Permit Non-Compliance

October 1, 2007 - October 31, 2007	30	mg/L	mon avg	1 exceedance	43	43	Equipment Modified, Repaired, Replaced or Re- calibrated, New Equipment or Treatment Process Installed	Assessment Underway
---------------------------------------	----	------	---------	--------------	----	----	---	---------------------

Total C of A/Permit Non-Compliance = 1 exceedance

TOTAL AMMONIA NITROGEN

C of A/Permit Non-Compliance

June 1, 2007 - June 30, 2007	5	mg/L	mon avg	1 exceedance	7.7	7.7	New Equipment or Treatment Process Installed	Assessment Underway
July 1, 2007 - July 31, 2007	5	mg/L	mon avg	1 exceedance	7.2	7.2	New Equipment or Treatment Process Installed, Other	Assessment Underway
August 1, 2007 - August 31, 2007	5	mg/L	mon avg	1 exceedance	7	7	New Equipment or Treatment Process Installed, Other	Assessment Underway
October 1, 2007 - October 31, 2007	5	mg/L	mon avg	1 exceedance	21	21	Equipment Modified, Repaired, Replaced or Re- calibrated, New Equipment or Treatment Process Installed	Assessment Underway

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to September 2008. For up-to-date information, please contact the appropriate district or area office.

2007 Municipal/Private Sewage Monthly Summary - Central Region

1319536 Ontario Limited - Royal Ontario Golf Course

6378 Trafalgar Road
Milton

Sector: Miscellaneous
Ministry Office: Halton-Peel

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
November 1, 2007 - November 30, 2007	5	mg/L	mon avg	1 exceedance	9.1	9.1	Equipment Modified, Repaired, Replaced or Re- calibrated, New Equipment or Treatment Process Installed	Assessment Underway

Total C of A/Permit Non-Compliance = 5 exceedances

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to September 2008. For up-to-date information, please contact the appropriate district or area office.

2007 Municipal/Private Sewage Monthly Summary - Central Region

351658 Ontario Limited - Kaneff Headquarters

8501 Mississauga Road
Brampton

Sector: Miscellaneous
Ministry Office: Halton-Peel

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
SUSPENDED SOLIDS								
C of A/Permit Non-Compliance								
January 4, 2007 - January 10, 2007	10	mg/L	rolling avg	2 exceedances	11	15.5	New Equipment or Treatment Process Installed	Voluntary Abatement Program Underway
February 21, 2007 - February 27, 2007	10	mg/L	rolling avg	2 exceedances	10.75	11.25	New Equipment or Treatment Process Installed	Voluntary Abatement Program Underway
May 2007	10	mg/L	rolling avg	1 exceedance	10.75	10.75	New Equipment or Treatment Process Installed	Voluntary Abatement Program Underway

Total C of A/Permit Non-Compliance = 5 exceedances

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to September 2008. For up-to-date information, please contact the appropriate district or area office.

2007 Municipal/Private Sewage Monthly Summary - Central Region

City of Toronto - Highland Creek STP

51 Beechgrove Dr
Toronto

Sector: Sewage Municipal
Ministry Office: Toronto

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

PHOSPHORUS

C of A/Permit Non-Compliance

May 1, 2007 - May 31, 2007	1	mg/L	/mon	1 exceedance	1.17	1.17	Action Plan Submitted - Implementing Improvements, Equipment Modified, Repaired, Replaced or Re- calibrated, New Equipment or Treatment Process Installed	Assessment Complete - Incident Resolved, Voluntary Abatement Program Underway
-------------------------------	---	------	------	--------------	------	------	--	---

Total C of A/Permit Non-Compliance = 1 exceedance

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to September 2008. For up-to-date information, please contact the appropriate district or area office.

2007 Municipal/Private Sewage Monthly Summary - Central Region

ClubLink Corporation - Emerald Hills Golf Course

14001 Warden Ave Stouffville
Whitchurch-Stouffville

Sector: Miscellaneous
Ministry Office: York-Durham

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

ESCHERICHIA COLI

C of A/Permit Non-Compliance

April 1, 2007 - April 30, 2007	200	cfu/100 ml	mon avg	1 exceedance	211.3	211.3	Operational Process Modification	Assessment Underway
-----------------------------------	-----	------------	---------	--------------	-------	-------	----------------------------------	---------------------

Total C of A/Permit Non-Compliance = 1 exceedance

NITROGEN

C of A/Permit Non-Compliance

May 1, 2007 - May 31, 2007	22	mg/L	mon avg	1 exceedance	22.5	22.5	Action Plan Submitted - Implementing Improvements	Assessment Underway
June 1, 2007 - June 30, 2007	22	mg/L	mon avg	1 exceedance	22.7	22.7	Additional Monitoring Underway	Assessment Underway
August 1, 2007 - August 31, 2007	22	mg/L	mon avg	1 exceedance	26.6	26.6	New Equipment or Treatment Process Installed	Assessment Complete - Incident Resolved
September 1, 2007 - September 30, 2007	22	mg/L	mon avg	1 exceedance	29.6	29.6	New Equipment or Treatment Process Installed	Assessment Complete - Incident Resolved

Total C of A/Permit Non-Compliance = 4 exceedances

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to September 2008. For up-to-date information, please contact the appropriate district or area office.

2007 Municipal/Private Sewage Monthly Summary - Central Region

Clublink Corporation - King Valley Golf Club

15675 Dufferin St, King City
King

Sector: Miscellaneous
Ministry Office: York-Durham

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
AMMONIA								
C of A/Permit Non-Compliance								
January 1, 2007 - January 31, 2007	2.5	mg/L	mon avg	1 exceedance	28.3	28.3	Equipment Modified, Repaired, Replaced or Re- calibrated	Voluntary Abatement Program Underway
February 1, 2007 - February 28, 2007	2.5	mg/L	mon avg	1 exceedance	35	35	Equipment Modified, Repaired, Replaced or Re- calibrated	Voluntary Abatement Program Underway
March 1, 2007 - March 31, 2007	2.5	mg/L	mon avg	1 exceedance	25.6	25.6	Equipment Modified, Repaired, Replaced or Re- calibrated	Voluntary Abatement Program Underway
April 1, 2007 - April 30, 2007	2.5	mg/L	mon avg	1 exceedance	14	14	Equipment Modified, Repaired, Replaced or Re- calibrated	Voluntary Abatement Program Underway
May 1, 2007 - May 31, 2007	2.5	mg/L	mon avg	1 exceedance	7.7	7.7	Equipment Modified, Repaired, Replaced or Re- calibrated	Voluntary Abatement Program Underway
November 1, 2007 - November 30, 2007	2.5	mg/L	mon avg	1 exceedance	3.5	3.5	Equipment Modified, Repaired, Replaced or Re- calibrated	Assessment Complete - Incident Resolved

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to September 2008. For up-to-date information, please contact the appropriate district or area office.

2007 Municipal/Private Sewage Monthly Summary - Central Region

**Clublink Corporation - King
Valley Golf Club**

15675 Dufferin St, King City
King

Sector: Miscellaneous
Ministry Office: York-Durham

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

Total C of A/Permit Non-Compliance = 6 exceedances

AMMONIA + NITRATE + NITRITE NITROGEN

C of A/Permit Non-Compliance

January 1, 2007 - January 31, 2007	22	mg/L	mon avg	1 exceedance	33	33	Equipment Modified, Repaired, Replaced or Re- calibrated	Voluntary Abatement Program Underway
February 1, 2007 - February 28, 2007	22	mg/L	mon avg	1 exceedance	37	37	Equipment Modified, Repaired, Replaced or Re- calibrated	Voluntary Abatement Program Underway
March 1, 2007 - March 31, 2007	22	mg/L	mon avg	1 exceedance	25	25	Equipment Modified, Repaired, Replaced or Re- calibrated	Voluntary Abatement Program Underway
April 1, 2007 - April 30, 2007	22	mg/L	mon avg	1 exceedance	27	27	Equipment Modified, Repaired, Replaced or Re- calibrated	Voluntary Abatement Program Underway
May 1, 2007 - May 31, 2007	22	mg/L	mon avg	1 exceedance	46	46	Equipment Modified, Repaired, Replaced or Re- calibrated	Voluntary Abatement Program Underway

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to September 2008. For up-to-date information, please contact the appropriate district or area office.

2007 Municipal/Private Sewage Monthly Summary - Central Region

Clublink Corporation - King Valley Golf Club

15675 Dufferin St, King City
King

Sector: Miscellaneous
Ministry Office: York-Durham

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
June 1, 2007 - June 30, 2007	22	mg/L	mon avg	1 exceedance	25	25	Equipment Modified, Repaired, Replaced or Re- calibrated	Voluntary Abatement Program Underway

Total C of A/Permit Non-Compliance = 6 exceedances

BIOCHEMICAL OXYGEN DEMAND

C of A/Permit Non-Compliance

January 1, 2007 - January 31, 2007	30	mg/L	mon avg	1 exceedance	66	66	Equipment Modified, Repaired, Replaced or Re- calibrated	Voluntary Abatement Program Underway
February 1, 2007 - February 28, 2007	30	mg/L	mon avg	1 exceedance	59	59	Equipment Modified, Repaired, Replaced or Re- calibrated	Voluntary Abatement Program Underway
May 2007	3	mg/L	any	1 exceedance	3.1	3.1	Training/Procedure Change	Provincial Officer's Order Issued

Total C of A/Permit Non-Compliance = 3 exceedances

PHOSPHORUS

C of A/Permit Non-Compliance

February 1, 2007 - February 28, 2007	2.5	mg/L	mon avg	1 exceedance	3.1	3.1	Equipment Modified, Repaired, Replaced or Re- calibrated	Voluntary Abatement Program Underway
---	-----	------	---------	--------------	-----	-----	--	---

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to September 2008. For up-to-date information, please contact the appropriate district or area office.

2007 Municipal/Private Sewage Monthly Summary - Central Region

Clublink Corporation - King Valley Golf Club

15675 Dufferin St, King City
King

Sector: Miscellaneous
Ministry Office: York-Durham

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
May 1, 2007 - May 31, 2007	2.5	mg/L	mon avg	1 exceedance	2.7	2.7	Equipment Modified, Repaired, Replaced or Re- calibrated	Voluntary Abatement Program Underway

Total C of A/Permit Non-Compliance = 2 exceedances

SUSPENDED SOLIDS

C of A/Permit Non-Compliance

January 1, 2007 - January 31, 2007	30	mg/L	mon avg	1 exceedance	27	27	Equipment Modified, Repaired, Replaced or Re- calibrated	Voluntary Abatement Program Underway
February 1, 2007 - February 28, 2007	30	mg/L	mon avg	1 exceedance	45	45	Equipment Modified, Repaired, Replaced or Re- calibrated	Voluntary Abatement Program Underway

Total C of A/Permit Non-Compliance = 2 exceedances

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to September 2008. For up-to-date information, please contact the appropriate district or area office.

2007 Municipal/Private Sewage Monthly Summary - Central Region

ClubLink Corporation - King's Riding Golf Club

Lot: 17, Conc: 2
King

Sector: Miscellaneous
Ministry Office: York-Durham

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

AMMONIA

C of A/Permit Non-Compliance

February 1, 2007 - February 28, 2007	2.5	mg/L	mon avg	1 exceedance	3.1	3.1	Other	Assessment Complete - Incident Resolved
---	-----	------	---------	--------------	-----	-----	-------	--

Total C of A/Permit Non-Compliance = 1 exceedance

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to September 2008. For up-to-date information, please contact the appropriate district or area office.

2007 Municipal/Private Sewage Monthly Summary - Central Region

ClubLink Corporation - Rattlesnake Point Golf Club

5405 Regional Road 25
Milton

Sector: Miscellaneous
Ministry Office: Halton-Peel

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
ESCHERICHIA COLI								
C of A/Permit Non-Compliance								
June 1, 2007 - June 30, 2007	200	CT/100 mL	mon avg. on a geo. mean density	1 exceedance	413	413	Equipment Modified, Repaired, Replaced or Re- calibrated	Assessment Underway
July 1, 2007 - July 31, 2007	200	CT/100 mL	mon avg. on a geo. mean density	1 exceedance	9771	9771	Equipment Modified, Repaired, Replaced or Re- calibrated	Assessment Underway
August 1, 2007 - August 31, 2007	200	CT/100 mL	mon avg. on a geo. mean density	1 exceedance	3978	3978	Equipment Modified, Repaired, Replaced or Re- calibrated	Assessment Underway

Total C of A/Permit Non-Compliance = 3 exceedances

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to September 2008. For up-to-date information, please contact the appropriate district or area office.

2007 Municipal/Private Sewage Monthly Summary - Central Region

**ClubLink Corporation -
Wyndance Golf Club**

403 - Hwy 47 RR #1 Goodwood
Uxbridge

Sector: Miscellaneous
Ministry Office: York-Durham

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

ESCHERICHIA COLI

C of A/Permit Non-Compliance

July 1, 2007 - July 31, 2007	200	cfu/100 ml	mon avg. on a geo. mean density	1 exceedance	751	751	Other	Voluntary Abatement Program Underway
August 1, 2007 - August 31, 2007	200	cfu/100 ml	mon avg. on a geo. mean density	1 exceedance	3083	3083	Additional Monitoring Underway	Voluntary Abatement Program Underway

Total C of A/Permit Non-Compliance = 2 exceedances

PHOSPHORUS

C of A/Permit Non-Compliance

July 1, 2007 - July 31, 2007	1	mg/L	mon avg	1 exceedance	5.5	5.5	Other	Voluntary Abatement Program Underway
August 1, 2007 - August 31, 2007	1	mg/L	mon avg	1 exceedance	5.4	5.4	Additional Monitoring Underway	Voluntary Abatement Program Underway
September 1, 2007 - September 30, 2007	1	mg/L	mon avg	1 exceedance	7.5	7.5	Other	Voluntary Abatement Program Underway

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to September 2008. For up-to-date information, please contact the appropriate district or area office.

2007 Municipal/Private Sewage Monthly Summary - Central Region

ClubLink Corporation - Wyndance Golf Club

403 - Hwy 47 RR #1 Goodwood
Uxbridge

Sector: Miscellaneous
Ministry Office: York-Durham

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
October 1, 2007 - October 31, 2007	1	mg/L	mon avg	1 exceedance	3.9	3.9	Other	Voluntary Abatement Program Underway

Total C of A/Permit Non-Compliance = 4 exceedances

SUSPENDED SOLIDS

C of A/Permit Non-Compliance

October 1, 2007 - October 31, 2007	25	mg/L	mon avg	1 exceedance	29	29	Other	Voluntary Abatement Program Underway
---------------------------------------	----	------	---------	--------------	----	----	-------	---

Total C of A/Permit Non-Compliance = 1 exceedance

TOTAL AMMONIA NITROGEN

C of A/Permit Non-Compliance

July 1, 2007 - July 31, 2007	3	mg/L	mon avg	1 exceedance	52	52	Other	Voluntary Abatement Program Underway
August 1, 2007 - August 31, 2007	3	mg/L	mon avg	1 exceedance	27	27	Additional Monitoring Underway	Voluntary Abatement Program Underway

Total C of A/Permit Non-Compliance = 2 exceedances

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to September 2008. For up-to-date information, please contact the appropriate district or area office.

2007 Municipal/Private Sewage Monthly Summary - Central Region

Granite Golf and Country Club

2699 York Durham Line, Uxbridge
Whitchurch-Stouffville

Sector: Miscellaneous
Ministry Office: York-Durham

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

SUSPENDED SOLIDS

C of A/Permit Non-Compliance

July 1, 2007 - July 31, 2007	5	mg/L	mon avg	1 exceedance	5.5	5.5	Additional Monitoring Underway	Assessment Complete - Incident Resolved
---------------------------------	---	------	---------	--------------	-----	-----	-----------------------------------	--

Total C of A/Permit Non-Compliance = 1 exceedance

TOTAL AMMONIA NITROGEN

C of A/Permit Non-Compliance

July 1, 2007 - July 31, 2007	2	mg/L	mon avg	1 exceedance	6.1	6.1	Additional Monitoring Underway	Assessment Complete - Incident Resolved
---------------------------------	---	------	---------	--------------	-----	-----	-----------------------------------	--

Total C of A/Permit Non-Compliance = 1 exceedance

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to September 2008. For up-to-date information, please contact the appropriate district or area office.

2007 Municipal/Private Sewage Monthly Summary - Central Region

Piper's Heath Golf Club Ltd.

5527 Trafalgar Road
Milton

Sector: Miscellaneous
Ministry Office: Halton-Peel

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

CARBONACEOUS BIOCHEMICAL OXYGEN DEMAND

C of A/Permit Non-Compliance

August 3, 2007 - August 31, 2007	15	mg/L	mon avg	1 exceedance	26	26	Additional Monitoring Underway, Training/Procedure Change	Assessment Underway
September 1, 2007 - September 30, 2007	15	mg/L	mon avg	1 exceedance	20	20	None Required	Assessment Underway
November 1, 2007 - November 30, 2007	15	mg/L	mon avg	1 exceedance	25	25	Other	Assessment Underway

Total C of A/Permit Non-Compliance = 3 exceedances

ESCHERICHIA COLI

C of A/Permit Non-Compliance

August 3, 2007 - August 31, 2007	100	mg/L	mon avg. on a geo. mean density	1 exceedance	4627	4627	Additional Monitoring Underway, Training/Procedure Change	Assessment Underway
September 1, 2007 - September 30, 2007	100	CT/100 mL	mon avg. on a geo. mean density	1 exceedance	20000	20000	None Required	Assessment Underway

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to September 2008. For up-to-date information, please contact the appropriate district or area office.

2007 Municipal/Private Sewage Monthly Summary - Central Region

Piper's Heath Golf Club Ltd.

5527 Trafalgar Road
Milton

Sector: Miscellaneous
Ministry Office: Halton-Peel

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
October 1, 2007 - October 31, 2007	100	CT/100 mL	mon avg. on a geo. mean density	1 exceedance	7814	7814	Additional Monitoring Underway, Other	Assessment Underway
November 1, 2007 - November 30, 2007	100	CT/100 mL	mon avg. on a geo. mean density	1 exceedance	906	906	Other	Assessment Underway

Total C of A/Permit Non-Compliance = 4 exceedances

PHOSPHORUS

C of A/Permit Non-Compliance

August 1, 2007 - August 31, 2007	2.5	mg/L	mon avg	1 exceedance	8.3	8.3	Additional Monitoring Underway, Training/Procedure Change	Assessment Underway
September 1, 2007 - September 30, 2007	2.5	mg/L	mon avg	1 exceedance	13	13	None Required	Assessment Underway
October 1, 2007 - October 31, 2007	2.5	mg/L	mon avg	1 exceedance	14	14	Additional Monitoring Underway, Other	Assessment Underway
November 1, 2007 - November 30, 2007	2.5	mg/L	mon avg	1 exceedance	8.3	8.3	Other	Assessment Underway
December 1, 2007 - December 31, 2007	2.5	mg/L	mon avg	1 exceedance	3.5	3.5	Other	Assessment Underway

Total C of A/Permit Non-Compliance = 5 exceedances

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to September 2008. For up-to-date information, please contact the appropriate district or area office.

2007 Municipal/Private Sewage Monthly Summary - Central Region

Piper's Heath Golf Club Ltd.

5527 Trafalgar Road
Milton

Sector: Miscellaneous
Ministry Office: Halton-Peel

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

SUSPENDED SOLIDS

C of A/Permit Non-Compliance

August 1, 2007 - August 31, 2007	15	mg/L	mon avg	1 exceedance	19	19	Additional Monitoring Underway, Training/Procedure Change	Assessment Underway
September 1, 2007 - September 30, 2007	15	mg/L	mon avg	1 exceedance	21	21	None Required	Assessment Underway
October 1, 2007 - October 31, 2007	15	mg/L	mon avg	1 exceedance	30	30	Additional Monitoring Underway, Other	Assessment Underway
November 1, 2007 - November 30, 2007	15	mg/L	mon avg	1 exceedance	37	37	Other	Assessment Underway

Total C of A/Permit Non-Compliance = 4 exceedances

TOTAL AMMONIA NITROGEN

C of A/Permit Non-Compliance

August 1, 2007 - August 31, 2007	2.5	mg/L	mon avg	1 exceedance	93	93	Additional Monitoring Underway, Training/Procedure Change	Assessment Underway
September 1, 2007 - September 30, 2007	2.5	mg/L	mon avg	1 exceedance	58	58	None Required	Assessment Underway
October 1, 2007 - October 31, 2007	2.5	mg/L	mon avg	1 exceedance	23	23	Additional Monitoring Underway, Other	Assessment Underway

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to September 2008. For up-to-date information, please contact the appropriate district or area office.

2007 Municipal/Private Sewage Monthly Summary - Central Region

Piper's Heath Golf Club Ltd.

5527 Trafalgar Road
Milton

Sector: Miscellaneous
Ministry Office: Halton-Peel

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
November 1, 2007 - November 30, 2007	2.5	mg/L	mon avg	1 exceedance	8.7	8.7	Other	Assessment Underway

Total C of A/Permit Non-Compliance = 4 exceedances

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to September 2008. For up-to-date information, please contact the appropriate district or area office.

2007 Municipal/Private Sewage Monthly Summary - Central Region

**The Regional Municipality of
Durham - Duffin Creek WPCP**

901 McKay Rd
Pickering

Sector: Sewage Municipal
Ministry Office: York-Durham

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

PHOSPHORUS

C of A/Permit Non-Compliance

November 1, 2007 - November 30, 2007	1	mg/L	mon avg	1 exceedance	1.08	1.08	Other	Assessment Underway
---	---	------	---------	--------------	------	------	-------	---------------------

Total C of A/Permit Non-Compliance = 1 exceedance

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to September 2008. For up-to-date information, please contact the appropriate district or area office.

2007 Municipal/Private Sewage Monthly Summary - Central Region

The Regional Municipality of Durham - Nonquon River WPCP

8 - 1730 Scugog Line
Scugog

Sector: Sewage Municipal
Ministry Office: York-Durham

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

SUSPENDED SOLIDS

C of A/Permit Non-Compliance

January 1, 2007 - December 31, 2007	41.4	kg/d	annual avg	1 exceedance	52.7	52.7	Action Plan Submitted - Implementing Improvements, Additional Monitoring Underway	Voluntary Abatement Program Underway
--	------	------	------------	--------------	------	------	--	---

Total C of A/Permit Non-Compliance = 1 exceedance

TOTAL AMMONIA NITROGEN

C of A/Permit Non-Compliance

February 1, 2007 - February 28, 2007	3	mg/L	mon avg	1 exceedance	10.1	10.1	Action Plan Submitted - Implementing Improvements, Additional Monitoring Underway	Voluntary Abatement Program Underway
February 1, 2007 - February 28, 2007	11.7	kg/d	mon avg	1 exceedance	77.2	77.2	Action Plan Submitted - Implementing Improvements, Additional Monitoring Underway	Voluntary Abatement Program Underway
March 1, 2007 - March 31, 2007	10	mg/L	mon avg	1 exceedance	16.7	16.7	Action Plan Submitted - Implementing Improvements, Additional Monitoring Underway	Voluntary Abatement Program Underway

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to September 2008. For up-to-date information, please contact the appropriate district or area office.

2007 Municipal/Private Sewage Monthly Summary - Central Region

The Regional Municipality of Durham - Nonquon River WPCP

8 - 1730 Scugog Line
Scugog

Sector: Sewage Municipal
Ministry Office: York-Durham

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
March 1, 2007 - March 31, 2007	38.7	kg/d	mon avg	1 exceedance	139.2	139.2	Action Plan Submitted - Implementing Improvements, Additional Monitoring Underway	Voluntary Abatement Program Underway
April 1, 2007 - April 30, 2007	5	mg/L	mon avg	1 exceedance	13.24	13.24	Action Plan Submitted - Implementing Improvements, Additional Monitoring Underway	Voluntary Abatement Program Underway
April 1, 2007 - April 30, 2007	19.4	kg/d	mon avg	1 exceedance	95.03	95.03	Action Plan Submitted - Implementing Improvements, Additional Monitoring Underway	Voluntary Abatement Program Underway
May 1, 2007 - May 31, 2007	3	mg/L	mon avg	1 exceedance	18.93	18.93	Action Plan Submitted - Implementing Improvements, Additional Monitoring Underway	Voluntary Abatement Program Underway
May 1, 2007 - May 31, 2007	11.7	kg/d	mon avg	1 exceedance	116.5	116.5	Action Plan Submitted - Implementing Improvements, Additional Monitoring Underway	Voluntary Abatement Program Underway

Total C of A/Permit Non-Compliance = 8 exceedances

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to September 2008. For up-to-date information, please contact the appropriate district or area office.

2007 Municipal/Private Sewage Monthly Summary - Central Region

**The Regional Municipality of
Halton - Mid-Halton WWTP**

2195 North Service Road West
Oakville

Sector: Sewage Municipal
Ministry Office: Halton-Peel

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

LOW PH EFFLUENT

C of A/Permit Non-Compliance

August 2007	6	pH	/d	1 exceedance	5.4	5.4	Conducting Study	Assessment Underway
November 2007	6	pH	/d	1 exceedance	5.5	5.5	Conducting Study	Assessment Underway

Total C of A/Permit Non-Compliance = 2 exceedances

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to September 2008. For up-to-date information, please contact the appropriate district or area office.

2007 Municipal/Private Sewage Monthly Summary - Central Region

The Regional Municipality of Halton - Skyway WWTP

1125 Lakeshore Road
Burlington

Sector: Sewage Municipal
Ministry Office: Halton-Peel

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
LOW PH EFFLUENT								
C of A/Permit Non-Compliance								
October 2007	6	pH	/wk	1 exceedance	5.95	5.95	Additional Monitoring Underway, Other	Voluntary Abatement Program Underway
October 2007	6	pH	/wk	1 exceedance	5.94	5.94	Conducting Study	Voluntary Abatement Program Underway

Total C of A/Permit Non-Compliance = 2 exceedances

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to September 2008. For up-to-date information, please contact the appropriate district or area office.

2007 Municipal/Private Sewage Monthly Summary - Central Region

Woodbine Entertainment Group

555 Rexdale Blvd
Toronto

Sector: Miscellaneous
Ministry Office: Toronto

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

ESCHERICHIA COLI

C of A/Permit Non-Compliance

January 1, 2007 - December 31, 2007	200	CT/100 mL	annual avg	1 exceedance	215	215	Additional Monitoring Underway	Assessment Complete - No Action Required
--	-----	--------------	------------	--------------	-----	-----	-----------------------------------	---

Total C of A/Permit Non-Compliance = 1 exceedance

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to September 2008. For up-to-date information, please contact the appropriate district or area office.

2007 Municipal/Private Sewage Monthly Summary - Central Region

York Catholic District School Board - St. Mary's School

75 Greenside Dr
King

Sector: Miscellaneous
Ministry Office: York-Durham

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

AMMONIA + NITRATE + NITRITE NITROGEN

C of A/Permit Non-Compliance

January 1, 2007 - June 30, 2007	2.5	mg/L	seasonal avg	2 exceedances	2.6	4.5	Conducting Study	Assessment Underway
------------------------------------	-----	------	-----------------	---------------	-----	-----	------------------	---------------------

Total C of A/Permit Non-Compliance = 2 exceedances

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to September 2008. For up-to-date information, please contact the appropriate district or area office.