

## 2007 Municipal/Private Sewage Monthly Summary - Northern Region

**City of Greater Sudbury -  
Sudbury WWTP**

1173 Kelly Lake Rd  
Greater Sudbury

**Sector:** Sewage Municipal  
**Ministry Office:** Sudbury

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
<b>ESCHERICHIA COLI</b>								
<b>C of A/Permit Non-Compliance</b>								
September 2007	500	CT/100 mL	mon avg. on a geo. mean density	1 exceedance	10000	10000	Other, Training/Procedure Change	Assessment Complete - No Action Required

**Total C of A/Permit Non-Compliance = 1 exceedance**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to September 2008. For up-to-date information, please contact the appropriate district or area office.

## 2007 Municipal/Private Sewage Monthly Summary - Northern Region

### City of Greater Sudbury - Walden STP

Lot: 10, Conc: 3, Walden STP  
Greater Sudbury

**Sector:** Sewage Municipal  
**Ministry Office:** Sudbury

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

### ESCHERICHIA COLI

#### C of A/Permit Non-Compliance

September 12, 2007 - September 17, 2007	200	CT/100 mL	mon avg. on a geo. mean density	2 exceedances	2160	10000	None Required	Assessment Complete - No Action Required
--	-----	--------------	--	---------------	------	-------	---------------	---

**Total C of A/Permit Non-Compliance = 2 exceedances**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to September 2008. For up-to-date information, please contact the appropriate district or area office.

## 2007 Municipal/Private Sewage Monthly Summary - Northern Region

### De Beers Canada Inc.

90 km W of Attawapiskat  
Unsurveyed Territory (Timmins D. O.)

**Sector:** Miscellaneous  
**Ministry Office:** Timmins

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

### ESCHERICHIA COLI

#### C of A/Permit Non-Compliance

January 2007	200	CT/100 mL	mon avg	1 exceedance	400	400	New Equipment or Treatment Process Installed	Assessment Complete - No Action Required
--------------	-----	--------------	---------	--------------	-----	-----	---	---

**Total C of A/Permit Non-Compliance = 1 exceedance**

### SUSPENDED SOLIDS

#### C of A/Permit Non-Compliance

January 2007	30	mg/l	/d	1 exceedance	67	67	New Equipment or Treatment Process Installed	Assessment Complete - No Action Required
--------------	----	------	----	--------------	----	----	---	---

**Total C of A/Permit Non-Compliance = 1 exceedance**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to September 2008. For up-to-date information, please contact the appropriate district or area office.

## 2007 Municipal/Private Sewage Monthly Summary - Northern Region

### North Bay Psychiatric Hospital

4700 Highway 11 N  
North Bay

**Sector:** Miscellaneous  
**Ministry Office:** North Bay

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

#### HIGH PH EFFLUENT

##### C of A/Permit Non-Compliance

November 2007	9.5	pH	any	1 exceedance	9.6	9.6	Operational Process Modification	Assessment Complete - No Action Required
---------------	-----	----	-----	--------------	-----	-----	----------------------------------	--

**Total C of A/Permit Non-Compliance = 1 exceedance**

#### LOW PH EFFLUENT

##### C of A/Permit Non-Compliance

October 2007	6	pH	any	1 exceedance	5.6	5.6	Operational Process Modification	Assessment Complete - No Action Required
--------------	---	----	-----	--------------	-----	-----	----------------------------------	--

**Total C of A/Permit Non-Compliance = 1 exceedance**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to September 2008. For up-to-date information, please contact the appropriate district or area office.

## 2007 Municipal/Private Sewage Monthly Summary - Northern Region

**The Corporation of the City of  
Sault Ste. Marie - Sault Ste. Marie  
East End STP**

2221 Queen St E  
Sault Ste. Marie

**Sector:** Sewage Municipal  
**Ministry Office:** Sault Ste. Marie

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

### LOW PH EFFLUENT

#### C of A/Permit Non-Compliance

June 2007	6	pH	any	1 exceedance	5.35	5.35	Other	Assessment Complete - No Action Required
-----------	---	----	-----	--------------	------	------	-------	--

**Total C of A/Permit Non-Compliance = 1 exceedance**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to September 2008. For up-to-date information, please contact the appropriate district or area office.

## 2007 Municipal/Private Sewage Monthly Summary - Northern Region

**The Corporation of the City of  
Temiskaming Shores - Haileybury  
STP**

100 View St  
Haileybury

**Sector:** Sewage Municipal  
**Ministry Office:** North Bay

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

### SUSPENDED SOLIDS

#### C of A/Permit Non-Compliance

January 1, 2007 - December 31, 2007	25	mg/L	annual avg	1 exceedance	46.7	46.7	Equipment Modified, Repaired, Replaced or Re- calibrated	Assessment Complete - No Action Required
--	----	------	------------	--------------	------	------	--	---

**Total C of A/Permit Non-Compliance = 1 exceedance**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to September 2008. For up-to-date information, please contact the appropriate district or area office.

## 2007 Municipal/Private Sewage Monthly Summary - Northern Region

**The Corporation of the City of  
Temiskaming Shores - New  
Liskeard Lagoon**

Lot 6 & 7 , Conc. 3  
Dymond

**Sector:** Sewage Municipal  
**Ministry Office:** North Bay

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

### PHOSPHORUS

#### C of A/Permit Non-Compliance

January 1, 2007 - December 31, 2007	1	mg/L	annual avg	1 exceedance	1.8	1.8	Equipment Modified, Repaired, Replaced or Re- calibrated	Assessment Complete - No Action Required
--	---	------	------------	--------------	-----	-----	--	---

**Total C of A/Permit Non-Compliance = 1 exceedance**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to September 2008. For up-to-date information, please contact the appropriate district or area office.

## 2007 Municipal/Private Sewage Monthly Summary - Northern Region

**The Corporation of the City of  
Temiskaming Shores - North  
Cobalt Lagoon**

Lakeview Drive  
Haileybury

**Sector:** Sewage Municipal  
**Ministry Office:** North Bay

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

### BIOCHEMICAL OXYGEN DEMAND

#### C of A/Permit Non-Compliance

May 1, 2007 - May 31, 2007	25	mg/L	mon avg	1 exceedance	30	30	New/Modified Sampling Program Underway, Operational Process Modification	Assessment Complete - No Action Required
-------------------------------	----	------	---------	--------------	----	----	---	---

**Total C of A/Permit Non-Compliance = 1 exceedance**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to September 2008. For up-to-date information, please contact the appropriate district or area office.

## 2007 Municipal/Private Sewage Monthly Summary - Northern Region

### The Corporation of the Municipality of Sioux Lookout - Sioux Lookout WPCP

148 King St W  
Sioux Lookout

**Sector:** Sewage Municipal  
**Ministry Office:** Kenora

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

### BIOCHEMICAL OXYGEN DEMAND

#### C of A/Permit Non-Compliance

May 1, 2007 - May 31, 2007	25	mg/L	mon avg	1 exceedance	66.5	66.5	Additional Monitoring Underway, Operational Process Modification	Assessment Complete - Incident Resolved, Assessment Complete - No Action Required
-------------------------------	----	------	---------	--------------	------	------	--	---

**Total C of A/Permit Non-Compliance = 1 exceedance**

### SUSPENDED SOLIDS

#### C of A/Permit Non-Compliance

February 1, 2007 - February 28, 2007	25	mg/L	mon avg	1 exceedance	27.5	27.5	Other	Assessment Complete - No Action Required
May 1, 2007 - May 31, 2007	25	mg/L	mon avg	1 exceedance	290.6	290.6	Additional Monitoring Underway, Operational Process Modification	Assessment Complete - Incident Resolved, Assessment Complete - No Action Required

**Total C of A/Permit Non-Compliance = 2 exceedances**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to September 2008. For up-to-date information, please contact the appropriate district or area office.

## 2007 Municipal/Private Sewage Monthly Summary - Northern Region

**The Corporation of the  
Municipality of Temagami -  
Temagami South WPCP**

Temagami South Lagoons  
Temagami

**Sector:** Sewage Municipal  
**Ministry Office:** North Bay

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

### SUSPENDED SOLIDS

#### C of A/Permit Non-Compliance

May 15, 2007 - June 15, 2007	25	mg/L	seasonal avg	1 exceedance	26	26	Conducting Study	Assessment Underway
---------------------------------	----	------	-----------------	--------------	----	----	------------------	---------------------

**Total C of A/Permit Non-Compliance = 1 exceedance**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to September 2008. For up-to-date information, please contact the appropriate district or area office.

## 2007 Municipal/Private Sewage Monthly Summary - Northern Region

### The Corporation of the Town of Blind River - Blind River STP

15 Martin St  
Blind River

**Sector:** Sewage Municipal  
**Ministry Office:** Sault Ste. Marie

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

#### SUSPENDED SOLIDS

##### C of A/Permit Non-Compliance

March 2007	25	mg/L	any	1 exceedance	197	197	None required	Other Abatement action taken
April 2007	25	mg/L	any	1 exceedance	198	198	None Required	Other Abatement action taken

**Total C of A/Permit Non-Compliance = 2 exceedances**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to September 2008. For up-to-date information, please contact the appropriate district or area office.

## 2007 Municipal/Private Sewage Monthly Summary - Northern Region

**The Corporation of the Town of  
Fort Frances - Fort Frances  
WWTP**

200 McIrvine Rd  
Fort Frances

**Sector:** Sewage Municipal  
**Ministry Office:** Kenora

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

### SUSPENDED SOLIDS

#### C of A/Permit Non-Compliance

November 2007	25	mg/L	/d	1 exceedance	555	555	Other	Assessment Complete - No Action Required
---------------	----	------	----	--------------	-----	-----	-------	--

**Total C of A/Permit Non-Compliance = 1 exceedance**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to September 2008. For up-to-date information, please contact the appropriate district or area office.

## 2007 Municipal/Private Sewage Monthly Summary - Northern Region

**The Corporation of the Town of  
Iroquois Falls - Iroquois Falls STP**

2 Northwest Industrial Rd  
Iroquois Falls

**Sector:** Sewage Municipal  
**Ministry Office:** Timmins

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
<b>ESCHERICHIA COLI</b>								
<b>C of A/Permit Non-Compliance</b>								
May 1, 2007 - May 31, 2007	200	CT/100 mL	mon avg. on a geo. mean density	1 exceedance	211	211	None Required	Assessment Complete - No Action Required

**Total C of A/Permit Non-Compliance = 1 exceedance**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to September 2008. For up-to-date information, please contact the appropriate district or area office.

## 2007 Municipal/Private Sewage Monthly Summary - Northern Region

**The Corporation of the Town of  
Smooth Rock Falls - Smooth Rock  
Falls STP**

142 First St  
Smooth Rock Falls

**Sector:** Sewage Municipal  
**Ministry Office:** Timmins

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

### ESCHERICHIA COLI

#### C of A/Permit Non-Compliance

March 1, 2007 - December 31, 2007	200	CT/100 mL	mon avg	8 exceedances	269.18	3868.5	Conducting Study	Voluntary Abatement Program Underway
--------------------------------------	-----	--------------	---------	---------------	--------	--------	------------------	---

**Total C of A/Permit Non-Compliance = 8 exceedances**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to September 2008. For up-to-date information, please contact the appropriate district or area office.

## 2007 Municipal/Private Sewage Monthly Summary - Northern Region

### The Corporation of the Township of Ear Falls - Ear Falls WWTP

KM275 Part 1 Aspen St  
Ear Falls

**Sector:** Sewage Municipal  
**Ministry Office:** Kenora

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

### ESCHERICHIA COLI

#### C of A/Permit Non-Compliance

November 2007	200	cfu/100 /d ml		1 exceedance	750	750	Equipment Modified, Repaired, Replaced or Re- calibrated	Assessment Complete - No Action Required
---------------	-----	------------------	--	--------------	-----	-----	--	---

**Total C of A/Permit Non-Compliance = 1 exceedance**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to September 2008. For up-to-date information, please contact the appropriate district or area office.

## 2007 Municipal/Private Sewage Monthly Summary - Northern Region

### The Corporation of the Township of Emo - Emo Lagoon

West of Emo Fair Grounds  
Emo

**Sector:** Sewage Municipal  
**Ministry Office:** Kenora

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

### PHOSPHORUS

#### C of A/Permit Non-Compliance

May 1, 2007 - November 30, 2007	1	mg/L	mon avg	2 exceedances	1.3	1.35	Operational Process Modification	Assessment Underway
------------------------------------	---	------	---------	---------------	-----	------	-------------------------------------	---------------------

**Total C of A/Permit Non-Compliance = 2 exceedances**

### SUSPENDED SOLIDS

#### C of A/Permit Non-Compliance

May 1, 2007 - May 31, 2007	30	mg/L	mon avg	1 exceedance	34.33	34.33	Operational Process Modification	Assessment Underway
-------------------------------	----	------	---------	--------------	-------	-------	-------------------------------------	---------------------

**Total C of A/Permit Non-Compliance = 1 exceedance**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to September 2008. For up-to-date information, please contact the appropriate district or area office.

## 2007 Municipal/Private Sewage Monthly Summary - Northern Region

### The Corporation of the Township of Manitouwadge - Manitouwadge STP

Lot M179, Conc BLKA  
Manitouwadge

**Sector:** Sewage Municipal  
**Ministry Office:** Thunder Bay

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

### BIOCHEMICAL OXYGEN DEMAND

#### C of A/Permit Non-Compliance

February 2007	25	mg/L	/2wk	2 exceedances	42	54	Equipment Modified, Repaired, Replaced or Re- calibrated	Assessment Complete - Incident Resolved
March 2007	25	mg/L	/2wk	3 exceedances	43	59	Equipment Modified, Repaired, Replaced or Re- calibrated	Assessment Underway
March 2007	25	mg/L	/2wk	1 exceedance	30	30	New/Modified Sampling Program Underway	Assessment Complete - Incident Resolved
March 2007	25	mg/L	/2wk	1 exceedance	54	54	None Required	Assessment Complete - Incident Resolved
March 2007	25	mg/L	/2wk	1 exceedance	44	44	Operational Process Modification	Assessment Underway

**Total C of A/Permit Non-Compliance = 8 exceedances**

### SUSPENDED SOLIDS

#### C of A/Permit Non-Compliance

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to September 2008. For up-to-date information, please contact the appropriate district or area office.

## 2007 Municipal/Private Sewage Monthly Summary - Northern Region

### The Corporation of the Township of Manitouwadge - Manitouwadge STP

Lot M179, Conc BLKA  
Manitouwadge

**Sector:** Sewage Municipal  
**Ministry Office:** Thunder Bay

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
May 2007	30	mg/L	/2wk	1 exceedance	31	31	Additional Monitoring Underway	Assessment Complete - Incident Resolved

**Total C of A/Permit Non-Compliance = 1 exceedance**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to September 2008. For up-to-date information, please contact the appropriate district or area office.