

Ontario Tap Water Order

Lead Testing Results for Township of North Glengarry

NORTH GLENGARRY, THE CORPORATION OF THE TOWNSHIP OF

Alexandria

5 distribution (hydrant) samples / 20 tap samples

Municipal Hydrant ID: H-00

Distribution (Hydrant)	June 5, 2007	Lead = 0.16 ug/L	pH=6.86 Alkalinity = 94 mg/L CaCO ₃
Tap	June 5, 2007	Lead = 0.21 ug/L	
Tap	June 5, 2007	Lead = 0.13 ug/L	
Tap	June 5, 2007	Lead = 0.21 ug/L	

Municipal Hydrant ID: H-312

Distribution (Hydrant)	June 6, 2007	Lead = 0.2 ug/L	pH=6.92 Alkalinity = 92 mg/L CaCO ₃
Tap	June 6, 2007	Lead = 0.16 ug/L	
Tap	June 6, 2007	Lead = 0.4 ug/L	
Tap	June 6, 2007	Lead = 0.14 ug/L	

Municipal Hydrant ID: H-319

Distribution (Hydrant)	June 5, 2007	Lead = 0.17 ug/L	pH=6.88 Alkalinity = 95 mg/L CaCO ₃
Tap	June 5, 2007	Lead = 0.17 ug/L	
Tap	June 5, 2007	Lead = 0.14 ug/L	
Tap	June 5, 2007	Lead = 0.23 ug/L	

Ontario Tap Water Order - Lead Testing Results


NORTH GLENGARRY, THE CORPORATION OF THE TOWNSHIP OF

Municipal Hydrant ID: H-34

Distribution (Hydrant)	June 5, 2007	Lead = 0.15 ug/L	pH=6.87 Alkalinity = 94 mg/L CaCO ₃
Tap	June 5, 2007	Lead = 0.21 ug/L	
Tap	June 5, 2007	Lead = 0.12 ug/L	
Tap	June 5, 2007	Lead = 0.19 ug/L	
Tap	June 5, 2007	Lead = 0.36 ug/L	
Tap	June 5, 2007	Lead = 0.18 ug/L	
Tap	June 5, 2007	Lead = 0.63 ug/L	
Tap	June 5, 2007	Lead = 0.13 ug/L	
Tap	June 5, 2007	Lead = 0.32 ug/L	

Municipal Hydrant ID: H-45

Distribution (Hydrant)	June 6, 2007	Lead = 0.16 ug/L	pH=6.88 Alkalinity = 93 mg/L CaCO ₃
Tap	June 6, 2007	Lead = 0.02 ug/L	
Tap	June 6, 2007	Lead = 0.22 ug/L	
Tap	June 6, 2007	Lead = 0.21 ug/L	

 Blue indicates lead result above Provincial Standard (10 ug/L)